

19 June 2026

Our reference: 234490, 216968

Penny White

Department of Planning, Housing and Infrastructure
penny.white@planning.nsw.gov.au

RE: SSD-23480429 at 253-267 Aldington Road, Kemps Creek (Westgate Industrial Estate)

Thank you for notifying Sydney Water of SSD-23480429 at 253-267 Aldington Road, Kemps Creek, within the Mamre Precinct. The SSDA will seek consent for the following:

- Introduction of additional inter-tenancy wall converting approved Warehouse 1B and 1C building into three warehouse tenancies, to be described as Warehouse 1B, 1C and 1D.
- Consolidation and re-distribution of ancillary office space to support three warehouse tenancies, resulting in a 578m² reduction in total warehouse GFA from 13,540m² to 12,962m², and an increase in ancillary office GFA of 103m², from 614m² to 717m².
- Modified parking provision of 62 spaces, 44 undercroft spaces and 18 at-grade spaces.
- Provision of an additional maintenance vehicle parking area to meet Sydney Water requirements.
- Relocation of undercroft carparking driveway access to western end of Lot 1, accessible via road 2.

We have reviewed the following documents supplied and provide the following comments to assist in understanding the servicing needs of the proposed development.

- Modification Report_253-267 Aldington Road, Kemps
- Appendix H_Civil Drawings_253 - 267 Aldington Road, Kemps Creek
- Appendix I_Civil Letter of Consistency_253 - 267 Aldington Road, Kemps Creek

Water, Wastewater and Recycled Water Servicing

The proponent has received servicing information under their active Section 73 application, CN216968. The proponent should update their Section 73 application as soon as possible to reflect the proposed modifications.

Stormwater Servicing

Sydney Water is satisfied that the Proposed Modification will not materially impact the Mamre Road Precinct Stormwater Scheme Plan, and has no further comment to make regarding stormwater servicing at this time.

Infrastructure Contributions

- Proponents will be required to pay infrastructure contributions towards Sydney Water's stormwater and recycled water servicing. Sydney Water is preparing a Development Servicing Plan (DSP) for the recycled water and trunk drainage in the Aerotropolis Initial Precincts. This DSP will determine the amount of the stormwater and recycled water Infrastructure Contributions to be paid to Sydney Water for the development.
- Proponents should also be aware that infrastructure contributions are payable for drinking water and wastewater.
- More information on drinking water and wastewater contributions can be found at [land development](#) and the Sydney Water Development Application Information Sheet (for proponent) enclosed.

Next steps

- Should the Department of Planning, Housing and Infrastructure (the Department) decide to progress with the subject development application, Sydney Water would require the following conditions be included in the development consent.
 - Section 73 Compliance Certificate
 - Building Plan Approval

Further details of the conditions can be found in Attachment 1.

- The proponent should update their Section 73 application as soon as possible to reflect the proposed modifications to the development.
- The Department is advised to forward the enclosed Sydney Water Development Application Information Sheet (for proponent) to assist the proponent in progressing their development. This Info Sheet contains details on how to make further applications to Sydney Water and provides more information on Infrastructure Contributions.

This advice is not formal approval of our servicing requirements. Detailed requirements, including any potential extensions or amplifications, will be provided once the development is referred to Sydney Water for a Section 73 application. More information about the Section 73 application process is available on our web page in the [Land Development Manual](#).

Please note that the available capacity may change over time depending on the rate of development and increased demand elsewhere in the potable water and wastewater catchments. Sydney Water does not reserve capacity pre-development, and it is advised that the proponent applies directly to Sydney Water for a Section 73 Compliance Certificate as soon as feasible.

The Department can read further advice on requirements for this proposal in Attachments 1 and 2. If the proponent has any questions, they should contact their Sydney Water Account Manager. Should the Department require further information, please contact Joanne Chan from the Growth Analytics Team at urbangrowth@sydneywater.com.au.

Yours sincerely,

Growth Analytics Team

Growth and Development, Water and Environment Services
Sydney Water, 1 Smith Street, Parramatta NSW 2150

Enclosed:

- Sydney Water Development Application Information Sheet (for proponent)

Attachment 1 – Recommended Development Conditions

Prior to the issue of an Occupation/Subdivision Certificate:

Section 73 Compliance Certificate

A compliance certificate must be obtained from Sydney Water, under Section 73 of the Sydney Water Act 1994. Our assessment will determine the availability of water and wastewater services, which may require extensions, adjustments, or connections to our mains. The compliance certificate also identifies any applicable Infrastructure Contribution charges. Make an early application for the certificate, as there may be assets to be built and this can take some time. A Section 73 Compliance Certificate must be obtained before an Occupation or Subdivision Certificate will be issued.

Applications can be made either directly to Sydney Water or through a Sydney Water accredited Water Servicing Coordinator.

Go to the Sydney Water website or call 1300 082 746 to learn more about applying through an authorised WSC or Sydney Water.

Prior to the issue of a Construction Certificate/Complying Development Certificate:

Building Plan Approval (including Tree Planting Guidelines)

The plans must be approved by Sydney Water prior to demolition, excavation or construction works commencing. This allows Sydney Water to determine if sewer, water or stormwater mains or easements will be affected by any part of your development. Any amendments to plans will require re-approval. Please go to [Sydney Water Tap in®](#) to apply.

Sydney Water recommends developers apply for a Building Plan Approval early as to reduce unnecessary delays to further referrals or development timescales.

Tree Planting

Certain tree species placed in proximity to Sydney Water's underground assets have the potential to inflict damage through invasive root penetration and soil destabilisation. Section 46 of the Sydney Water Act specifies what might occur when there is interference or damage to our assets caused by trees.

For any trees proposed or planted that may cause destruction of, damage to or interference with our work and are in breach of the Sydney Water Act 1994, Sydney Water may issue an order to remove that tree or directly remove it and seek recovery for all loss and associated compensation for the removal.

For guidance on types of trees that can cause damage or interference with our assets see Sydney Water webpage Wastewater blockages. For guidance on how to plant trees near our assets, see Diagram 5 – Planting Trees within Sydney Water's [Technical guidelines – Building over and adjacent to pipe assets](#).

Attachment 2 – Sydney Water Requirements for Commercial and Industrial Developments (for proponent’s information)

Trade Wastewater Requirements

If this development is going to generate trade wastewater, the property owner must submit an application requesting permission to discharge trade wastewater to Sydney Water’s sewerage system. You must obtain Sydney Water approval for this permit before any business activities can commence. It is illegal to discharge Trade Wastewater into the Sydney Water sewerage system without permission.

The permit application should be emailed to Sydney Water’s Business Customer Services at businesscustomers@sydneywater.com.au.

A Boundary Trap is required for all developments that discharge trade wastewater where arrestors and special units are installed for trade wastewater pre-treatment.

If the property development is for Industrial operations, the wastewater may discharge into a sewerage area that is subject to wastewater reuse. Find out from Business Customer Services if this is applicable to your development.

Backflow Prevention Requirements

Backflow is when there is unintentional flow of water in the wrong direction from a potentially polluted source into the drinking water supply.

All properties connected to Sydney Water's supply must install a testable Backflow Prevention Containment Device appropriate to the property's hazard rating. Property with a high or medium hazard rating must have the backflow prevention containment device tested annually. Properties identified as having a low hazard rating must install a non-testable device, as a minimum.

Separate hydrant and sprinkler fire services on non-residential properties, require the installation of a testable double check detector assembly. The device is to be located at the boundary of the property.

Before you install a backflow prevention device:

1. Get your hydraulic consultant or plumber to check the available water pressure versus the property’s required pressure and flow requirements.
2. Conduct a site assessment to confirm the hazard rating of the property and its services. Contact PIAS at NSW Fair Trading on 1300 889 099.

For installation you will need to engage a licensed plumber with backflow accreditation who can be found on the Sydney Water website:

<https://www.sydneywater.com.au/plumbing-building-developing/plumbing/backflow-prevention.html>

Water Efficiency Recommendations

Water is our most precious resource and every customer can play a role in its conservation. By working together with Sydney Water, business customers are able to reduce their water consumption. This will help your business save money, improve productivity and protect the environment.

Some water efficiency measures that can be easily implemented in your business are:

- Install water efficiency fixtures to help increase your water efficiency, refer to WELS (Water Efficiency Labelling and Standards (WELS) Scheme, <http://www.waterrating.gov.au/>
- Consider installing rainwater tanks to capture rainwater runoff, and reusing it, where cost effective. Refer to <https://www.sydneywater.com.au/your-business/managing-your-water-use/water-efficiency-tips.html>
- Install water-monitoring devices on your meter to identify water usage patterns and leaks.
- Develop a water efficiency plan for your business.

It is cheaper to install water efficiency appliances while you are developing than retrofitting them later.

Contingency Plan Recommendations

Under Sydney Water's customer contract Sydney Water aims to provide Business Customers with a continuous supply of clean water at a minimum pressure of 15meters head at the main tap. This is equivalent to 146.8kpa or 21.29psi to meet reasonable business usage needs.

Sometimes Sydney Water may need to interrupt, postpone or limit the supply of water services to your property for maintenance or other reasons. These interruptions can be planned or unplanned.

Water supply is critical to some businesses and Sydney Water will treat vulnerable customers, such as hospitals, as a high priority.

Have you thought about a contingency plan for your business? Your Business Customer Representative will help you to develop a plan that is tailored to your business and minimises productivity losses in the event of a water service disruption.

For further information please visit the Sydney Water website at: <https://www.sydneywater.com.au/your-business/managing-trade-wastewater/commercial-trade-wastewater.html> or contact Business Customer Services on 1300 985 227 or businesscustomers@sydneywater.com.au.