

8 November 2021

Minoshi Weerasinghe

Senior Planning Officer

Key Sites Assessments

Department of Planning, Industry and Environment

4 Parramatta Square, 12 Darcy Street, Parramatta NSW 2150

Minoshi.Weerasinghe@planning.nsw.gov.au

RE: Sydney Water input to SEARs - SSD-30855273 for Shelbourne Hotel Redevelopment at 200-202 Sussex Street, Sydney

Thank you for seeking Sydney Water's input on the Secretary's Environmental Assessment Requirements for the abovementioned SSD which proposes for a residential/serviced apartment tower and commercial and retail uses in the podium levels. We have reviewed the proposal and provide the following comments for your consideration.

Sydney Water requests that the Department of Planning, Industry and Environment include the following Secretary's Environmental Assessment Requirements relating to the provision of water-related services for the subject site:

Water-related Infrastructure Requirements

1. The proponent of the development should determine service demands following servicing investigations and demonstrate that satisfactory arrangements for drinking water, wastewater, and, recycled water services have been made.
2. The proponent must obtain endorsement and/or approval from Sydney Water to ensure that the proposed development does not adversely impact on any existing water, wastewater or stormwater main, or any other Sydney Water asset, including any easement or property.
3. When determining landscaping options, the proponent should take into account that certain tree species can cause cracking or blockage of Sydney Water pipes and therefore should be avoided.
4. Strict requirements for Sydney Water's stormwater assets (for certain types of development) may apply to this site. The proponent should ensure that satisfactory steps/measures been taken to protect existing stormwater assets, such as avoiding building over and/or adjacent to stormwater assets and building bridges over stormwater assets. The proponent should consider taking measures to minimise or eliminate potential flooding, degradation of water quality, and avoid adverse impacts on any heritage items, and create pipeline easements where required.
5. As this development creates trade wastewater, Sydney Water has trade wastewater requirements which need to be met. By law, the property owner must submit an

application requesting permission to discharge trade wastewater to Sydney Water's sewerage system. The proponent must obtain Sydney Water approval for this permit before any business activities can commence. Given this development comprises industrial operations, wastewater may discharge into a sewerage area that is subject to wastewater reuse. Please contact Sydney Water's Business Customer Services to send your permit application or to find out more information. They can be contacted at the following email address: businesscustomers@sydneywater.com.au.

Integrated Water Cycle Management

6. The proponent should outline any sustainability initiatives that will minimise/reduce the demand for drinking water, including any alternative water supply and end uses of drinking and non-drinking water that may be proposed, and demonstrate water sensitive urban design (principles are used), and any water conservation measures that are likely to be proposed. This will allow Sydney Water to determine the impact of the proposed development on our existing services and required system capacity to service the development.

If you require any further information, please contact the Growth Planning Team at urbangrowth@sydneywater.com.au.

Yours sincerely,



Kristine Leitch
Commercial Growth Manager
City Growth and Development, Business Development
Sydney Water, 1 Smith Street, Parramatta NSW 2150