

30 June 2022

Our Ref: 158607

Thomas Bertwistle

Energy, Resources and Industry Assessments

Department of Planning and Environment

Thomas.Bertwistle@planning.nsw.gov.au

RE: SSD-37558583 Lot 1 Bringelly Road Business Hub – Warehouse Facility at 5 Skyline Crescent, Horningsea Park

Thank you for notifying Sydney Water of SSD-37558583 at 5 Skyline Crescent, Horningsea Park, which proposes site preparatory works including clearing of all existing vegetation and bulk earthworks, construction of a new warehouse building comprising a warehouse facility with a GFA of 4,470m² and ancillary office space with a GFA of 1,000m² and associated works. Sydney Water has reviewed the application based on the information supplied and provides the following comments to assist in planning the servicing needs of the proposed development.

Water Servicing

- Potable water servicing should be available via a 200mm CICL watermain (laid in 1954) in Stuart Road.
- A 150mm watermain is in Skyline Crescent and adjustments may be required. Further details will be provided when the development is referred to Sydney Water at the Section 73 stage.

Wastewater Servicing

- Wastewater servicing should be available via a 225mm PP wastewater main (laid in 2020) on Skyline Crescent.
- Amplifications, adjustments, and/or minor extensions may be required.

Critical Assets

- A 600mm SCL trunk watermain traverses the north of the site and an associated stop valve is in the proposed truck carparking area.
- **The 600mm trunk watermain is a critical asset which feeds Carnes Hill Remainder Zone from Carnes Hill Reservoir.**
- Please ensure the proposed development zone of influence does not include the 600mm trunk water main in Skyline Crescent and the development site. If the development zone of influence includes this main, an Out of Scope Building Planning Approval may be required.

This advice is not formal approval of our servicing requirements. Detailed requirements, including any potential extensions or amplifications, will be provided once the development is referred to Sydney Water for a Section 73 application. More information about the Section 73 application process is available on our web page in the [Land Development Manual](#).

Further advice and requirements for this proposal are in Attachment 1. If you require any further information, please contact the Growth Planning Team at urbangrowth@sydneywater.com.au.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'K. Leitch', with a stylized flourish extending to the right.

Kristine Leitch

Commercial Growth Manager

City Growth and Development, Business Development Group

Sydney Water, 1 Smith Street, Parramatta NSW 2150

Attachment 1

Section 73 Compliance Certificate

A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained from Sydney Water.

The proponent is advised to make an early application for the certificate, as there may be water and wastewater pipes to be built that can take some time. This can also impact on other services and buildings, driveways or landscape designs.

Applications must be made through an authorised Water Servicing Coordinator. For help either visit www.sydneywater.com.au > Plumbing, building and developing > Developing > Land development or telephone 13 20 92.

Building Plan Approval

The approved plans must be submitted to the Sydney Water [Tap in™](#) online service to determine whether the development will affect any Sydney Water sewer or water main, stormwater drains and/or easement, and if further requirements need to be met.

The [Tap in™](#) service provides 24/7 access to a range of services, including:

- building plan approvals
- connection and disconnection approvals
- diagrams
- trade waste approvals
- pressure information
- water meter installations
- pressure boosting and pump approvals
- changes to an existing service or asset, e.g. relocating or moving an asset.

Sydney Water's [Tap in™](#) online service is available at:

<https://www.sydneywater.com.au/SW/plumbing-building-developing/building/sydney-water-tap-in/index.htm>

Sydney Water recommends developers apply for Building Plan approval early as in some instances the initial assessment will identify that an Out of Scope Building Plan Approval will be required.

Out of Scope Building Plan Approval

Sydney Water will need to undertake a detailed review of building plans:

1. That affect or are likely to affect any of the following:
 - Wastewater pipes larger than 300mm in size
 - Pressure wastewater pipes
 - Drinking water or recycled water pipes
 - Our property boundary
 - An easement in our favour
 - Stormwater infrastructure within 10m of the property boundary.
2. Where the building plan includes:
 - Construction of a retaining wall over, or within the zone of influence of our assets
 - Excavation of a basement or building over, or adjacent to, one of our assets
 - Dewatering – removing water from solid material or soil.

The detailed review is to ensure that:

- our assets will not be damaged during, or because of the construction of the development
- we can access our assets for operation and maintenance
- your building will be protected if we need to work on our assets in the future.

The developer will be required to pay Sydney Water for the costs associated with the detailed review.

Tree Planting

Certain tree species placed in close proximity to Sydney Water's underground assets have the potential to inflict damage through invasive root penetration and soil destabilisation. Sydney Water requires that all proposed or removed trees and vegetation included within the proposal adhere to the specifications and requirements within Section 46 of the Sydney Water Act (1994) and *Diagram 5 – Planting Trees* within our [Technical guidelines – Building over and adjacent to pipe assets](#). Please note these guidelines include more examples of potential activities impacting our assets which may also apply to your development.

If any tree planting proposed breaches our policy, Sydney Water may need to issue an order to remove every tree breaching the act, or directly remove every tree breaching the Act and bill the developer or Council for their removal.