

Our ref: SSD-47662959-PA-22

Kathryn Saunders
Senior Advisor, Town Planning (Post Approval & Compliance)
Health Administration Corporation NSW
C/o Health Infrastructure NSW
1 Reserve Road
St Leonards, NSW 2065

Attn: Stephanie Jackman (stephanie.jackman@health.nsw.gov.au)

07/02/2025

RPA Redevelopment (SSD-47662959)
Operational Noise Monitoring Report, Condition E8

Dear Ms Saunders

I refer to your submission regarding Operational noise monitoring to the Planning Secretary under condition E8 of SSD-47662959.

I note the submission:

- was reviewed by the Applicant, and no issues were raised to the Department;
- relates specifically to Operational Stage 3 (OC3) for the Temporary Helipad Landing Site (THLS);
- confirms that noise monitoring was undertaken on Tuesday 14 January 2025, by Acoustic Logic, confirming in their letter dated 20 January 2025 that attended noise measurements of the Carpark during normal operational conditions complies with condition E8;
- was submitted within 2 months of the commencement of Stage 3 (OC3) notified to the Department as 5 December 2024 under PA-14; and
- states in a letter dated 22 January 2025 that:
 - limited new mechanical plant being installed and commissioned as part of OC3 to facilitate operational components of the temporary helipad, such as operation of the lifts and comms room, attached to the existing Multi-storey Carpark; and
 - operational noise levels do not exceed the recommended noise levels for mechanical plant identified in the ARUP report, and thus no noise attenuation measures are necessary and as such compliance with condition E8 has been achieved.

Also, I note that no short-term noise monitoring for Stages OP1 and OP2 was submitted to the Department due to no mechanical plant, as agreed by the Planning Secretary on 1 August 2024 under PA-11.

Accordingly, the Department has filed your submission for our information.

Please note that if there are any inconsistencies between the submission and the conditions of consent, the conditions will prevail.

Also, please make the Acoustic Logic letter with the Department letter available for public access on the project website as per condition A22.

Should you have any questions, please contact Jeremy Martin at jeremy.martin@dpie.nsw.gov.au.

Yours sincerely

A handwritten signature in black ink, appearing to read 'Shiraz Ahmed', with a long horizontal flourish extending to the right.

Shiraz Ahmed
Team Leader - Social Infrastructure Projects
Infrastructure Management

As nominee of the Planning Secretary