



Residential Care Facility

Land adjoining 97 Kesterton Rise North Rothbury

Regulatory Compliance Report

BCA Assessment

Prepared for: Arcare – Huntlee

Date: 22 August 2024

Revision: 2

Table of Contents

1.	Executive Summary	3
2.	Introduction	5
3.	Compliance with the BCA	5
4.	Documentation of Performance Solutions	6
5.	Preliminaries	6
6.	Structure	8
7.	Fire Protection	8
8.	Access and Egress	14
9.	Services and Equipment	17
10.	Health and Amenity	20
11.	Energy Efficiency	22
12.	Access for People with Disabilities	23
13.	Appendix A – Reference Documentation	26
14.	Appendix B – Draft Fire Safety Schedule.....	27
15.	Appendix C – Fire Resistance Levels	28

Date	Rev No	No. of Pages	Issue or Description of Amendment	Assessed By	Approved By	Date Approved
09/07/24	1	35	Final Report	Zahraa Thamer	Andrew Brohier	10/07/24
22/08/24	1	30	Final Report (Minor updates)	Zahraa Thamer	Andrew Brohier	22/08/24

1. EXECUTIVE SUMMARY

The proposed development is a residential care facility.

Summary of Compliance

As Registered Certifiers or relevant building surveyor we have reviewed the concept architectural design documents prepared by Marchese Partners International Pty Ltd (refer appendix A) for compliance with the building assessment provisions currently outlined in BCA 2022.

This report has been prepared to assess the project against the Building Code of Australia to enable the issuance of construction approvals. Further assessment of the design will be undertaken during the Construction Certificate phase to ensure compliance is achieved prior to approval being issued by the PCA.

Deviations from the Deemed-to-Satisfy Provisions



The assessment of the design documentation has revealed that the following areas deviate from the deemed-to-satisfy provisions of the BCA. These items will be addressed in the project fire engineering report.

No.	Description	Relevant DTS Clauses	Performance Requirements
Fire Safety Items			
1	Exit travel distances <i>Ground floor</i> <ul style="list-style-type: none"> Up to 58m in lieu of 40m to an exit. <i>Basement</i> <ul style="list-style-type: none"> Up to 23m in lieu of 20m to a point of choice in the Class 7a portion. Up to 28m in lieu of 20m to a point of choice in the Class 9c portion. <p>The above items will be addressed in the project fire engineering report.</p>	D2D5	D1P4, E2P2
2	Distance between alternative exits <i>Ground floor</i> <ul style="list-style-type: none"> Up to 65m in lieu of 60m to an alternative exit 	D2D6	D1P4, E2P2

Document Disclaimer

This document has been prepared solely for the use of our client in accordance with and as per our agreement for providing compliance consulting services. Although all due care has been taken in the preparation of this document, no warranty is given, nor liability accepted (except that required by law) in relation to the information contained within this document. This document represents the opinions based on the facts and matters known at the time of preparation of this document. Opinions, judgments, and recommendations detailed in this document, which are based on our understanding and interpretation of current statutory and regulatory obligations and standards should not be construed as legal opinions. This report is not valid until all outstanding invoices have been paid. Once paid, this note and watermark will be removed.

This document does not, in any way, constitute or form part of a 'Design Declaration' under the Design and Building Practitioners Act 2020 or the Design and Building Practitioners Regulation 2021. In addition, this report is not to be referenced or referred to in any declarations made under that legislation.

No.	Description	Relevant DTS Clauses	Performance Requirements
3	<p>The above items will be addressed in the project fire engineering report.</p> <p>Travel via fire-isolated exits</p> <p><i>Ground floor</i></p> <p>Path of travel on ground floor necessitates passing within 6m of the external wall in the following areas:</p> <ul style="list-style-type: none"> Along the ramp from Northern fire stair  <p><i>Basement</i></p> <p>Path of travel from the stair necessitates passing within 6m of the external wall and openings.</p>  <p>The above items will be addressed in the project fire engineering report.</p>	D2D12	D1P4, D1P5, E2P2
4	<p>Sprinkler / Hydrant Booster Location</p> <p>Multiple departures with this booster location:</p> <ul style="list-style-type: none"> As the building will have multiple entrances, the hydrant booster will not be located within sight of the main entrance. Fire Indicator Panel will not technically be at the front entrance due to the building having multiple entrances. <p>The above items will be addressed in the project fire engineering report.</p>	E1D2, E1D4, AS 2419.1 – 2021	E1P3, E1P4

No.	Description	Relevant DTS Clauses	Performance Requirements
Miscellaneous Items			
5	Special Hazard Fire engineering brief is to reference the proposed Solar Panels as a special Hazard.	E1D17	N/A

Any additional requirements that will apply as a result of performance solutions will need to be confirmed by the professional preparing the performance solutions. Any performance solutions will need to be prepared by a suitably qualified/accredited professional.

Refer to parts 10 of this report for further details regarding the required services.

Any fire engineered solutions will need to be approved after consultation with the NSW Fire Brigade as part of the Construction Certificate process via a Section 26 and 27 submission.

The application for Construction Certificate shall be assessed under the relevant provisions of the Environmental Planning & Assessment Act 1979 (As Amended) and the Environmental Planning & Assessment (Development Certification and Fire Safety) Regulation 2021.

2. INTRODUCTION

The proposed development comprises of a residential care facility.

The site is located at on part of Lot 4150 DP 127557 adjoining 97 Kesterton Rise, North Rothbury.

This report is based upon the review of the design documentation listed in Appendix A of this Report.

The report is intended as an overview of the relevant provisions of the Building Code of Australia for assistance only.

The applicable legislation governing the design of buildings is the Environmental Planning and Assessment Act 1979. Section 19 of the of the Environmental Planning and Assessment (Development Certification and Fire Safety) Regulations 2021 requires all new building works to comply with the current BCA.

The BCA applicable to the development is the version that is in force at the time of a valid Construction Certificate application which includes the entrance floor. For the purposes of this Report, BCA 2022 has been utilised.

3. COMPLIANCE WITH THE BCA

The Building Code of Australia is a performance based document, whereby compliance is achieved by complying with the Governing Requirements and the Performance Requirements.

Performance Requirements are satisfied by one of the following:

- 1) A Performance Solution
- 2) A Deemed-to-Satisfy Solution
- 3) A combination of (1) and (2)

4. DOCUMENTATION OF PERFORMANCE SOLUTIONS

A Performance Solution must demonstrate compliance with all relevant Performance Requirements, or the solution must be at least equivalent to the Deemed-to-Satisfy provisions.

Compliance with the Performance Requirements is to be demonstrated through one or a combination of the following:

- a) Evidence of suitability in accordance with Part A5 of the BCA that shows the use of a material, product, plumbing and drainage product, form of construction or design meets the relevant Performance Requirements.
- b) A Verification Method including the following:
 - i. The Verification Methods provided in the NCC.
 - ii. Other Verification Methods, accepted by the appropriate authority that show compliance with the relevant Performance Requirements
- c) Expert Judgement
- d) Comparison with the Deemed-to-Satisfy Provisions

Where a Performance Solution is proposed as the method to achieve compliance, the following steps must be undertaken:

- a) Prepare a performance-based design brief in consultation with relevant stakeholders,
- b) Carry out analysis, using one or more of the assessment methods nominated above, as proposed by the performance-based design brief,
- c) Evaluate results from (b) against the acceptance criteria in the performance-based design brief,
- d) Prepare a final report that includes:
 - i. All Performance Requirements and/or Deemed-to-Satisfy Provisions identified as applicable,
 - ii. Identification of all assessment methods used,
 - iii. Details of required steps above,
 - iv. Confirmation that the Performance Requirement has been met; and
 - v. Details of conditions or limitations, if an exist, regarding the Performance Solution.

5. PRELIMINARIES

5.1. BUILDING ASSESSMENT DATA

Summary of Construction Determination:

Part of Project	Building 1
Classification	Class 5, 7a & 9c
Number of Storeys	2
Rise In Storeys	2
Type of Construction	A*
Effective Height (m)	3.3m

Note:

- *The effective height of the project includes all stories included in the rise in stories of the project,*
- *The effective height of the building has been determined based on 46.70 - 43.40. Where these RL's change the effective height of the building will need to be reassessed*
- *As the compartment size for Type B Construction has been exceed the building is required to be constructed to Type A*

Summary of the floor areas and relevant populations where applicable: -

Part of Project	BCA Classification	Approx. Floor Area (m ²)	Approximate Volume (m ³)	Assumed Population
Basement	Class 7a	1,788 m ²	5,900 m ³	59
	Class 9c	534 m ²	1,762 m ³	35
Ground floor	Class 5	1,344 m ²	25,801 m ³	134
	Class 9c	3,879 m ²		96
Total		7,545 m ²	33,463 m ³	324

- *Notes: The above populations have been based on floor areas and calculations in accordance with Table D2D18 (prev. Table D1.13) of the BCA.*
- *D2D18 (c) outlines that any other suitable measures of assessing capacity can be used. Where seating plans are provided this may be used in lieu of Table D2D18,*
- *The carpark areas have been considered ancillary to the use for the purposes of population numbers*

6. STRUCTURE

6.1. STRUCTURAL PROVISIONS (BCA B1)

New structural works are to comply with the applicable requirements of BCA Part B1, including AS/NZS 1170.0-2002, AS/NZS 1170-1-2002, AS/NZS 1170.2-2021 and AS 1170.4-2007.

Depending on the importance level of the building as determined by AS/NZS 1170.0-2002, the non-structural elements of the building, including partitions (and non-structural fire walls), ceilings, services and racking/shelving may be required to comply with the seismic restraint requirements of AS 1170.4-2007. Where this is required, certification will be required confirming that the design of the seismic restraints comply with AS 1170.4-2007. This may be provided by a specialist seismic consultant or by the architect and services design engineers.

It is noted that Verification Method, B1V2 (previously BV2) is a pathway available to verify compliance with BCA Performance Requirement B1P1 (1)(c) (previously BP1.1(a)(iii)).

Glazing is to comply with AS1288-2021, and AS2047-2014.

Prior to the issue of the Construction Certificate structural certification is required to be provided by a Professional Engineer registered on the National Engineering Register in the structural field.

7. FIRE PROTECTION

7.1. FIRE COMPARTMENTATION (BCA C2D2 (PREVIOUSLY C1.1))

The BCA stipulates three levels of fire resistant construction, which is based upon the rise in storeys and classification of the building. Each of these types of construction has maximum floor area and volume limitations as per BCA Table C3D3 (previously C2.2).

Based upon the rise in storeys and use of the building, it is required to be constructed in accordance with the requirements of Type A Construction, in accordance with Tables S5C11a-g of Specification 5 (previously Table 3 & 3.9 of Specification C1.1) of the Building Code of Australia 2022.

The maximum floor area and volume limitations of a fire compartment as nominated in the deemed to satisfy provisions are as follows:

Classification		Type of Construction		
		A	B	C
5, 9b or 9c aged care building	max floor area—	8 000 m ²	5 500 m ²	3 000 m ²
	max volume—	48 000 m ³	33 000 m ³	18 000 m ³
6, 7, 8 or 9a (except for patient care areas)	max floor area—	5 000 m ²	3 500 m ²	2 000 m ²
	max volume—	30 000 m ³	21 000 m ³	12 000 m ³

As the compartment size exceeds 5 500 m² the building will be required to be Type A Construction.

7.2. FIRE RESISTANCE (BCA C2D2 (PREVIOUSLY C1.1))

The building should be constructed generally in accordance with the relevant provisions of Specification 5 (previously Specification C1.1) of the BCA applicable to Type A Construction, please refer to Appendix C which outlines the required fire rating to be achieved by the development.

Where a fire wall is proposed, it is noted that the wall is to achieve a structural rating regardless of whether it is loadbearing or not. Refer to Appendix C for required FRLs.

Other passive fire protection issues that will need to be addressed in detailed documentation phase include:

- Emergency Power Supply,
- Emergency Generators,
- Electricity Supply,
- Hydrant Pump Rooms,
- Sprinkler Pump Rooms,

The above areas are to be separated from the remainder of the building by construction achieving a minimum fire resistance level of 120/120/120 and have -/120/30 self-closing fire doors.

Please note that with regards to fire separation, the provisions and required FRL's that apply to the building also apply to an occupiable outdoor space associated with the building.

7.3. CLASS 9c FIRE AND SMOKE COMPARTMENTATION PROVISIONS (BCA C3D6 (PREVIOUSLY C2.5))

In addition to the above general fire compartmentation requirements, the BCA also contains additional prescriptive fire and smoke compartmentation provisions for Class 9c aged care areas. The deemed to satisfy requirements are as follows:

- Bounding construction to the sole occupancy units of 120 minutes where the dividing walls are loadbearing,
- Separation between the non-residential portions and the residential portions of 120 minutes,
- Residential portions separated into areas not more than 500 m² by smoke proof walls complying with Specification 11 (previously Specification C2.5)

Ancillary use areas containing equipment or materials that are a high potential fire hazard, must be separated from the sole-occupancy units by smoke proof walls. Ancillary use areas include, but are not limited to, the following:

- A kitchen and related food preparation areas having a combined floor area of more than 30 m².
- A laundry, where items of equipment are of the type that is potential fire sources (e.g. gas fire dryers).
- Storage areas greater than 10m² used predominantly for the storage of administrative records.

7.4. FIRE HAZARD PROPERTIES (BCA C2D10 AND C2D11 (PREVIOUSLY C1.10 AND BCA C1.9))

External Wall Cladding

Since the building is of Type A construction, the following components are required to be completely non-combustible:

- External walls, including façade coverings, framing, insulation;
- Flooring and framing of lift pits;

- Non-loadbearing internal walls required to have an FRL;
- All non-loadbearing shafts since the building is a Class 9c building;
- All non-loadbearing shafts connecting more than 2 storeys since the building is a Class 5 & Class 7a building.
- All loadbearing internal walls and loadbearing fire walls, including those that are part of loadbearing shafts.

For materials and assemblies that are required to be non-combustible, the material or system must be not deemed combustible when tested in accordance with AS 1530.1-1994.

The above noted requirements do not apply to the following:

- a) Gaskets,
- b) Caulking,
- c) Sealants,
- d) Termite management systems,
- e) Glass, including laminated glass, and associated adhesives, including tapes,
- f) Thermal breaks associated with—
 - i. glazing systems; or
 - ii. external wall systems, where the thermal breaks—
 - A. are no larger than necessary to achieve thermal objectives; and
 - B. do not extend beyond one storey; and
 - C. do not extend beyond one fire compartment.
- g) Damp-proof courses,
- h) Compressible fillers and backing materials, including those associated with articulation joints, closing gaps not wider than 50 mm,
- i) Isolated—
 - i. construction packers and shims; or
 - ii. blocking for fixing fixtures; or
 - iii. fixings, including fixing accessories; or
 - iv. acoustic mounts.
- j) Waterproofing materials applied to the external face, used below ground level and up to 250 mm above ground level,
- k) Joint trims and joint reinforcing tape and mesh of a width not greater than 50 mm,
- l) Weather sealing materials, applied to gaps not wider than 50 mm, used within and between concrete elements,
- m) Wall ties and other masonry components complying with AS 2699 Part 1 and Part 3 as appropriate, and associated with masonry wall construction,
- n) Reinforcing bars and associated minor elements that are wholly or predominately encased in concrete or grout,
- o) A paint, lacquer or a similar finish or coating,
- p) Adhesives, including tapes, associated with stiffeners for cladding systems,
- q) Fire-protective materials and components required for the protection of penetrations.

Combustible Materials

The following materials, though combustible or containing combustible fibres, may be used wherever a non-combustible material is required:

- a) Plasterboard.
- b) Perforated gypsum lath with a normal paper finish.
- c) Fibrous-plaster sheet.
- d) Fibre-reinforced cement sheeting.
- e) Pre-finished metal sheeting having a combustible surface finish not exceeding 1 mm thickness and where the Spread-of-Flame Index of the product is not greater than 0.
- f) Sarking type materials that do not exceed 1mm in thickness and have a Flammability Index not greater than 5.
- g) Bonded laminated materials where -

- (i) each laminate is non-combustible; and
- (ii) each adhesive layer does not exceed 1 mm in thickness; and
- (iii) the total thickness of the adhesive layers does not exceed 2 mm; and
- (iv) the Spread-of-Flame Index and the Smoke-Developed Index of the bonded laminated material as a whole does not exceed 0 and 3 respectively.

BCA 2022 introduced a number of additional clarifications and considers the following materials, when entirely composed of itself, are non-combustible and may be used wherever a non-combustible material is required:

- a) Concrete.
- b) Steel, including metallic coated steel,
- c) Masonry, including mortar,
- d) Aluminium, including aluminium alloy,
- e) Autoclaved aerated concrete, including mortar,
- f) Iron,
- g) Terracotta,
- h) Porcelain,
- i) Ceramic,
- j) Natural stone,
- k) Copper,
- l) Zinc,
- m) Lead,
- n) Bronze,
- o) Brass.

Any Aluminium Composite Panels must be labelled in accordance with SA TS 5344.

The BCA does nominate that ancillary elements may not be fixed to an external wall that is required to be non-combustible unless they comprise of the following:

- a) An ancillary element that is non-combustible.
- b) A gutter, downpipe or other plumbing fixture or fitting.
- c) A flashing.
- d) A grate or grille not more than 2 m² in area associated with a building service.
- e) An electrical switch, socket-outlet, cover plate or the like.
- f) A light fitting.
- g) A required sign.
- h) A sign other than one provided under (a) or (g) that—
 - i) achieves a group number of 1 or 2; and
 - ii) does not extend beyond one storey; and
 - iii) does not extend beyond one fire compartment; and
 - iv) is separated vertically from other signs permitted under (h) by at least 2 storeys.
- i) An awning, sunshade, canopy, blind or shading hood other than one provided under (a) that—
 - i) meets the relevant requirements of Table S7C7 as for an internal element; and
 - ii) serves a storey—
 - A. at ground level; or
 - B. immediately above a storey at ground level; and
 - iii) does not serve an exit, where it would render the exit unusable in a fire.
- j) A part of a security, intercom or announcement system.
- k) Wiring.

- l) Waterproofing material installed in accordance with AS 4654.2 and applied to an adjacent floor surface, including vertical upturn, or a roof surface.
- m) Collars, sleeves and insulation associated with service installations.
- n) Screens applied to vents, weepholes and gaps complying with AS 3959.
- o) Wiper and brush seals associated with doors, windows or other openings.
- p) A gasket, caulking, sealant or adhesive directly associated with (a) to (o)

Interior Linings

The fire hazard properties of fixed surface linings and mechanical ductwork will also need to be addressed within the detailed documentation phase pursuant to Specification 7 (previously Specification C1.10) of the Building Code of Australia. The following requirements apply:

Sprinkler Protected Areas

- a) Floor Coverings – Critical radiant Flux not less than 1.2 kW/m²
- b) Wall and Ceiling Linings – Material Group No. 1, 2, 3
- c) Other Materials – Spread of Flame Index not exceeding 9 and Smoke Developed Index not exceeding 8.

Rigid and flexible air handling ductwork must comply with AS4254 Parts 1 & 2 2012.

Floor linings and floor coverings used in lift cars must have a critical radiant flux not less than 2.2, and wall and ceiling linings must be a Material Group No. 1 or 2.

7.5. SEPARATION OF EQUIPMENT (C3D13 (PREVIOUSLY C2.12))

Equipment listed below must be separated from the remainder of the building providing a FRL as required by Specification 5 (previously Spec C1.1) but not less than 120/120/120 with a self-closing fire door with an FRL or not less than -/120/30. When separating a lift shaft and life motor room, an FRL of not less than 120/-/- is required.

- a) Lift motors and lift control panels; or
- b) Emergency generators used to sustain emergency equipment operating in the emergency mode; or
- c) Central smoke control plant; or
- d) Boilers; or
- e) A battery system installed in that building that has total voltage of 12 volts or more and a storage capacity of 200kWh or more.

7.6. PROTECTION OF OPENINGS IN EXTERNAL WALLS (BCA C4D3, C4D4, C4D5 (PREVIOUSLY C3.2 / C3.3 / C3.4))

The prescriptive provisions of the BCA stipulate that any external opening within 3m of the boundary, within 6m of the far boundary of a road, river, lake or the like that adjoins the allotment, or within 6m of another building on the allotment requires protection by -/60/- fire rated construction, or externally located wall wetting sprinklers.

Where a building is separated into fire compartments, the distance between parts of external walls and openings within them must be not less than the table below unless those parts of each external wall has an FRL not less than 60/60/60 and openings are protected.

Angle Between Walls	Minimum Distance
0° (walls opposite)	6m
More than 0° to 45°	5m
More than 45° to 90°	4m
More than 90° to 135°	3m
More than 135° to 180°	2m
More than 180°	Nil

Fire source feature is defined as;

- a) *The far boundary of a road, river, lake or the like adjoining an allotment,*
- b) *The side or rear boundary of the allotment,*
- c) *The external wall of another building on the allotment which is not a class 10 building.*

7.7. PROTECTION OF OPENINGS FIRE RATED BUILDING ELEMENTS (BCA C4D6, C4D11 (PREVIOUSLY C3.5 AND BCA C3.10))

The prescriptive provisions of the BCA stipulate that openings within building elements required to have an FRL shall be protected as follows:

- a) Penetrations through fire rated floors to be protected either by a tested prototype (e.g. fire collar, fire damper, etc) or be installed within a fire rated shaft achieving an FRL the same as the FRL of the floor it is passing through;
- b) Any penetration through a wall or room required to have an FRL (e.g. substation, boiler room, apartment separating wall etc) is to be protected either by a tested prototype (e.g. fire collar, fire damper, etc) or be installed within a shaft achieving an FRL the same as the FRL of the floor it is passing through;;
- c) Self-closing -/60/30 fire doors to the doors opening to the fire isolated stairs (note that this also includes the access doors to the condenser units on the plant platforms).

Note that where fire dampers, fire collars, etc are utilised, allowance needs to be made for access hatches to be provided within the walls / ceilings to ensure that maintenance access is provided.

As the design develops, details will need to be included in relation to sealing of penetrations / construction of fire rated shafts.

8. ACCESS AND EGRESS

8.1. PROVISION FOR ESCAPE (BCA D2 (PREVIOUSLY D1))

The egress provisions for the proposed building are provided by the following:

- Fire isolated stairways,
- External doors,
- Horizontal exits

Detailing issues that will need to be addressed as the design develops include:

- Door hardware,
- Exit door operation,
- Stair construction,
- Handrail and balustrade construction,
- Details of separation of rising and descending stairs,
- Discharge from fire isolated exits,
- Details of the egress provisions to the road,
- Door swings

8.2. REQUIRED FIRE ISOLATION OF EXITS (BCA CLAUSE D2D5 (PREVIOUSLY D1.3))

Class 5, 7a & 9c

Stairs utilised as required exits must be fire isolated where they connect, pass through or pass by more than 2 consecutive storeys and, an extra storey may be added if the building has a sprinkler system (other than a FPAA101D system) installed throughout.

8.3. TRAVEL VIA FIRE ISOLATED EXITS (BCA D2D12 (PREVIOUSLY D1.7))

The BCA requires each fire isolated stairway to provide independent egress from each storey served and discharge directly, or by way of its own fire isolated passageway to:

- A road or open space; or
- To a point in a storey within the confines of the building, that is used only for pedestrian movement, car parking or the like and is open for at least 2/3 of its perimeter, and an unimpeded path of travel not more than 20m to a road or open space; or
- A covered area that adjoins a road or open space, is open for at least 1/3 of its perimeter, has an unobstructed clear height throughout of not less than 3m, and provides an unimpeded path of travel to a road or open space of not less than 6m.

Additionally, where the path of travel from the point of discharge requires occupants to pass within 6m of any part of the external wall of the same building (measured horizontally), that external wall must have a 60/60/60 FRL and have any openings protected internally for a distance of 3m above or below the path of travel.

The following departures are noted:

Ground floor

Path of travel on ground floor necessitates passing within 6m of the external wall in the following areas:

Along the ramp from Northern fire stair

Basement

Path of travel from the stair necessitates passing within 6m of the external wall and openings.

8.4. HORIZONTAL EXITS (BCA D2D16 (PREVIOUSLY D1.11))

Horizontal exits are not to comprise of more than half of the required exits from any part of a storey divided by a fire wall except in a class 9a health care building or a class 9c building where the adjoining compartment has at least one required exit which is not a horizontal exit.

Horizontal exits are to have a clear area on the side of the wall that the persons are evacuating to that accommodates the total number of persons served by the horizontal exit. Space allowances are to be based on areas of not less than:

- 2.5m²/patient/resident in a Class 9a health care or 9c aged care building; and
- 0.5m² per person in any other case

Where a compartment is provided with two exits only, and one is a horizontal exit, the clear area provided above is to accommodate all occupants evacuating from the compartment.

8.5. EXIT TRAVEL DISTANCES (BCA D2D5, D2D6 (PREVIOUSLY D1.4, D1.5))

The locations of the proposed exits would appear to indicate that the deemed to satisfy requirements in terms of travel distances, distances between alternative exits and egress widths would be deviate from the DTS provisions as outlined below

The travel distances to exits should not exceed:

Class 5, 7a & 9c

- no point on the floor must be more than 20m to a single exit or point of choice and where two exits are provided, a maximum of 40m to one of those exits; and
- exits shall be located to not be more than 60m apart and not closer than 9m

The above indicates that the deemed to satisfy requirements in terms of travel distances would be satisfied, with the exception of the following areas:

Ground floor

- Up to 58m in lieu of 40m to an exit.

Basement

- Up to 23m in lieu of 20m to a point of choice in the Class 7a portion.
- Up to 28m in lieu of 20m to a point of choice in the Class 9c portion.

Distances between alternative exits do not comply in the following areas:

Ground floor

- Up to 65m in lieu of 60m to an alternative exit

The extended travel distances and distance between the exit stairs will need to be addressed to comply with the requirements of the deemed to satisfy provisions noted above, or be assessed as performance solutions by the Fire Safety Engineer using BCA Performance Requirements D1P4 and E2P2 (previously DP4 & EP2.2)

8.6. DIMENSIONS OF EXITS (BCA D2D7, D2D8, D2D9, D2D10, D2D11 (PREVIOUSLY D1.6))

Minimum dimensions of 1000mm and 2000mm height to be provided within exits, with the paths of travel should provide a minimum width of 1000mm (note that all maintenance access, cat walks, etc may comply with AS1657-2018 in which case a 600mm clear width is required).

The following table summarises the exit widths required by BCA Clause D2D7, D2D8, D2D9, D2D10, D2D11 (previously D1.6):

Storey	Number of people	Exit Width Required	Exit Width Provided
Basement	94	1m	2.5m
Ground Floor	230	2.5m	12m

Ground floor

Lack of 1m clear width in both courtyard areas.

During CC phase, it is understood the lack of clear 1m width in the courtyard areas will be increased to meet the minimum requirements.

Doorways are permitted to contain a clear opening width of the required width of the exit minus 250mm, with a height of 1980mm as part of egress requirements. Access for persons with disabilities however requires a clear doorway opening width of 850mm (i.e. minimum 920 mm doors).

8.7. BALUSTRADES AND HANDRAILS (BCA D3D17, D3D18, D3D19, D3D20, D3D22, D3D29 (PREVIOUSLY D2.16 / BCA D2.17 / D2.24))

Generally

Balustrading to a minimum height of 1000mm with a maximum opening of 124mm in any direction should be provided adjacent to balconies, landings, corridors etc where located adjacent to a change in level exceeding 1000mm, or where it is possible to fall through an openable window located more than 4m above the surface beneath.

Where it is possible to fall more than 4m to the surface below, the balustrade shall not contain any horizontal or near horizontal members that facilitate climbing between 150 – 760mm above the floor. It is noted that these provisions also apply to any building elements, including AC covers and the like, that are within 1m of the required balustrade.

Where a required barrier is fixed to the vertical face forming an edge of a landing, balcony, deck, stairway or the like, the opening formed between the barrier and the face must not exceed 40 mm.

Handrails should generally be provided at a minimum height of 865mm alongside of all ramps and stairs.

The public stairs and ramps located along an accessible path of travel should be designed in accordance with the requirements of AS1428.1 for persons with disabilities. This requires a handrail on each side of the stair and ramp and for the handrail to extend approximately 550mm – 600mm past the last tread / end of ramp.

In addition to the above, handrails are required to both sides of all stairs with a width of 2m or more.

Please also note handrails are required on both sides of all corridors used by residents and they are to be fixed not less than 50mm from the wall. The above dimensions are to be measured clear of the handrails.

Further review will be undertaken to ensure compliance as the design develops at CC stage.

8.8. SLIP RESISTANCE (BCA D3D15 (PREVIOUSLY D2.14))

The slip resistance requirements for ramps and stairs are outlined below:

Table D3D15 (prev. Table D2.14) SLIP-RESISTANCE CLASSIFICATION

Application	Surface conditions	
	Dry	Wet
Ramp steeper than 1:14	P4 or R11	P5 or R12
Ramp steeper than 1:20 but not steeper than 1:14	P3 or R10	P4 or R11
Tread or landing surface	P3 or R10	P4 or R11
Nosing or landing edge strip	P3	P4

9. SERVICES AND EQUIPMENT

The following section of this report describes the essential fire safety measures and the minimum performance requirements of those measures. A draft essential fire safety schedule can be found in Appendix B.

It is noted that the provisions below also apply to occupiable outdoor areas.

9.1. FIRE HYDRANTS (BCA E1D2 (PREVIOUSLY E1.3))

A Fire Hydrant system is required to be provided in accordance with BCA Clause E1D2 (prev. E1.3) and AS2419.1-2021.

All fire hydrants shall have the centre line of the fire hydrant valve or outlet not less than 750mm and not more than 1200mm above the ground, finished floor level or platform as outlined in AS2419.1-2021.

Where the building falls into one of the above criteria, the hydrant system is required to be assessed on a performance basis with consultation with FRNSW as required by legislation. Performance solutions are required to be verified to BCA Performance Requirement E1P3 (previously EP1.3).

Pressure and flow information will be required to confirm the required pressures and flow to the system, depending on the type of hydrant to be utilized at the Construction Certificate stage.

The fire services/hydraulic engineer is to confirm the required flow rates for the development at the Construction Certificate stage.

The building is required to be provided with a booster assembly as part of the fire hydrant requirements. The booster is required to be located at the main entry.

Further review will be undertaken to ensure compliance as the design develops at CC stage.

The following departures will be addressed in the fire engineering report:

- As the building will have multiple entrances, the hydrant booster will not be located within sight of the main entrance.
- Fire Indicator Panel will not technically be at the front entrance due to the building having multiple entrances.

9.2. FIRE HOSE REELS (BCA E1D3 (PREVIOUSLY E1.4))

A Fire Hose Reel System is required to BCA Clause E1D3 (previously E1.4) and AS2441-2005.

Fire hose reel assemblies shall be suitably mounted at a spindle height of between 1400mm and 2400mm above floor level as outlined in AS2441-2005.

The system is required to provide coverage to the Class 7a zones only.

Fire hose reels are to be located within 4m of exits and provide coverage within the building based on a 36m hose length and 4m of water spray. Where required, additional fire hose reels shall be located internally as required to provide coverage. These hose reels are to be located adjacent to internal hydrants.

Fire hose reel cupboards must not contain any other services such as water meters, etc., and doors to fire hose reel cupboards are not to impede the path of egress unless a performance solution is developed under BCA Performance Requirement E1P1 (previously EP1.1).

Fire Hose reel are not to extend through Fire and Smoke Walls.

Further review will be undertaken to ensure compliance as the design develops at CC stage.

9.3. FIRE EXTINGUISHERS (BCA E1D14 (PREVIOUSLY E1.6))

The provision of portable fire extinguishers is required to BCA Clause E1D14 (previously E1.6) and AS2444 - 2001 to provide coverage to the building.

Portable fire extinguishers must be located not more than 1200mm from the finished floor and not less than 100mm as outlined in AS2444-2001.

E1D14 details when portable fire extinguishers are required:

Occupancy Class	Risk Class (as defined in AS 2444)
General provisions – Class 2 to 9 buildings (except within sole-occupancy units of a Class 9c building)	<ul style="list-style-type: none"> a) To cover Class AE or E fire risks associated with emergency services switchboards. (Note 1) b) To cover Class F fire risks involving cooking oils and fats in kitchens. c) To cover Class B fire risks in locations where flammable liquids in excess of 50 litres are stored or used (not excluding that held in fuel tanks of vehicles). d) To cover Class A fire risks in normally occupied fire compartments less than 500m² not provided with fire hose reels (excluding open deck carparks). e) To cover Class A fire risks in classrooms and associated schools not provided with fire hose reels. f) To cover Class A fire risks associated with Class 2 or 3 building or class 4 part of building.
Specific provisions (in addition to general provisions) – a) Class 9c building	To cover class A and E fire risks. (Note 2)

Fire extinguishers are to be located in accordance with AS 2444 - 2001, often collocated with fire hydrants and/or fire hose reels.

Further review will be undertaken to ensure compliance as the design develops at CC stage.

9.4. AUTOMATIC SPRINKLER PROTECTION (BCA E1D4 – E1D13 (PREVIOUSLY E1.5))

Automatic sprinkler protection is required to Specification 17 (previously Spec. E1.5) and AS2118.1-2017 to the following areas:

- Throughout any Class 7a car park (other than open deck car parks) containing accommodation for more than 40 vehicles,
- Throughout the entire building where Class 9c aged care is proposed.

In the event a performance solution is provided for the sprinkler system, the booster assembly must be provided with a radiant heat shield complying with the requirements of AS 2419.1 – 2021.

It is noted that a system complying with FPAA101D or FPAA101H does not afford concessions elsewhere in the BCA such as spandrel separation and fire hazard properties.

The sprinkler system shall be connected to and activate an occupant warning system complying with BCA Specification 20 (prev. Spec E2.2a).

An occupant warning system should be provided in accordance with BCA Specification 17 (previously Spec E1.5).

9.5. SPECIAL HAZARDS (BCA E1D17 (PREVIOUSLY E1.10))

Any special hazard is to be included in the project Fire Engineering Brief for comment by FRNSW. This applies to the proposed solar panels.

9.6. SMOKE HAZARD MANAGEMENT (BCA E2D3 – E2D20 (PREVIOUSLY E2.2))

Smoke hazard management shall be provided throughout the building by means of the following systems:

- Automatic Shutdown of Mechanical Systems in accordance with the requirements of AS/NZS 1668.1-2015 Amendment 1;
- Automatic Smoke Detection System complying with BCA Specification 20 Clause 4 (previously E2.2a) and AS 1670.1-2018
- Carpark ventilation systems must comply with Clause 5.5 of AS/NZS1668.1-2015 Amendment 1

A fire indicator panel is required as part of the detection system. This panel is to be located within 4m of the main entry and should be incorporated within the fire control room. Any variation to the prescriptive provisions will require the consent of the fire brigade and should form part of the fire safety engineering report to verify the performance requirements of the BCA.

Fire Indicator Panel will not technically be at the front entrance due to the building having multiple entrances.

9.7. LIFT SERVICES (BCA E3D3, E3D4, E3D5, E3D9, E3D10, E3D11E3.4 AND BCA E3.6)

The passenger lifts to be installed are to be:-

- Fitted with warning signs, fire service controls in accordance with Clauses E3D4, Figure E3D4, E3D9, E3D11, and E3D12 (previously E3.3, Figure E3.3, E3.7, E3.9 and E3.10) of the BCA.
- Be provided with the following in order to satisfy accessibility requirements:
 - A handrail in accordance with AS1735.12-1999,

- Minimum internal floor dimensions of 1400 x 1600mm for lifts which travel more than 12m, or 1100 x 1400mm for lifts which travel not more than 12m,
- Fitted with a series of door opening sensory devices which will detect a 75mm diameter or across the door opening between 50mm and 1550mm above floor level,
- Have a set of buttons for operating the lift located at heights above level complying with AS1735.12 - 1999

9.8. EXIT SIGNS AND EMERGENCY LIGHTING (BCA E4D2, E4D4, E4D5, E4D6 AND E4D8 (PREVIOUSLY E4.2 E4.5, E4.6, E4.8))

Emergency Lighting and Exit Signs indicating exit location paths of travel to exits to be provided in accordance with BCA Part E4 and AS/NZS 2293.1-2018, including the potential use of photo luminescent exit signs.

Where exit signs are proposed to be above 2.7m to avoid potential damage by forklifts in the warehousing areas, this will need to be documented as a performance solution by an accredited fire safety engineer. This would need to be assessed to BCA Performance Requirement E4P2 (previously EP4.2).

Details are required to be provided for review at CC stage.

10. HEALTH AND AMENITY

10.1. STORMWATER DRAINAGE (BCA CLAUSE F1D3 (PREVIOUSLY CLAUSE F1.1))

Stormwater drainage systems serving the building are to comply with AS3500.3 - 2021.

The use of a syphonic stormwater drainage system is not covered by Australian Standards and any design incorporating one would need an appropriate performance solution will need to be documented by the hydraulic consultant addressing the system compliance against BCA Performance Requirements F1P2 and F1P3 (prev. FP1.2 & FP1.3).

10.2. SURFACE WATER MANAGEMENT (BCA PART F1)

Exposed Joints

Exposed joints in the drainage surface on a roof, balcony, podium or similar horizontal surface part of a building must not be located beneath or run through a planter box, water feature or similar part of the building.

Joints are to be protected in accordance with Section 2.9 of AS 4654.2.

External Waterproofing Membranes

All external above ground areas (roof slabs, balconies etc.) shall be protected by a waterproofing system in accordance with AS4654 Parts 1 and 2 – 2012.

10.3. ROOF & WALL CLADDING (BCA PART F3 (PREVIOUSLY PART F1))

BCA 2022 has introduced some deemed to satisfy provisions that relate to the waterproofing of external walls. These provisions apply as follows:

- Masonry, including masonry veneer, unreinforced and reinforced masonry is to comply with AS 3700
- Autoclaved aerated concrete is to comply with AS 5146.3
- Metal wall cladding is to comply with AS 1562.1

Where the installation is not proposed to comply with the above, or a different material is proposed to be used, a performance solution can be utilised to demonstrate compliance.

Performance Requirement F3P1 (previously FP1.4) which relates to the prevention of the penetration of water through external walls, must be complied with. Where a performance solution is proposed, it is to be prepared by a suitably qualified professional (façade engineer with NER for structural engineering) that demonstrates that the external walls of the proposed building comply with Performance Requirement F3P1 (previously FP1.4) which reads as follows:

A roof and external wall (including openings around windows and doors) must prevent the penetration of water that could cause—

- a) *unhealthy or dangerous conditions, or loss of amenity for occupants; and*
- b) *undue dampness or deterioration of building elements.*

10.4. WET AREAS & OVERFLOW PROTECTION (BCA PART F2 (PREVIOUSLY PART F1))

Internal wet areas throughout the development (e.g. bathrooms, laundries) shall be waterproofed in accordance with AS3740 - 2021 requirements.

Further review will be undertaken as the design develops with respect to the specification of waterproofing membrane, provision of water-stops at doorways etc.

10.5. SANITARY FACILITIES (BCA F4D2, F4D3, F4D4, F4D5, F4D6 (PREVIOUSLY F2.2 AND F2.3))

Offices

Separate sanitary facilities are required to be provided for male & female employees at a rate at the following.

The following table summarises the sanitary facilities required for staff:

Sanitary Facilities Required			
Staff	WC	Urinals	Basins
Male (staff)	<u>Basement</u> 3	-	<u>Basement</u> 3
	<u>Ground Floor</u> 9		<u>Ground Floor</u> 9
Female (staff)	<u>Basement</u> 3	-	<u>Basement</u> 3
	<u>Ground Floor</u> 9		<u>Ground Floor</u> 9
Accessible	<u>Basement</u> 1	-	<u>Basement</u> 1
	<u>Ground Floor</u> 1		<u>Ground Floor</u> 1

Note: The Unisex facilities provided for people with disabilities may be counted once for each sex. These facilities are to be provided in accordance with AS1428.1-2009.

Bathroom Construction

Where bathrooms or rooms containing water closets have the WC within 1200mm of the doorway, the door shall be either sliding, open outwards, or be provided with removable hinges.

10.6. LIGHT AND VENTILATION (BCA PART F6 (PREVIOUSLY PART F4))

Class 5, 7a & 9c

Natural Ventilation is required to be provided to rooms at a rate of 5% of the floor area in openings. Alternatively, mechanical ventilation is required in accordance with AS1668.2-2012

Artificial lighting complying with AS/NZS1680.0-2009 is to be incorporated with the final detailed design to be developed to confirm this.

A required window must be transparent and located:

- (i) in an external wall with the window sill not more than 1 m above the floor level; and
- (ii) where the window faces an adjoining allotment, another building or another wall of the same building, it must not be less than a horizontal distance of 3 m from the adjoining allotment, other building or wall.

10.7. SOUND TRANSMISSION AND INSULATION (BCA PART F7 (PREVIOUSLY PART F5))

Building elements within Class 9c buildings should provide the following sound insulation levels.

Location	Notes	Sound Insulation Requirement
Floors separating sole occupancy units		$R_w \geq 45$
Walls separating sole occupancy units	Wall must be of Discontinuous Construction	$R_w \geq 45$
Wall separating a sole-occupancy unit from a kitchen, bathroom, sanitary compartment (not being an associated ensuite), laundry, plant room or utilities room		$R_w \geq 45$

Please note for walls requiring impact resistance an air gap between leafs of the wall construction is required to be provided.

A report from the acoustic engineer verifying design compliance with the provisions of Part F7 (previously Part F5) of the BCA is required at CC stage.

11. ENERGY EFFICIENCY

11.1. SECTION J (JP1 ENERGY EFFICIENCY)

Efficient energy use must be achieved appropriate to the function and use of the building, level of human comfort, solar radiation, energy source of the services and sealing of the building envelope. To achieve this JV1, JV2, JV3, JV4 and JV5 verification methods have been introduced as options available to achieve compliance.

It is noted that a deemed to satisfy pathway is still available.

The proposed site will be located in a climate zone 5.

Certification from an appropriately qualified engineer should be provided at CC stage for either option with a report / computation outlining how compliance is achieved.

12. ACCESS FOR PEOPLE WITH DISABILITIES

The development is required to comply with the accessibility provisions contained within:

- The Building Code of Australia 2022;
- Disability (Access to Premises – Buildings) Standards 2010;
- AS1428.1-2009 General Requirements for Access – New Building Work;
- AS1428.4.1 -2009 Tactile Ground Surface Indicators
- AS2890.6-2009 Car Parking for People with Disabilities

Note: With the introduction of the Commonwealth *Disability Discrimination Act (DDA)* in 1992 (enacted in 1993), all organisations have a responsibility to provide equitable and dignified access to goods, services and premises used by occupants. Organisations and individuals since its introduction, are required to work to the objects of the Act which are to eliminate, as far as possible, discrimination against persons on the ground of disability in the **areas of work, accommodation, education, access to premises, clubs and sports, and the provision of goods, facilities, services and land, existing laws and the administration of Commonwealth laws and programs.**

This report assesses against the requirements contained with the Building Code of Australia (and documents referred to therein) and is not considered to be a full assessment against the Disability Discrimination Act.

Refer to access consultant's report for a full assessment against Part D4 of the BCA.

12.1. GENERAL BUILDING ACCESS REQUIREMENTS (BCA D4D2 (PREVIOUSLY D3.1))

Access for people with disabilities shall be provided to and within the building in accordance with the requirements of Clause D4D3, D4D4 and D4D5 (previously D3.2, D3.3 and D3.4) of the BCA 2022 and AS 1428.1. Parts of the building required to be accessible shall comply with the requirements of:-

- AS1428.1-2009 General Requirements for Access – New Building Work;
- AS1428.4.1 -2009 Tactile Ground Surface Indicators
- AS2890.6-2009 Car Parking for People with Disabilities

Access for persons with a disability is to be provided as follows:

Office (Class 5)

To and within all areas normally used by the occupants

Car parks (Class 7a buildings)

To and within any level containing accessible car parking spaces.

Aged Care Facilities

From a pedestrian entrance required to be accessible, to at least 1 floor containing single occupancy units, and to the entrance doorway of single occupancy units located on that level, and to and within each type of common facility e.g. hairdressers, shops, laundries, TV rooms and public dining.

Where a ramp or a lift complying with AS1428.1 is provided, to and within all areas of the level served by the lift or ramp.

Where a group of sole occupant units or individual units are provided, the following ratio is required.

1 to 10 single occupancy units	To and within 1 accessible sole occupancy units
11 to 40	To and within 2 accessible sole occupancy units
41 to 60	To and within 3 accessible sole occupancy units
61 to 80	To and within 4 sole occupancy units
81 to 100	To and within 5 sole occupancy units
101 to 200	To and within 5 sole occupancy units and 1 for every 25 sole occupancy units over 100 or part thereof in excess of 100.
201 to 500 single occupancy units	To and within 9 accessible sole occupancy units, plus 1 for every 30 units in excess of 200 units or part thereof in excess of 200.
More than 500	To and within 19 accessible sole occupancy units plus 1 for every 50 units in excess of 500 units

Where more than 2 single occupancy units are required to be accessible they must be indicative of the range of units/rooms available.

12.2. PROVISION FOR ACCESS TO BUILDINGS (BCA CLAUSE D4D3 (PREVIOUSLY D3.2))

The BCA prescribes access to be provided to and within the building as follows:

- Via the principle pedestrian entry and at least 50% of all other entrances from the allotment boundary
- From designated car parking spaces for the use of occupants with a disability.
- From another accessible building connected by a pedestrian link.
- All areas used by the occupants.

In buildings over 500m² in floor area, a non-accessible entrance must not be located more than 50m from an accessible entrance.

Where a pedestrian entry contains multiple doors, the following is required;

- Entrance containing not more than 3 doors, at least one of the doorways must be accessible.
- Where an entrance contains more than 3 doors, not less than 50% of the doorways must be accessible.

A door is considered to be accessible if it is automatic (open and closing) or is more than 850mm in clear opening width and contains the required door circulation space.

12.3. ACCESSIBILITY WITHIN BUILDING (BCA CLAUSE D4D4 (PREVIOUSLY D3.3))

A building required to be accessible is required to be equipped with either a AS 1428.1 compliant lift or AS 1428.1 compliant ramp, (but the maximum vertical rise of a ramp must not exceed 3.6m).

An exemption to not provide either a lift or ramp exists for class 5, 6, 7b, or 8 buildings, where a building contains;

- a) Less than 3 storeys; and
- b) Floor area of each storey (excluding the entrance level) is not more than 200m².

Within the building the following are required;

- Door circulation space as per AS1428.1 Clause 13.3 and as attached in Appendix B;
- Doorways must have a clear opening of 850mm;
- Passing spaces (1.8m wide passages) must be provided at maximum of 20m intervals
- Within 2.0m of end access ways/corridors, turning areas spaces are required to be provided.
- Carpet pile height of not more than 11mm to an adjacent surface and backing <4mm
- Any glazing capable of being mistaken for a doorway or opening must be clearly marked (or contain chair rail, hand rail or transom as per AS 1288 requirements)

The design would generally comply with the prescriptive provisions of the BCA with additional ongoing review being undertaken as to door widths, circulation, etc. Further details are to be provided or access to these areas is to be assessed by an access consultant.

13. APPENDIX A – REFERENCE DOCUMENTATION

The following documentation was used in the assessment and preparation of this report:

Drawing No.	Title	Revision	Date	Prepared By
A0.01	Cover Sheet	F	13/08/2024	Marchese Partners Internation Pty Ltd
A1.01	Site Context	C	13/08/2024	Marchese Partners Internation Pty Ltd
A1.02	Site Photos	C	13/08/2024	Marchese Partners Internation Pty Ltd
A1.04	Site Analysis A	C	13/08/2024	Marchese Partners Internation Pty Ltd
A1.05	Site Analysis B	C	13/08/2024	Marchese Partners Internation Pty Ltd
A1.06	Concept Design	C	13/08/2024	Marchese Partners Internation Pty Ltd
A2.00	Proposed Site Plan	F	13/08/2024	Marchese Partners Internation Pty Ltd
A2.01	Proposed Ground Floor Plan	F	13/08/2024	Marchese Partners Internation Pty Ltd
A2.02	Arcare	F	13/08/2024	Marchese Partners Internation Pty Ltd
A2.03	Arcare	F	13/08/2024	Marchese Partners Internation Pty Ltd
A3.01	Arcare	C	13/08/2024	Marchese Partners Internation Pty Ltd
A3.02	Arcare	F	13/08/2024	Marchese Partners Internation Pty Ltd
A4.01	Building Sections	F	13/08/2024	Marchese Partners Internation Pty Ltd
A4.02	Interface Section	C	13/08/2024	Marchese Partners Internation Pty Ltd
A4.03	Courtyard Sections	C	13/08/2024	Marchese Partners Internation Pty Ltd
A4.04	Material Board	C	13/08/2024	Marchese Partners Internation Pty Ltd
A5.01	CGIs	C	13/08/2024	Marchese Partners Internation Pty Ltd

14. APPENDIX B – DRAFT FIRE SAFETY SCHEDULE

No.	Measure	Standard of Performance
1.	Automatic Fail Safe Devices	BCA 2022 Clause D3D24 & D3D26
2.	Automatic Fire Detection and Alarm System	BCA 2022 Clause Spec 20, AS 1670.1 – 2018, AS/NZS 1668.1 – 2015
3.	Automatic Fire Suppression System	BCA 2022 Spec 17, AS 2118.1 – 2017 Amdt 1 & 2, AS 2118.6 – 2012 (Combined sprinkler & hydrant)
4.	Emergency Lighting	BCA 2022 Clause E4D2, E4D4 & AS/NZS 2293.1 – 2018
5.	Exit Signs	BCA 2022 Clauses E4D5, E4D6 & E4D8 and AS/NZS 2293.1 – 2018
6.	Fire Dampers	BCA 2022 Clause C4D15, AS 1668.1 – 2015 & AS 1682.1&2 - 2015
7.	Fire Doors	BCA 2022 Clause C4D3, C4D5, C4D6, C4D7, C4D8 & C4D9 and AS 1905.1 – 2015
8.	Fire Hose Reels	BCA 2022 Clause E1D3 & AS 2441 – 2005 Amdt 1
9.	Fire Hydrant System	BCA 2022 Clause E1D2 & AS 2419.1 – 2021
10.	Fire Seals, Collars (electrical, hydraulic, mechanical, fire)	BCA 2022 Clause C4D15, C4D16 & AS 1530.4 – 2014
11.	Lightweight Construction	BCA 2022 Clause C2D9
12.	Mechanical Air Handling System (zone smoke control/automatic smoke exhaust/stair pressurisation)	BCA 2022 Clause E2D3 & AS/NZS 1668.1 – 2015
13.	Portable Fire Extinguishers	BCA 2022 Clause E1D14 & AS 2444 – 2001
14.	Smoke Dampers	BCA 2022 AS/NZS 1668.1 – 2015
15.	Smoke Detectors and Heat Detectors	BCA 2022 Clause Spec 20 AS 1670.1 – 2018, AS/NZS 1668.1 – 2015
16.	Smoke Doors	BCA 2022 Spec 11
17.	Warning and Operational Signs	EP&A (Development Certification and Fire Safety) Regulation 2021 Clause 108, BCA 2022 Clause C4D7, D3D28 & E3D4
18.	Building Occupant Warning System	BCA 2022 Spec 17 & Spec 20 Clause S20C7 & AS 1670.1 – 2018 – Clause 3.22
19.	Emergency Evacuation Plan	Applicable FER & AS 3745 – 2010
20.	Paths of Travel	EP&A (Development Certification & Fire Safety) Reg 2021 Section 108, 109
21.	Required Exit Doors (power operated)	BCA 2022 Clause E3D24 (3)

15. APPENDIX C – FIRE RESISTANCE LEVELS

The table below represents the Fire resistance levels required in accordance with BCA 2022:

Type A Construction

Table S5C11a: Type A Construction: FRL of loadbearing parts of external walls

Distance from a fire source feature	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8
Less than 1.5m	90/90/90	120/120/120	180/180/180	240/240/240
1.5 to less than 3m	90/60/30	120/90/90	180/180/120	240/240/180
3m or more	90/60/30	120/60/30	180/120/90	240/180/90

Table S5C11b: Type A Construction: FRL of non-loadbearing parts of external walls

Distance from a fire source feature	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8
Less than 1.5m	-/90/90	-/120/120	-/180/180	-/240/240
1.5 to less than 3m	-/60/60	-/90/90	-/180/120	-/240/180
3m or more	-/-/-	-/-/-	-/-/-	-/-/-

Table S5C11c: Type A Construction: FRL of external columns non incorporated in an external wall

Column type	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8
Loadbearing	90/-/-	120/-/-	180/-/-	240/-/-
Non-loadbearing	-/-/-	-/-/-	-/-/-	-/-/-

Table S5C11d: Type A Construction: FRL of common walls and fire walls

Wall type	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8
Loadbearing or non-loadbearing	90/90/90	120/120/120	180/180/180	240/240/240

Table S5C11e: Type A Construction: FRL of loadbearing internal walls

Location	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8

Fire-resisting lift and stair shafts	90/90/90	120/120/120	180/120/120	240/120/120
Bounding public corridors, public lobbies and the like	90/90/90	120/-/-	180/-/-	240/-/-
Between or bounding sole-occupancy units	90/90/90	120/-/-	180/-/-	240/-/-
Ventilating, pipe, garbage, and like shafts not used for the discharge of hot products of combustion	90/90/90	120/90/90	180/120/120	240/120/120

Table S5C11f: Type A Construction: FRL of non-loadbearing internal walls

Location	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8
Fire-resisting lift and stair shafts	-/90/90	-/120/120	-/120/120	-/120/120
Bounding public corridors, public lobbies and the like	-/60/60	-/-/-	-/-/-	-/-/-
Between or bounding sole-occupancy units	-/60/60	-/-/-	-/-/-	-/-/-
Ventilating, pipe, garbage, and like shafts not used for the discharge of hot products of combustion	-/90/90	-/90/90	-/120/120	-/120/120

Table S5C11g: Type A Construction: FRL of other building elements not covered by Tables S5C11a to S5C11f

Location	FRL (in minutes): Structural Adequacy/ Integrity/ Insulation			
	Class 2,3 or 4 part	Class 5, 7a or 9	Class 6	Class 7b or 8
Other loadbearing internal walls, internal beams, trusses and columns	90/-/-	120/-/-	180/-/-	240/-/-
Floors	90/90/90	120/120/120	180/180/180	240/240/240
Roofs	90/60/30	120/60/30	180/60/30	240/90/60

(3) Carparks

For building elements in a carpark as described in (1) and (2), the following minimum FRLs are applicable:

a) External wall:

- i. Less than 3 m from a fire-source feature to which it is exposed:
 - A. Loadbearing: 60/60/60.
 - B. Non-loadbearing: -/60/60.
- ii. 3 m or more from a fire-source feature to which it is exposed: -/-/-.

b) Internal wall:

- i. Loadbearing, other than one supporting only the roof (not used for carparking): 60/-/-.
 - ii. Supporting only the roof (not used for carparking): -/-/-.
 - iii. Non-loadbearing: -/-/-.
- c) Fire wall:
- i. From the direction used as a carpark: 60/60/60.
 - ii. From the direction not used as a carpark: as required by Tables S5C11a to S5C11g.
- d) Columns:
- i. Supporting only the roof (not used for carparking) and 3 m or more from a fire-source feature to which it is exposed: -/-/-.
 - ii. Steel column, other than one covered by (i) and one that does not support a part of a building that is not used as a carpark—
 - A. 60/-/-; or
 - B. an ESA/M of not greater than 26m²/tonne.
 - iii. Any other column not covered by (i) or (ii): 60/-/-.
- e) Beams:
- i. Steel floor beam in continuous contact with a concrete floor slab
 - A. 60/-/-; or
 - B. an ESA/M of not greater than 30m²/tonne.
 - ii. Any other beam: 60/-/-.
- f) Fire-resisting lift and stair shaft (within the carpark only): 60/60/60.
- g) Floor slab and vehicle ramp: 60/60/60.
- h) Roof (not used for carparking): -/-/-.
- (4) For the purposes of subclause (3):
- a) ESA/M means the ratio of exposed surface area to mass per unit length.
 - b) Refer to Specification 17 for special requirements for a sprinkler system in a carpark complying with (3) and (b) located within a multi-classified building.