



**Norman
Disney &
Young**

20 March 2012

JBA Planning
Level 7, 77 Berry St
North Sydney New South Wales 2060
Australia

Attention: Oliver Klein

**Prince of Wales Comprehensive Cancer & Blood Disorder Centre
Stage 1 Director Generals Requirements (DGR) Condition 11
Infrastructure & Utilities: Electrical and Telecommunications**

SYDNEY
MELBOURNE
BRISBANE
PERTH
CANBERRA
ADELAIDE

In response to the Stage 1 DGR Condition 11, we confirm that NDY has undertaken initial consultation with Ausgrid to confirm that there is sufficient electrical infrastructure such that the site can be suitably serviced. Telstra has not been contacted as the communications services required for the new development will be derived from the existing hospital infrastructure.

AUCKLAND
WELLINGTON

Under the current electrical strategy no temporary works are required for the Stage 1 development outside of that required for temporary Builders power supplies.

LONDON
MANCHESTER

Further liaison is required with the Authorities and the Hospital to determine the extent of the augmentation required to provide electrical and telecommunications services to the site.

DUBAI

Please refer to Appendix A attached for correspondences with Ausgrid.

KUALA LUMPUR
(Licencee)

We trust that the above details are sufficient for your present purposes.

Regards,

NORMAN DISNEY & YOUNG

Shayne Blazley
Senior Associate



APPENDIX A

Hao Le

From: David Tomlin [dtomlin@ausgrid.com.au]
Sent: Monday, 19 December 2011 3:45 PM
To: Hao Le
Subject: RE: SC03273 - Prince Of Wales Hospital, Avoca St, Randwick

Hi Hao,
The application is acceptable, just to clarify on our last conversation, if you wish to have two kiosks they must side by side, if not then a chamber substation will be required.

Regards,

DAVID TOMLIN | PROJECT COORDINATOR – CONTESTABILITY SYDNEY SOUTH & EAST
Distribution Operations & Reliability | **AUSGRID**



Building 1A, 33-45 Judd Street, Oatley NSW 2223 AUSTRALIA

☎ (02) 9585 5823 (35823) | 📠 (02) 9585 5797 (35797) | 📞 0407 278 470 | ✉ dtomlin@ausgrid.com.au

"Hao Le" <h.le@ndy.com>

19/12/2011 02:52 PM

To "David Tomlin" <dtomlin@ausgrid.com.au>
cc "Robert Bartlett" <r.bartlett@ndy.com>, "Matthew Owen" <MOwen@thincprojects.com>, "Karsten Bastien" <KBastien@ricedaubney.com.au>
Subject RE: SC03273 - Prince Of Wales Hospital, Avoca St, Randwick

Dear David,

Please be advised that there has been a change in the building size and usage which has resulted in the change in electrical demand. Please find attached revised application for your information and review. We have attached the previously issued application for your reference. Note we are currently exploring the option of chamber substation vs 2 X kiosk substation and will advise yourself of our client's decision once we receive confirmation. In the meantime could you please review the application and advise if the electrical demand application is acceptable.

Please contact the undersigned should you wish to discuss further.

Many thanks.

Regards,



**Norman
Disney &
Young**

Hao Le

Senior Electrical Engineer

NORMAN DISNEY & YOUNG Level 1, 60 Miller Street, North Sydney, NSW 2060, Australia

Phone: +61 2 9928 6800 | **Direct:** +61 2 9928 6824 | **Mobile:** +61 433 676 846 | **Fax:** +6 2 9955 6900

www.ndy.com

This email and any attachments are confidential and may be legally privileged in which case neither is intended to be waived or lost by mistaken delivery to you.

If you are not the intended recipient, please delete without copying and advise us by e-mail of the mistake in delivery. Copyright NDY Group. All rights



From: David Tomlin [mailto:dtomlin@ausgrid.com.au]
Sent: Thursday, 8 September 2011 7:07 PM
To: Dean Eislers
Subject: SC03273 - Prince Of Wales Hospital, Avoca St, Randwick

Dear Dean,
Please find attached assessment response, ES10 Application, and Summary of Charges for the above project.

Regards,

DAVID TOMLIN | PROJECT COORDINATOR - CONTESTABILITY SYDNEY SOUTH & EAST

Distribution Operations & Reliability | **AUSGRID**

Building 1A, 33-45 Judd Street, Oatley NSW 2223 AUSTRALIA

☎ (02) 9585 5823 (35823) | 📠 (02) 9585 5797 (35797) | ✉ dtomlin@ausgrid.com.au This e-mail may contain confidential or privileged information.

If you have received it in error, please notify the sender immediately via return e-mail and then delete the original e-mail.

If you are the intended recipient, please note the change of sender email address to @ausgrid.com.au.

Ausgrid has collected your business contact details for dealing with you in

your business capacity. More information about how we handle your personal information, including your right of access is contained at <http://www.ausgrid.com.au/>[attachment

"O_ls110802s0015_EA_application_for_supply_(HL)~20111219.pdf" deleted by David Tomlin/energyAustralia/AU] [attachment "ES1 Form B Supplementary Application for Connection July 2011_Amended 20111219.doc" deleted by David Tomlin/energyAustralia/AU] [attachment "ES1 Form A Application For Connection Electronic Version July 2011_Amended 20111219.doc" deleted by David Tomlin/energyAustralia/AU]

----- Message from "Dean Eislers" <d.eislers@ndy.com> on Fri, 26 Aug 2011 15:11:11 +1100 -----

To: <ea.datanorth@ausgrid.com.au>

Subject: Prince of Wales Hospital - new project - electrical capacity planning

Dear Sir/Madam,

NDY have been engaged on the new Cancer Care and Blood Disorder Centre (CCBDC) at the Prince of Wales Hospital, Randwick. We are in preliminary planning now and would like to start discussion regarding the anticipated load for the new facility.

Attached is a letter describing the project including site location and maximum demand and application for load forms to start discussions.

Kind regards,



**Norman
Disney &
Young**

Dean Eislers

Senior Associate

NORMAN DISNEY & YOUNG Level 1, 60 Miller Street, North Sydney, NSW 2060, Australia

T +61 2 9928 6800 | D +61 2 9928 6938 | M +61 413 221 305 | F +61 2 9955 6900 | E d.eislers@ndy.com

www.ndy.com

This email and any attachments are confidential and may be legally privileged in which case neither is intended to be waived or lost by mistaken delivery to you.

If you are not the intended recipient, please delete without copying and advise us by e-mail of the mistake in delivery. Copyright NDY Group. All rights reserved.

NDY Management Pty Limited trading as Norman Disney & Young (ABN 29 003 234 571)



NDY promotes a sustainable environment.
Please consider the environment when printing this email.

[attachment "Is110802s0015_EA_application_for_supply_(DE)~20110824.pdf" deleted by David Tomlin/energyAustralia/AU]

[attachment "ES1 Form B Supplementary Application for Connection July 2011.doc" deleted by David

Tomlin/energyAustralia/AU] [attachment "ES1 Form A Application For Connection Electronic Version July 2011.doc" deleted by David Tomlin/energyAustralia/AU]

This e-mail may contain confidential or privileged information.

If you have received it in error, please notify the sender immediately via return e-mail and then delete the original e-mail.

If you are the intended recipient, please note the change of sender email address to @ausgrid.com.au.

Ausgrid has collected your business contact details for dealing with you in

your business capacity. More information about how we handle your personal information, including your right of access is contained at <http://www.ausgrid.com.au/>