



- | | |
|---|---|
|  | RETAIN EXISTING WINDOWS - TRIM. RETROFIT FIRE RATED CONSTRUCTION TO INSIDE FACE OF WALL OPENING. APPLY BLACK FILM TO INSIDE FACE OF GLAZING |
|  | RETAIN EXISTING WINDOWS AS IS. |
|  | RETAIN EXISTING WINDOWS. RETROFIT FIRE RATED GLAZIN TO THE INSIDE FACE OF WALL OPENING |
|  | REMOVED AND STORE EXISTING WINDOWS AND DOORS. REPLACE WITH FIRE RATED DOORSET ON HOLD OPEN OR OPEN MECHANISM |
|  | DEMOLISH EXISTING WINDOWS, REPLACE WITH FIRE RATED DOORSET ON HOLD OPEN |
|  | RETAIN WINDOW OR LOUVRE AS IS. RETROFIT FIRE DAMPER TO MECHANICAL EQUIPMENT |
|  | RETAIN EXISTING OPENING. RETROFIT FIRE RATED DOOR ON HOLD OPEN MECHANISM |
|  | PROPOSED AIN GLAZED FACADE TO BE DRENCHED |

Architectus Sydney Pty Ltd is the owner of the copyright subsisting in these drawings, plans, designs and specifications. They must not be used, reproduced or copied, in whole or in part, nor may the information, ideas and concepts therein contained (which are confidential to Architectus Sydney Pty Ltd) be disclosed to any person without the prior written consent of that company.

[illegible][illegible]

Do not scale drawings.
Verify all dimensions on site

jestico + whales



CH2MHILL®

1 Cobourg Street
London
NW1 2HP
T (44) 207 380 0382
F (44) 870 622 0732
www.jesticowhiles.com

Optima Building, Level 1 North
58 Robertson Street
Glasgow, United Kingdom G2 8DU
T (44) 141 204 2333
F (44) 141 204 2033
www.ch2mhill.com

architectus™

Architectus Sydney
Level 3 341 George Street
Sydney NSW 2000
T (61 2) 8252 8400
F (61 2) 8252 8600
sydney@architectus.com.au

ABN 11 098 489 448

checked	RO	scale	1 : 50@A1
drawn	MM	project no	110010.00

project

Australian Institute of Nanoscience

Environmental Assessment

Fire Separation

drawing no.	issue
A-1530	D

27/09/2012 1:02:54 PM