

----- Forwarded message -----

From: **Gavin Cherry** <Gavin.Cherry@penrith.city>

Date: Tue, 27 Apr 2021 at 15:54

Subject: Final Comment on the Review of Amended Stormwater Management Plan (SMP) as per Conditions of Consent for Former Penrith Glass Recycling Facility at Andrews Road, Cranebrook - SSD-5267

To: Anne Trevena <anne.trevena@buildrunrepair.com>

Cc: Simone Muscat <simone.muscat@penrith.city>

Hi Anne,

Apologies for the delay.

Council's Waterways Team reviewed the revised SMP submitted and have confirmed acceptance.

It has been noted that additional justification has been provided in relation to compliance with Water Conservation, and the report also indicates the proposed dust suppression sprinklers use less water than what was proposed in the original EIS. It has been noted that the design of the stormwater treatment system has changed since the original EIS and now includes a first flush system with a trade waste agreement, rather than the bunker hardstand areas being treated by gross pollutant traps (GPT) before being discharged into the wetland.

Given the additional information provided in the report in response to previous comments, Council is of the view that the revised SMP resolves the outstanding issues previously raised provided all of the commitments with regards to the management of the site with respect to stormwater, and the first flush system is maintained in accordance with the Trade Waste agreement.

Regards

Gavin Cherry
Development Assessment Coordinator

E Gavin.Cherry@penrith.city
T [+612 4732 8125](tel:+61247328125) | F +612 4732 7958 | M
PO Box 60, PENRITH NSW 2751
www.visitpenrith.com.au
www.penrithcity.nsw.gov.au

From: Anne Trevena <anne.trevena@buildrunrepair.com>
Sent: Monday, 12 April 2021 12:49 PM
To: Gavin Cherry <Gavin.Cherry@penrith.city>
Cc: Naji, Firas <Firas.Naji@arcadis.com>; Tilley, Heather <Heather.Tilley@arcadis.com>
Subject: Re: Further Comment on the Review of Amended Stormwater Management Plan (SMP) as per Conditions of Consent for Former Penrith Glass Recycling Facility at Andrews Road, Cranebrook - SSD-5267

Hi Gavin,

Thank you for your additional comments from Penrith City Council on the Visy Penrith Glass Recycling facility's Stormwater Management Plan. I have discussed with Tim Gowing and note his clarification that Council comments are for Visy consideration as the development is complete. I note that this approach is in line with the terms of reference of this consultation for the Penrith Glass Stormwater Management Plan, which is set out in SSD-5267, schd 3, condition 15.

I provide response comments **in blue** below and include revised excerpts from the Stormwater Design Report (with revised text **in red**). The revised Stormwater Design Report is also attached with revised text in red. Previous correspondence with Council regarding condition 15 consultation with the site's previous owners has also become available and is now included in the Stormwater Design Report.

Our stormwater engineer, Firas Nadji, is cc'd here and will provide the electronic version of the MUSIC modelling for your reference.

I trust this will fulfill the requirements of the consultation for the Stormwater Management Plan.

Regards

Anne

--

Anne Trevena
Environment Manager
Build Run Repair
(a member of the Visy group of companies)
0400 866 436