

Calala BESS

300MW - 1200MWh

Lot details and set-back

Part of Lot: 17/DP629969

A-102b

Legend

-  Calala BESS extent (8.9ha)
-  Subject site
-  Property parcel

Existing transmission line - Capacity (kV)

-  132
-  330

Proposed design

-  Fence
-  Fence - High Voltage
-  Gate
-  Noise wall
-  Underground cable (330 kV)
-  Access track
-  Auxiliary power
-  Battery enclosure
-  Control room
-  Control room - TNSP
-  Distribution kiosk (33 kV)
-  Harmonic filter - future development
-  High voltage connection asset
-  Inverter station
-  Laydown area
-  Lightning mast
-  Parking
-  Switchroom
-  Temporary office
-  Warehouse
-  Firewater tank
-  Stormwater basin
-  Transmission line alignment

Scale: 1:4,000 @ A3
Spatial Reference: GDA 1994 MGA Zone 56

Notes: This plan is indicative for development approval only and subject to detailed design changes. It contains highly confidential and proprietary information that are of independent, economic value to Equis. This drawing and design shall not be reproduced, amended, disclosed or distributed to others with out the express written consent of Equis.

