



File Ref. No: FRN23/1081 BFS23/1176 8000026861
TRIM Doc. No: D23/23494
Contact: Qualified Firefighter Barton Hill

20 March 2023

NESTOR TSAMBOS
NSW Department of Planning and Environment
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Nestor,

Re: Advice on Secretary's Environmental Assessment Requirements (SEARs) – BURROWAY SOLAR FARM – EUMUNGERIE ROAD BURROWAY (SSD-55968733)

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on the 9 March 2023, requesting input into the preparation of the SEARs for the BURROWAY SOLAR FARM - EUMUNGERIE ROAD BURROWAY (SSD-55968733). FRNSW have reviewed the SEARs along with the Scoping Report and make the following comments:

There is currently insufficient information available regarding the fire safety and emergency response management aspects of the project. FRNSW notes the Scoping Report details a 100MW/400MWh Battery Energy Storage System (BESS). It is the experience of FRNSW that BESS facilities present special problems of firefighting when responding to and managing an incident. FRNSW requests to be consulted and given the opportunity to review the hazard and risk analysis and provide comment regarding the proposed fire and life safety systems at the preliminary and final design phases of the project.

For further information please contact the Operational Liaison and Special Hazards Unit, referencing FRNSW file number BFS23/1176. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'James O'Carroll'.

Superintendent James O'Carroll
Manager
Operational Liaison and Special Hazards Unit

Cc: nestor.tsambos@dpie.nsw.gov.au