

Document: Redbank Power Station – Description of Proposed Modifications for Conversion to Fire Biomass fuels

Prepared for: Verdant Earth Technologies Limited

Subject: Proposed Conversion of Redbank Power Station to fire Biomass fuel
Report for Further Appeal for the LEC.

Prepared by: By: David Tanner, Principal Consultant
Boiler & Power Plant Services Pty Ltd
ABN 92 148 996 525
116 River Ave,
Chatswood NSW 2067

Date: 20 Oct. 2021

Ref: B&PPS Document C12198-01

1



View of the Redbank Site looking South

2

3

4

Disclaimer

This document was carefully prepared on the basis of our observation, analysis and data provided, and any conclusions and recommendations are based on our experience and judgement. Any data which we furnish concerning performance or condition of equipment is carefully predicted or estimated by us. However, this data may be based on assumptions and on information furnished by others, and is not guaranteed except to the extent expressly set forth in this report

EXECUTIVE SUMMARY

The scope of this document includes the description of the plant functional operation and main equipment, and a description of the proposed modifications to the plant and equipment to enable Biomass fuel firing.

Particular reference is made to the original Development Consent (1994), and where necessary to the 1997 Development Consent. The Amended EIS of 1993 forms part of the basis for the original Development Consent (1994 Consent).

In summary it is proposed to use the Biomass fuel in the equipment and locations designated for the "Supplementary fuel" described in the EIS and associated Consent documents. Due to the nature of the Biomass fuel, some equipment modifications to the Supplementary fuel handling systems are proposed as described in this document.

Summary of proposed plant modifications

The following summarises the extent of the modifications listed by plant functional areas to enable the plant to use Biomass fuels.

Modifications proposed:


- Internal roadways including new weigh bridges
- Supplementary fuel receipt, storage & reclaim
- Supplementary fuel transport equipment

No modification proposed:

- Site buildings and infrastructure works
- Boiler plant
- Steam turbine equipment
- Tailing (BDT) fuel system
- Water and waste-water treatment systems
- Ash Handling plant
- Switchyard and electrical transmission equipment
- Cooling water systems
- Steam and water systems Balance of Plant
- Hunter River water make-up and discharge systems
- Control System equipment

Refer to the site plan on the following page marked up to illustrate the location of the plant modifications proposed to enable the plant to handle Biomass fuel.

Figure 1 – Redbank Power Station Site Plan



Abbreviations used in this document

1994 Consent	Development consent ordered in the LEC November 1994
1997 Consent	Development consent ordered in the LEC dated 27.03.1997
Biomass fuel	Wood chips as specified in Appendix A to this document
BDT	Beneficiated Dewatered Tailings
BOP	Balance of Plant
db	Dry Basis
EIS	Amended Environmental Impact Statement No. 21333 of Nov. 1993.
GSE	Gross Specific Energy (same as GCV)
GCV	Gross Calorific Value (same as Gross Specific Energy)
HBD	Heat Balance Diagram
HP	High Pressure
LEC	Land and Environment Court of NSW
LHV	Lower Heating Value (or NCV)
LP	Low Pressure
kV	Kilovolts
MCR	Boiler Maximum Continuous Rating (261 t/h at full steam temperature)
MW	Megawatt
Net Output	Difference between the metered export power and metered import power
OEM	Original Equipment Manufacturer
ROM	Run of Mine Coal (Supplementary fuel)
ST	Steam Turbine
t/h	tonnes/hour

40

41 Table of Figures

42	Figure 1 – Redbank Power Station Site Plan.....	3
43	Figure 2 - View of Redbank Site from South.....	5
44	Figure 3 – Redbank Process Flow Schematic (Fig 2.5-1 from Amended EIS).....	7
45	Figure 4 – Water Balance – wet cooling EIS Fig. 2.7-2	13
46	Figure 5 – Table of plant conveyors.....	14
47	Figure 6 – Redbank plant performance 1994 Consent vs. 1997 Consent (as built).....	15
48	Figure 7 – Redbank anticipated performance – Biomass fuel firing.....	16
49	Figure 8 – Redbank FICirc™ CFB Boiler Orientation.....	17
50	Figure 9 – Boiler response to different Biomass fuel moistures.....	17
51	Figure 10 – Table of plant operating ranges.....	18
52	Figure 11 - Key Plan of Proposed Works.....	19
53	Figure 12 - Moving Floor Bulk Unloader Bin	20
54	Figure 13 - View of Visy Tumut Stacker (AMECO)	20
55	Figure 14 – Showing extension to Supplementary Fuel reclaim Conveyor CV76.....	21
56	Figure 15 – Fixed tripper (diverter) allows Biomass fuel transfer from CV34.....	22
57	Figure 16 - Reversing Conveyor Concept – Boiler 1.....	22
58	Figure 17 - Reversing Conveyor Concept – Boiler 2.....	23
59	Figure 18 - Fuel Silo Modification Specification	23
60	Figure 19 – View of modified silo bases and Biomass fuel feeders	24
61	Figure 20 - Design Biomass Fuel (analysis by mass%).....	25
62	Figure 21 – Typical fuel ultimate analysis by mass%.....	26
63	Figure 22 - Key Plan of Site Views in this report.....	31

64

1 INTRODUCTION AND OVERVIEW

1.1 Plant overview

The Redbank Power Project is a 128 MW power plant located near the Warkworth Mine in the Hunter Valley, west of Newcastle, New South Wales (NSW), Australia. The primary fuel is derived from coal washery tailings. The Redbank Power Station burns coal tailings and supplementary fuel to produce electricity.

The Redbank Power Station was commissioned in 2001 to burn beneficiated dewatered coal (BDT) tailings as main fuel and run of mine coal as the Supplementary (or Run of Mine ROM) fuel. The plant consists of two fluidised bed combustion steam generator units of FiCirc™ design and a single 151MW steam turbine and associated balance of plant equipment. The station has been out of operation since October 2014 and the current owners plan to convert of the plant to fire Biomass fuel (uncontaminated wood waste) as part of a recommissioning process. A view of the site appears below.

Figure 2 - View of Redbank Site from South



The following summary is extracted from the 1993 Amended EIS, with footnotes to indicate the significant changes which resulted from the 1997 Development Consent which were due to improvements to the tailings fuel quality by integrating the coal dewatering in the Warkworth mine operations.

2 Summary of the 1994 Consent Description of Plant

Paragraphs shown below in *Italic text* are extracts from the Amended EIS (1993). This formed the basis for the 1994 Development Consent.

2.1 Plant Operation

“The major features of the design of the Redbank Power Project include: a nominal rating of 120 megawatts¹ (MWe) (gross), approximately 100MW net output; fuel for the plant

¹ The current plant rating of 128 MW is due to a higher plant efficiency from the higher quality fuel from 1997.

would be coal washery tailing supplied from the Warkworth and Lemington² coal preparation plants, augmented as necessary by existing tailing dams and supplemental fuel.

"Tailing would be transferred by slurry pipeline³ from the Warkworth and Lemington washeries (and, as needed, from the Warkworth and Lemington tailing dams) to the Project site where the tailing would be stored for use as boiler fuel.

"Supplemental fuel would be trucked a short distance⁴ to the Project site, where it would be stored and used as necessary to supplement the tailing fuel.

"The boiler station would consist of two atmospheric-pressure, hybrid bubbling/circulating bed type boilers of the 'FiCirc™' design of Combustion Power Company, a subsidiary of National Power. Tailing fuel would be mechanically dewatered and introduced into the boilers in paste form.

"The power generating unit would be a turbo-alternator generating at 11 kilovolts (kV). Connection to the Shortland electrical system would be via a new 132 kV electrical interconnect line of less than one kilometre (km) in length.

"This would connect with Shortland's existing 132 kV line from Singleton to Kurri Kurri.

"The objectives of the Project are to:

(1) improve the utilisation of natural (fuel) resources.

(2) introduce an alternative, environmentally responsible method of tailing disposal; and

(3) operate in a way that minimises or eliminates environmental impacts."

2.1.1 Process Flow Diagram from the 1994 Development Consent.


The following Process Flow Schematic is the Figure 2.5.1 from Amended EIS 1993 which forms a part of the 1994 Development Consent.

² Fuel sourced only from Warkworth mine

³ Tailing fuel supplied by overland conveyor

⁴ Supplementary fuel supplied by overland conveyor

Figure 3 – Redbank Process Flow Schematic (Fig 2.5-1 from Amended EIS)



2.2 Description of the Plant based on the 1994 Development Consent.

The following description of the Redbank plant is consistent with the 1994 consent, of which the Amended EIS of 1993 is a part with minor editing to the original wording to include:

- Change of tense to clarify current plant configuration
- Ignoring stated options in the EIS which were not included in the plant design
- Provision of explanatory comments to explain variations from the 1994 Consent.

The plant operating description is divided into a number of functional areas, and the corresponding sections of the Amended EIS (1993) are given for reference.

2.2.1 Amended EIS Para 2.6.1 - Fuel supply and materials handling

The fuel supply consists of two major fuel streams, designated "Tailings" and "Supplementary Fuel" in the Amended EIS.

Fuel Receiving

Tailing reclaimed from dams and other emplacements would be transferred by slurry pipeline from the moveable tailing reclaim system to the plant receiving tanks/thickeners.

The supplemental/startup fuels would be received on site by trucks or belt conveyor from the individual mines.

Fuel Storage

This system would receive, thicken and store approximately 96 hours supply of tailing in slurry form.

Supplemental fuel storage consists of a truck unloading station and stockpile with a belt conveyor and stacker arrangement having multiple discharge points. Maximum storage capacity is approximately 35,000-40,000 tonnes of material. Reclaim is by front-end loader.

The addition of supplementary fuel occurs when the tailings are not available in sufficient quantities.

Supplemental Fuel Preparation

Supplemental fuel is transferred from the stockpile to the crusher by a combination of front-end loader and by conveyor where it is crushed to approximately 2 mm size. The crushing and screening station reduces the supplemental fuel size for feeding to the power plant boiler station.

The crushed coal is then be transferred by covered conveyor to (silos) to supply fuel to the two boilers

2.2.2 (Boiler) Combustor and Steam Generator (Amended EIS para 2.6.2)

The fuels are then prepared as necessary and fed to the two FiCirc™ boilers which are a circulating fluidised bed boiler. The heat released from this process is collected in a high pressure steam header and fed to the condensing steam turbine generator [item 3.].

The combustor/ boiler system fires the dewatered tailing from the dewatering station with addition of supplemental fuel as required to raise steam suitable for supplying the turboalternator system. The anticipated steam design conditions are 400-450 tonnes per hour (tph) of steam at 10-12 Megapascals gauge (MPa.(g)) and 515-540°C from nominally 160°C feedwater.

The boilers would meet the required emission limits of particulates, SO₂ and NO_x while firing the dewatered tailing fuel and supplemental fuel. The low emission boilers are two FiCirc™ fines circulating fluidised-bed boilers as designed by Combustion Power Company. The major components of the combustor/ boilers are as follows:

Boiler Fuel Feed System

The tailings fuel feed system consists of (four) positive displacement hydraulically operated type pumps. The combustor feed pumps force dewatered tailing into the combustion chambers of the boilers through multiple injection ports. Jets of compressed air are used to disperse the fuel in the combustor.

Fluidised Bed Boilers


Each of the two identical fluidised bed boilers are designed for delivery of combustion air to the plenum of the combustor by a Forced Draught (FD) fan system. The dense phase bed of suspended particles act as the primary combustion zone with secondary combustion/afterburning occurring in the freeboard above the bed. The fluidised bed contains evaporator heat exchanges in the steam generation circuit.

The flue gas proceeds from the combustion zone to cyclones operating in parallel flow, to recycle all but the finest particles back into the fluidised bed. From the cyclones, the flue gases proceed to the convective section I which contains the superheaters, the remainder of the evaporator and the economiser sections of the boiler.

A combustion air preheater on the flue gas exhaust is used to enhance boiler efficiency. The flue gases pass through the air preheater and then to the baghouse for particulate clean up. From the baghouse the flue gases proceed through an Induced Draught (ID) fan and from the ID fan to the stack.

Limestone is fed to the combustor to capture SO_2 and SO_3 as solid calcium sulphate (CaSO_4). The CaSO_4 becomes part of the particulates which are removed from the boilers.

FI CIRC™ Fluidised Bed Furnace Segment



Boiler Start-Up System

A bed preheating system (fired by distillate fuel oil) is used for boiler start-up and restarts after shutdowns. The oil start-up system includes a storage tank (e.g. 400,000 litres) which is surrounded by a bund wall to ensure that spillage or leakage is contained and prevented from causing soil or ground water contamination. As required, the ground beneath the tank is sealed to prevent soil or groundwater contamination. After initial heating with oil or gas, the boilers are further heated to operating temperature with the start-up fuel.

Flue Gas Cleaning

The flue gas from the boilers are cleaned of particulate/ dust by fabric filter baghouses. The particulate emissions from each boiler (via the stack) is within the requirements of the NSW EPA.

The baghouses consist of multiple chambers containing large numbers of fabric filter "bags". The gases flow through the bags and the particulates are removed by filtration. The collected particulate matter/ash is discharged periodically (by shaking the dust from the

outside of the filter bags with pulses of compressed air, which then is collected) *in individual chambers and transferred to the ash handling system.*

The dust is transferred from the individual chambers via a pressurised dense phase pneumatic ash conveying system to the ash storage silo.

Fluidising Air, Secondary Air and Induced Draught Fans

Fans are driven by electric motors. As needed, inlet and discharge silencers are fitted to limit fan noise for personnel hearing protection. Silencing material would also be applied to the fan inlet and outlet ducts and fan housings, as required.

Boiler Forced Circulation Pumps

Pumps are used to maintain water circulation rates within the main evaporators. Each boiler is fitted with redundant pumps, with one pump always in standby mode. Pumps are of the single-stage centrifugal type, driven by electric motors.

Boiler Feedwater Pumps

The boiler feedwater pumps raise the pressure of boiler feedwater from the deaerator to pressures in excess of the operating pressure of the boilers. There are redundant pumps, with one pump in standby mode. Pumps are of the multi-stage centrifugal type, driven by electric motors.

2.2.3 Turboalternator, Condenser and Feedwater Heating (Amended EIS para 2.6.3)

To generate electricity, the high-pressure superheated steam produced in the boiler station is expanded in a condensing steam turbine, which in turn drives an alternator. Steam is bled from the turbine for boiler feedwater heating and deaerating, as required. The exhaust steam from the turbine is condensed in a condenser subsystem. From the condenser, pumps transfer the condensate to the deaerator, where additional steam would strip out dissolved gases and heat the feedwater.

The Turboalternator

The steam turbine is a condensing machine driving a high-voltage alternator. The turbine consists of a high and low pressure section, rotating at synchronous speed, suitable for directly driving the alternator.

The alternator is of air-cooled type, in which heat was transferred via a closed air circuit to a water-cooled heat exchanger.

Low-Pressure Condensate Pumps

There are redundant, e.g. 2 X 100% capacity pumps of the centrifugal type, each driven by an electric motor and used to return condensate from the condenser.

Low-Pressure Feedwater Heater

This is of the shell and tube type to heat condensate between the condenser and deaerator.

Deaerator

This strips oxygen from the feedwater and heat the feedwater to a temperature suitable for feeding to the boilers.

2.2.4 Cooling System (Amended EIS para 2.6.4)

The Project uses two major cooling water systems: the Main Cooling Water System and the Auxiliary Cooling Water System.

The main cooling water system is used to reject waste heat from the power cycle. This waste heat represents the energy in the steam exiting the turbo-alternator that cannot be recovered as useful work. The Redbank Project, like most thermal power stations, would use a cooling tower to reject this waste heat to the atmosphere.

Acceptable water chemistry is maintained in the main cooling water system largely by discharging a portion of the cooling water on a continuous basis as cooling tower blowdown. Small quantities of biocides and sulphuric acid are added to the basin to control biological growth and pH, respectively. Corrosion inhibitors and dispersants may also typically be added, depending on the actual cooling water chemistry. Makeup water is added to the cooling tower system to make up for the losses due to blowdown and evaporation.

The auxiliary cooling water system provides cooling water to numerous minor auxiliary heat loads located throughout the plant.

2.2.5 Ash Handling (Amended EIS para 2.6.5)

The ash handling system transports all ash from the plant to a location on the Warkworth mine lease convenient for disposal by Warkworth.

Ash Collection System

Ash is collected from the baghouse hoppers under the economizer and air preheater and from the combustor via an ash cooler. Ash from these points is collected and discharged through control valves into a pipework system to transport the ash to the ash storage silo.

Ash Storage Silo

The storage silo is located on the site⁵ and would act as a transfer station for loading ash into trucks.

Ash Conditioner

The ash conditioning station utilising water spray is used for dust control upon discharge. Water is added to moisten the ash to prevent fugitive dusting.

Dense phase (slurry) transport moves ash from the ash cooler to a mixing tank on the Project site. The ash is mixed in this tank with water to achieve a water/ash ratio of approximately 35% / 65%. This dense phase mixture is then pumped from the Project site via small diameter pipe to open cut areas on the Warkworth lease.

2.2.6 Water Treatment (Amended EIS para 2.6.6)

Water for the Project is purchased from outside water agencies and piped to the Project site. Over ninety-five percent of the water used by the Project requires softening and/or filtration to make the supply water suitable for Project use. (These major uses for water include cooling tower make-up, service water and firewater.) Additional water uses (e.g. boiler make-up) and the associated water treatment is relatively small.

⁵ This silo is located on the Redbank site not the mine site.

275 **Cooling Tower Make-up/Service Water/Firewater**

276 *The influent water is softened in a large solids-contact-type clarifier. Lime, soda ash,*
277 *flocculants, and sulphuric acid are be added in the clarifier to reduce the hardness of the*
278 *water. Softened water exiting the clarifier is filtered in a gravity sand filter. Filtered make-up*
279 *water is stored in an above-ground storage tank. This water storage tank allows the plant to*
280 *operate during brief interruptions in the make-up water supply system. The storage I tank*
281 *would also supply water to the Project service water system.*

282 *A dedicated firewater storage tank stores filtered water for use in the event of a fire on the*
283 *Project site. Fire pumps distribute I firewater to underground distribution piping, fire*
284 *hydrants, hose stations and building sprinkler systems located throughout the Project.*

285 **Boiler Make-up Water**

286 *High purity water is required for make-up to the boiler feedwater system. This water is*
287 *needed to prevent scaling and corrosion in the boiler tubes and to prevent carry-over of*
288 *contaminants into the steam turbine.*

289 *The high purity boiler make-up water is generated by passing water from the make-up*
290 *water storage tank sequentially through filtration elements, a Reverse Osmosis (RO)*
291 *system, and a mixed bed demineraliser system.*

292 *High purity water is then be piped to the boiler make-up water storage tank. From this tank*
293 *the boiler make-up water is piped to the deaerator as needed to make up for losses in the*
294 *boiler feedwater system.*

295 **Chemical Feed and Storage Systems**

296 *Storage tanks and associated feed systems are located on-site to supply the necessary*
297 *chemicals to the various water streams. For example sulphuric acid, biocides, corrosion*
298 *inhibitors, and dispersants are added to the main and auxiliary cooling water to control pH,*
299 *control biological growth (algae), reduce corrosion, and keep particulate matter in*
300 *suspension, respectively. Oxygen scavengers, corrosion inhibitors, and other chemicals are*
301 *be added to the boiler feedwater system to maintain boiler water quality. Lime, soda ash,*
302 *flocculant, and sulphuric acid are needed for the pre-treatment softener.*

303 **2.2.7 Electrical System (EIS para 2.8)**

304 *The turboalternator would generate power at 11 kV. An 11 kV feeder would tee off the load*
305 *side of the alternator circuit breaker to feed an 11 kV auxiliaries switchboard. This*
306 *arrangement would enable the plant auxiliaries to be back-fed from the utility interconnect*
307 *line for plant start-up. Output would be stepped up via a generator transformer to 132 kV to*
308 *connect to the Singleton to Kurri Kurri overhead transmission line. The plant electrical*
309 *system would consist of:*

310 *Main Switchyard*

311 *This would consist of main step-up transformer, distribution-side breakers, isolators and*
312 *protection gear as necessary. The substation would also contain the utility metering and*
313 *protective devices.*

314 *High-Voltage Power Supplies*

315 *This would be required for major drives for the draught fans and boiler feed water pumps.*

Low-Voltage Supply


This would be for all other drives and power supply needs in the plant, including lighting and general power outlets.

2.2.8 Plant water system (EIS Para 2.7)

Figure 2.7-2 shows the water requirements for the Project based on an evaporative cooling system. In this scenario, water extracted from the tailing would be returned to the tailing ponds at the mines. Process water for the Project would be purchased from water agencies (e.g. Department of Water Resources) and supplied from the Glenbawn and Glennies Creek Dams via the Hunter River. Service water would be used directly, while boiler make-up water would undergo treatment. this water would be returned to the Hunter River but this would occur only if the water returned were desalinated to a point where it was of higher quality (i.e. lower salinity) than the river itself at the discharge point... Potable water for domestic consumption would be trucked to the Project site from outside sources. It is estimated that one to two weekly truck deliveries would be sufficient for those requirements. The potable water would be stored on site in an above ground storage tank.

(S)anitary wastewater would be treated in a small I (e.g. package type) treatment system.

Figure 4 – Water Balance – wet cooling EIS Fig. 2.7-2



3 CHANGES FROM 1994 CONSENT TO 1997 CONSENT (AS BUILT PLANT)

The 1994 Development Consent is based on the Amended EIS of 1993. This section of the document compares the “as built” modifications to the description of the plant from the 1994 Development Consent. The “as built” plant incorporated a number of process and physical equipment alterations which arose from the 1997 Development Consent.

Comments are made “by exception”, thus where no comment is made, then no substantial change has occurred, however, each significant change is only described once in the following and not re-iterated each time the item is reference in the 1994 Consent.

The major difference between the 1994 Consent and the 1997 Consent is that the “Tailings Slurry Thickening” occurs at Warkworth mine, and this process incorporates a beneficiation process which separates excess ash from the tailings in the dewatering process, and improves the fuel quality.

3.1 The use of BDT Fuel

The 1994 Consent describes the fuel resource as tailings from Warkworth or Lemington mines which represents very wet and high-ash tailing product which is an inherent characteristic of coal mine washery waste.

The improved fuel preparation facilities associated with the 1997 Consent and built at the Warkworth mine included the provision of Jameson (froth flotation) Cells which provided the beneficiated and dewatered tailings (BDT) which was the basis of the fuel burned at Redbank during its operation until shut down in 2014. The 1997 Consent process is based on included the following considerations relating to the BDT fuel compared to the Tailing fuel described in the 1994 Development Consent.

- Improved Fuel Preparation
- Same fuel energy consumption (annual)
- Improved Thermal Efficiency
- Less ash to emplace
- Fuel Preparation integrated with Mine Coal Preparation Facilities
- Improved Fuel Handling and Storage
- Increased plant net output
- Output of CO₂ will be reduced by over 15% per MW-h of output, and 10% per year.
- Annual emissions of SO₂ and NO_x remain the same

3.2 Fuel Transfer Systems

The use of tailings fuel (as BDT) enabled the use (sharing) of the conveyor transport system designated for the Supplementary fuel in the 1994 Consent without the need for a separate slurry pipeline.

This has resulted in the conveyor arrangement shown on the plant conveyor drawings which are included in Appendix C to this document. The function of the individual conveyors within the development is as described below:

Figure 5 – Table of plant conveyors

Conveyor	Function
V8700 Overland conveyor	Provides the tailings (as BDT) and the Supplementary (as BUF) fuels from the Warkworth washery facility to the fuel receival transfer point on the Redbank site. The fuels are provided in separate delivery runs (and not simultaneously)

Conveyor	Function
CV34 Tailings and Supplementary fuel	Transports the fuels from the overland conveyor delivery point to the following locations: - Tailings mode – fuel directly to the tailings (as BDT) storage silos located between the two boilers. - Supplementary fuel mode – fuel is transported to the transfer house local to the coal stockpile where it is tripped off the conveyor onto the stockpile stacker conveyor (CV36), see below. The conveyor does not carry both fuels simultaneously.
CV36 stacker conveyor (Supplementary fuel)	Transports the Supplementary fuel from the transfer house to the stockpile, and discharges fuel onto the stockpile.
CV76 Reclaim conveyor	Collects the Supplementary fuel from the stockpile and transports it to the crusher house.
CV35 Supplementary fuel conveyor	Transports the crushed Supplementary fuel from the crusher house to the Boiler 1 and Boiler 2 fuel silos.

3.3 Increased Thermal Efficiency and Electrical Output

Based on the use of BDT fuel as described above rather than tailings results in a higher thermal efficiency, and electrical output. The difference is summarised below:

Figure 6 – Redbank plant performance 1994 Consent vs. 1997 Consent (as built)

Item	Units	1994 Consent	1997 Consent
Annual Fuel Heat Input	Million GJ/annum	12.7	12.7
Net electrical output	MW	100	128

The Gross Fuel Heat Input is the product of (annual fuel delivery) x (Gross Specific Energy) of the Fuel. The 1994 Consent provides for 975,000 te/annum of fuel of GSE of 13 GJ/te.

3.4 Water Requirements (Amended EIS ref.2.7)

The plant water requirements are substantially as shown on the water balance in the Amended EIS labelled “Water Balance Wet Cooling”, except that:

- The dewatering associated with the tailing fuel preparation is located within the Warkworth mine
- Wastewater is stored on site in a storage pond of 60ML and returned to the Hunter River as part of the Hunter River Salinity Trading Scheme (HRSTS).

A Redbank “as built” water balance (Process Flow Balance Diagram) is provided in Appendix C to this document, as approved by the EPA during the plant construction phase.

4 EFFECTS OF MODIFICATIONS TO FIRE BIOMASS FUEL - 2021

This section considers the effect of biomass fuel (in the place of the ROM Coal, or supplementary fuel) on the plant operation. The plant will remain capable of firing BDT fuel, and it is not intended to fire BDT and Biomass fuel at the same time in any FiCirc™ combustion chamber.

The fuel preparation (drying, chipping, screening etc...) is performed off site such according to the fuel specification in Appendix A to this document. The fuel sizing is nominally 50mm maximum size, with typically 4% less than as fines of <1mm.

4.1 Biomass fuel Effect on Plant Performance

The plant net electrical output will not change when firing biomass fuel, however Biomass fuel will have the following effects on the plant performance.

Figure 7 – Redbank anticipated performance – Biomass fuel firing

	Units	1994 Consent	1997 Consent	Proposed Mods
Fuel Type	-	Coal tailings	BDT	Biomass fuel
Reference fuel moisture	%	dry basis	25	25
Net Plant Output (reference)	MW	100	128	128
Fuel gross specific energy	GJ/te	13 (dry)	21 (wet)	15.21 (wet)
Fuel energy consumption (annual)	GJ/annum	12.7 million	12.7 million	12.7 million
Approximate fuel consumption ⁶	Te/annum	975,000 (dry)	600,000 (wet)	835,000 (wet)
Approximate fuel consumption	Te/annum	975,000	450,000	626,000
Calculated efficiency (GSE basis)	%	22.7% ⁷	29.9%	27.2%

4.2 Boiler Plant Operation

The FiCirc™ boilers at Redbank were designed to fire coal tailings (as BDT) and Supplementary Fuel (as ROM coal). The boilers are suitable for Biomass fuel firing without change as demonstrated overseas (refer below), and the following gives an overview of their performance firing Biomass fuel.

4.2.1 FiCirc™ Boilers

CFB boilers are widely used and well suited for power generation due to the following characteristics:

- Able to utilise a wide variety of fuels
- Lower combustion temperatures result in lower oxides of nitrogen emissions
- In-situ removal of sulphur oxides by reaction with limestone sorbent if required
- High combustion efficiency

In B&PPS experience the Redbank FiCirc™ boilers and similar units are widely used to fire Biomass fuel and we:

- are familiar with the Redbank boilers
- have done extensive performance modeling of FiCirc™ boilers
- are familiar with a similar FiCirc™ boiler firing Biomass fuel
- have visited the Schiller Plant in Portsmouth, NH, USA

Schiller Plant

The Schiller plant which operated until 2018 included a FiCirc™ boiler having the following characteristics

- Boiler Type FiCirc™
- Fuel Biomass fuel (forest product residue)


⁶ 1994 fuel properties on dry basis as delivered fuel moisture was uncontrolled and dewatering occurred on the Redbank site. Where "dry basis" is stated, it means bone dry (with no moisture).

⁷ Not explicitly stated but implied from the data given.

- Location Portsmouth, NH, USA
- Electrical Generating Capacity 50 MW electrical

There are also a large number of fluidized bed units of similar design by other manufacturers which fire Biomass fuel. This includes plants at Visy in Tumut, NSW, and at Worsley Alumina in W.A.

Figure 8 – Redbank FiCirc™ CFB Boiler Orientation



The figure above shows an illustration of the CFB FiCirc™ Boilers at Redbank. No modifications are required to the boiler to fire Biomass fuel.

4.2.2 Boiler operation with different Biomass fuel moisture levels

During Biomass fuel firing, the FiCirc™ boiler steam output (and hence the plant net electrical output) will depend on the Biomass fuel moisture level as shown in the table below. At Biomass fuel moisture levels above about 25%, the plant electrical output is be reduced due to the flue gas system limitations.

Figure 9 – Boiler response to different Biomass fuel moistures

Moisture	-	10%	15%	25%	35%	45%
GCV	GJ/te	18.25	17.2	15.2	13.2	11.2
Gross heat release	GJ/h	1,643	1,660	1,700	1,675	1,600
Flue gas flow	Te/h	700	715	750	750	750
Steam flow	%MCR	100%	100%	100%	94%	85%
Fuel flow	Te/h	89.8	96	112	127	143

From the above table, the maximum heat input (Gross heat release) occurs at 25% fuel moisture content.

4.2.3 Plant operating range

The plant can operate in a number of operating modes. In normal automatic control mode with both boilers in service, the plant can accept electrical output load changes between 70% and 100%. The plant

can also operate with only one boiler in service. This means that depending on the operating configuration, the normal plant operating electrical output range can be considered as follows:

Figure 10 – Table of plant operating ranges

Mode	Net Plant Electrical Output Range
Two boilers normal operation	90 – 128 MW
One boiler out of service operation	50 – 64 MW

Plant electrical output outside of this range are not considered routine operations.

4.2.4 Flue Gas Emissions

The existing flue gas cleaning equipment will be used for Biomass fuel. The FiCirc™ boilers are inherently able to control the NOx and SOx as discussed in the section previously.

The Fabric Filter bags are used to reduce the particulate emissions as required by the EPA.

The existing cyclones located at the outlet of the FiCirc™ combustion chamber are designed to prevent all but the finest particles (typically <15 micron) from passing through to the back pass where the gases are cooled prior to entry to the fabric filter bags. This prevents burning cinders from entering the baghouse which is a problem with other types of firing such as stokers and bubbling fluidized beds.

4.2.5 Ash Handling

The 1994 Consent provided for the return of the Redbank boiler ash to Warkworth mine by a slurry pipeline. This is not proposed for the Biomass fuel conversion as Warkworth are not able to accept ash from Biomass from the Redbank plant.

The collection and storage of the ash (primarily fly-ash from the boiler combustion process collected by the bag filters) will not change. The ash it will be loaded into trucks by either of the following two systems which are located at the discharge of the 500 cubic meter capacity ash silo:

- Wet paddle mixer discharge into a truck.
- Dry ash transfer via telescopic chute to dry product handling truck.

The existing slurry pumping equipment will be stored on site enable future use. No new equipment is required.

5 EQUIPMENT MODIFICATIONS TO UTILISE BIOMASS FUEL -

This section of the document describes the physical alterations to the plant and process equipment necessary to fire Biomass fuel.


The modifications are necessary as Biomass is much less dense than coal, and has a lower Calorific Value, and tends to arch or bridge over outlet openings and cause blockages. Additional conveyor volume capacity is required, and some modification to silos and transfer systems which are designed according to the following principles.

- The Supplementary fuel as envisaged in the Amended EIS (unmarketable coal) will not be used for the plant as supplementary fuel.
- The Biomass fuel will be transported and stored in the equipment and locations which were designated for the Supplementary fuel.
- The Supplementary fuel equipment will be modified as necessary to accommodate the characteristics of the Biomass fuel. Such modifications are not irreversible.

- The BDT fuel capability will be maintained.
- The existing dust collection equipment associated with the fuel handling system will be reused and where new transfer points are proposed, new dust filter systems will be provided.
- Existing equipment that is not required for biomass firing will be left in-situ or stored on the site to enable future re-use.

A Key Plan of the proposed works is provided below and in Appendix C.

Figure 11 - Key Plan of Proposed Works



The following outlines the key features of the proposed system.

- Installation of an additional weighbridge and internal road works
- Biomass fuel supply, stockpile and reclaim
- Conveyor system modifications
- Boiler silo and feed system modifications

5.1 Fuel Receiving and Distribution

Biomass fuel will be delivered by B-Double vehicles via two dual truck unloading stations near the existing ash silo and the stations will feed the Biomass fuel onto either:

- A mobile stacker feed conveyor from the delivery area to the stockpile stacker unit, with an elevated discharge chute and with stockpile reclaim via front-end loader to "moving floor bulk unloader bins".

- A separate unloading conveyor to feed the CV76 reclaim conveyor directly via “moving floor bulk unloader bins” as shown below (per Keith manufacturing)

Figure 12 - Moving Floor Bulk Unloader Bin



These devices replace the existing stacking conveyor CV36, as it is not of sufficient dimension or capacity for handling Biomass fuel.

5.2 Fuel Storage Area

The Biomass fuel stockpile will occupy the area dedicated to the Supplementary Fuel storage, and its tonnage capacity is reduced due to the lower density of the Biomass fuel compared to coal. The stockpile area accommodates 3 days storage capacity.

Biomass fuel storage will be stored in an uncovered area. Covered storage is more commonly used overseas in colder, wetter climates for protection against the elements and to maintain a more consistent moisture content fuel.

We draw your attention to some local examples. The large industrial sized woodchip fired power plant at Visy Tumut in NSW uses uncovered storage of approximately 28,000 m³/ 11,000 te as shown below and they are in a wetter climate than Redbank.

Figure 13 - View of Visy Tumut Stacker (AMECO)



Another example is Rocky Point in Gold Coast, 30 MWe power plant in QLD, it fires wood waste in the off season and does not have any covered storage.

Based on the considerations above and Redbank FiCirc™ Fluidised bed boiler combustion capability to handle various moisture content woodchips an outdoor uncovered stockpile is proposed.

5.3 Fuel Conveyors

The Biomass fuel proposal considers the re-use of both the BDT and Supplementary fuel conveyors. A substantial portion of fuel transport equipment may be re purposed for Biomass fuel including.

- CV76 Existing reclaim conveyor
- CV34 Existing tailing/ supplementary fuel conveyor (from tripper house to Boiler 1)
- CV35 Existing Supplementary Fuel (BUF) conveyor (from crusher house to Boiler 2)

In order to transport the necessary quantity of Biomass fuel from the stockpile to the boilers, it is necessary to use both conveyors CV34 and CV35 simultaneously. Conveyor CV34 (also the tailings conveyor) will be used to feed boiler 1, and CV35 (the Supplementary fuel conveyor) will be used to feed boiler 2.


The following sections describe the changes necessary to accomplish the above.

5.3.1 Transfer - Crusher house transfer point

The transfer from the Supplementary fuel reclaim conveyor (CV76) to the main Supplementary fuel conveyor (CV35) occurs at the crusher house. As the crusher is no longer needed, a new chute is required to replace the coal crusher assembly and remove the coal crusher from service.

A Biomass fuel flow splitter will be provided at the outlet of the conveyor CV76 (in the crusher house) to split the Biomass fuel stream to feed both the existing conveyor CV35 and the proposed new extension of CV76 to feed conveyor CV34.

Figure 14 – Showing extension to Supplementary Fuel reclaim Conveyor CV76



5.3.2 Fuel transfer at the boiler silo roof areas

The current system of chutes discharging Supplementary fuel from conveyor CV35 to the boiler fuel silos is not suitable for use with Biomass fuel as the fuel is likely to hang up or choke in the chutes, and so to feed Biomass fuel from the existing CV34 and CV35 conveyors into the fuel silos the following modifications are proposed:

A new fixed tripper (diverter) pulley set and transfer chute-work for the tailings conveyor (CV34) in the Boiler Unit 1 silo roof area to allow either of the following to occur:


- Provide Biomass fuel to the reversing conveyor system, OR
- Allow BDT to continue its travel to the BDT silos located between Boiler Units 1 and 2.

The existing Supplementary fuel conveyor (CV35) then feeds the reversing conveyor system for boiler unit 2 only.

The reversing conveyors distribute the fuel from the delivery points for boiler 1 and boiler 2 from CV34 and CV35 respectively and distribute the fuel into the existing fuel silos.


The following diagrams illustrate the above description:

Figure 15 – Fixed tripper (diverter) allows Biomass fuel transfer from CV34




Note - The above sketch indicates modification to tailings conveyor local to boiler 1. Grey equipment (including conveyor gantries, silo cylinder and roof) is existing, and modifications for Biomass fuel are shown with green shading.

Figure 16 - Reversing Conveyor Concept – Boiler 1



559

Figure 17 - Reversing Conveyor Concept – Boiler 2



560

561 **5.4 Boiler Supplementary Fuel Feed System**

562 **5.4.1 Fuel Silos**

563 The existing boiler fuel silos have dual-outlet trouser-leg hoppers designed for Supplementary fuel. The
564 base of the existing silos will be converted to be suitable for Biomass fuel by the replacement the portion
565 of the silo below the existing construction joint to include a flat-bottom bin with a rotary screw auger. The
566 rotary screw augers provide Biomass fuel for the boiler fuel feeding system. Fire deluge nozzles will be
567 fitted to each of the existing silos.

568 Figure 18 - Fuel Silo Modification Specification


No. of silos	3 per boiler (six total)
Nominal diameter	6000mm (existing portion) 4676mm (new bottom portion)
Storage capacity (nominal)	250m ³ each
Residence time (nominal)	4 hours
Biomass fuel outlet feeder	600mm auger screw type

569

5.4.2 Fuel feeding system (from silo to feeder)

The existing Supplementary fuel weigh feeders are not of sufficient capacity for the Biomass fuel volume and will be replaced by screw feeders to deliver Biomass fuel from the bin auger discharge to the existing boiler feed chutes.

Figure 19 – View of modified silo bases and Biomass fuel feeders



The above sketch shows (in green colour) the new bottom portion of the silos and the Biomass fuel boiler screw feeders. The grey components including steelwork remain unchanged.

The above feed system discharges into six fuel spreaders located on the side wall of the FiCirc™ combustion chamber. These fuel spreaders will be retained as they are suitable for Biomass fuel.

APPENDIX A – FUEL ANALYSIS

The following is the specification for the “Design Biomass” fuel analysis which has used for the design basis for the conversion of the Redbank plant to fire biomass.

Type of fuel: Wood chip or equivalent Biomass fuel consistent with the requirements of the EPA NSW document “Eligible Waste Fuel Guidelines” of December 2016.

The following table specifies the range of fuel properties consistent with the boiler plant design capabilities.

Figure 20 - Design Biomass Fuel (analysis by mass%).

Parameter	Units	Design	Range or Limit
General Properties			
Calorific Value	MJ/kg (dry ash free)	20.2	19 - 22
Moisture	% (as fired)	25	10 to 50
Ash	% (as fired)	0.5	0.3 - 4
Chlorine	% (dry ash free)	0.02	up to 0.05
Sulphur	% (dry ash free)	0.1	up to 0.2
Particle size (Comply with P45A EN 15149-1)			
> 120 mm	% mass	0	
< 120 mm & > 100 mm	% mass	≤ 3.5%	
< 100 mm & > 63 mm	% mass	≤ 6%	
< 45 mm & > 8 mm	% mass	≥ 75%	
< 3.15 mm	% mass	≤ 8%	
Physical Properties (Note 1)			
Bulk Density	kg/m3		160 - 490
Ash Analysis (dry basis) (Typical)			
Silicon as SiO ₃	% in ash		10 to 30
Aluminium as Al ₂ O ₃	% in ash		5 to 30
Iron as Fe ₂ O ₃	% in ash		3 to 12
Calcium as CaO	% in ash		10- to 30
Magnesium as MgO	% in ash		5 to 22
Sodium as Na ₂ O	% in ash		0.3 to 1.7
Potassium as K ₂ O	% in ash		5 to 15
Titanium as TiO ₂	% in ash		0.1 to 1
Manganese as Mn ₂ O ₄	% in ash		0.3 to 8
Sulphur as SO ₃	% in ash		1 to 9
Phosphorus as P ₂ O ₅	% in ash		1 to 5
Ash Fusion Temperatures			
Initial Deformation	°C		>1200
Hemispherical	°C		>1230
Trace Elements (dry fuel basis)			
Mercury (Hg)	mg/kg in fuel		<0.1
Cadmium + Thallium (Cd + Tl)	mg/kg in fuel		<1
Zinc (Zn)	mg/kg in fuel		<100
Lead (Pb)	mg/kg in fuel		<20
Chromium (Cr), Copper (Cu), Arsenic (As)	mg/kg in fuel		<21

The following table gives a range of fuel properties which may be considered. Typical values for Tailings (as BDT) and for Supplementary Fuel (as ROM). The properties are tabled for reference purposes.

Figure 21 – Typical fuel ultimate analysis by mass%.

Comparison of analyses of Wood, BDT & ROM Coal		Hunter Energy SGS Wood	Hunter Energy SGS Wood	Hunter Energy SGS Wood	Hunter Energy SGS Wood	Typical Wood Chips	BDT (tailing) Mean HRL 2005	ROM Coal HRL 2005
BASIS		As Fired 15%	As Fired 25%	As Fired 35%	As Fired 45%	As Fired 25%	As Fired 33.4%	As Fired 9.7%
Carbon	% Mass	43.94	38.77	33.60	28.43	36.68	39.03	52.24
Hydrogen	% Mass	5.11	4.51	3.91	3.31	4.44	2.41	3.30
Nitrogen	% Mass	0.15	0.14	0.12	0.10	0.28	0.89	1.13
Sulphur	% Mass	0.04	0.04	0.03	0.03	0.02	0.32	0.42
Oxygen	% Mass	35.30	31.15	27.00	22.84	32.85	4.88	7.16
H ₂ O	% Mass	15.00	25.00	35.00	45.00	25.00	33.40	9.70
ASH	% Mass	0.45	0.40	0.35	0.29	0.73	19.08	26.05
TOTAL	% Mass	100.00	100.00	100.00	100.00	100.00	100.00	100.00
ASH	% Mass db	0.53	0.53	0.53	0.53	0.97	28.65	28.85
GCV	MJ/Kg	17.24	15.21	13.18	11.15	15.07	16.01	21.40
NCV	MJ/Kg	15.74	13.60	11.46	9.32	13.48	14.66	20.44
GCV daf	MJ/Kg	20.39	20.39	20.39	20.39	20.29	33.68	33.31

- where GCV.daf in the above table indicates Gross Calorific Value on a dry as-free basis.


The “Design Biomass” fuel used for the Redbank plant performance calculations firing biomass is the Wood fuel listed in the “As fired 25%”(moisture)” column in the figure above.

Fuel Sizing

Fuel will be sized and screened off site and be prepared in accordance with the boiler requirements.

- Wood chipped and screened to 50 mm nominal size
- Maximum of the sum of three dimensions to be less than 150 mm (length+width+thickness)
- Recommended Sizing is Indicated by the dark line
- Acceptable Sizing is indicated by the Shaded Band

Recommended Sizing
Wood or Bark
For Spreader Stoker Firing



604
605
606

APPENDIX B – FUEL CALORIFIC VALUE

B1.0 Calorific value

This Appendix explains the basis of the calculation of the Gross Calorific Value (or GCV) for woody Biomass fuels such as these proposed for use at the Redbank Power Station.

The Calorific Value of a fuel is the amount of heat liberated by its complete combustion expressed as kJ/kg (or MJ/kg or GJ/t) for solid fuels. The terms Higher Heating Value, or Gross Specific Energy may also be used but are synonymous with GCV in relation to solid fuels.

The calorific value can be either a Gross Heating Value or a Net Heating Value and are by convention calculated with respect to a standard reference temperature.

Gross Calorific Value (GCV) is also known as Higher Heating Value (HHV)

Net Calorific Value (NCV) is also known as Lower Heating Value (LHV)

The difference between GCV and NCV above is that the GCV includes, and the NCV excludes the energy used to vaporise water contained in the original energy form or created during the combustion process. Thus the difference for a solid fuel may be expressed as:

$$\text{NCV} = \text{GCV} - (\text{Latent heat of water} \times (\text{Water in fuel} + 8.94 \times \text{Hydrogen in fuel}))$$

Where the water and hydrogen in fuel are expressed as mass fractions.

B2.0 Basis of Gross Calorific Value for the Redbank Plant

For a consistent basis of determining the anticipated power plant performance and stack emissions a “Design Biomass fuel” fuel must be defined.

The basis for B&PPS documents prepared for Hunter Energy is a Design Biomass fuel having a Gross Calorific Value of 15.21 MJ/kg (GJ/t) and containing a moisture content of 25%. This value was determined from an average (arithmetic mean) of samples analysed by SGS during June 2020 and the average moisture content of the Biomass fuel that will be supplied to Redbank. The SGS analytical report and Biomass fuel moisture were provided to B&PPS by Costa Tsiolkas of Hunter Energy.

B&PPS were subsequently provided with another analytical report prepared by HRL dated October 2020.

A comparison for the laboratory analyses is provided in Table 1.

Table 1 – Results of Laboratory Samples of Woody Biomass fuel

Fuel: Biomass Laboratory Analysis for Redbank by SGS and HRL

Biomass Analysis for Redbank 2020		SGS Sample Average 5 Jun 20	SGS Sample 1 Top 5 Jun 20	SGS Sample 2 Middle 5 Jun 20	SGS Sample 3 Bottom 5 Jun 20	HRL Sample Average 21 Oct 20	HRL Karuah - Shavings/Sawdust 21 Oct 20	HRL Heron Creek Sample 2 Boral 21 Oct 20	HRL Buladelah Newells Creek Sawmill 21 Oct 20	HRL Buladelah Relts 21 Oct 20	HRL Sweetmans Sawmill 21 Oct 20
BASIS		As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%	As Fired 25%
C	% Mass	38.77	38.42	38.94	38.95	38.21	38.18	38.03	38.25	38.33	38.25
H	% Mass	4.51	4.54	4.49	4.50	4.19	4.13	4.35	4.20	4.13	4.13
N	% Mass	0.14	0.20	0.10	0.10	0.13	0.12	0.08	0.12	0.14	0.21
S	% Mass	0.04	0.05	0.04	0.02	0.01	0.01	0.01	0.01	0.01	0.01
O	% Mass	31.15	31.23	31.10	31.11	32.24	31.92	32.49	32.31	32.25	32.22
H ₂ O	% Mass	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00
ASH	% Mass	0.40	0.56	0.32	0.32	0.24	0.66	0.07	0.12	0.15	0.20
TOTAL	% Mass	100.00	100.00	100.00	100.00	100.01	100.00	100.01	100.01	100.00	100.00
Gross CV	MJ/Kg	15.21	14.87	15.47	15.28	15.00	14.85	14.85	15.08	15.08	15.15
Nett CV	MJ/Kg	13.60	13.26	13.86	13.68	13.46	13.33	13.28	13.53	13.55	13.63
GCV daf	MJ/Kg	20.39	19.98	20.71	20.47	20.06	19.98	19.82	20.13	20.14	20.25

Notes

Analyses brought to same 25% moisture basis

SGS Sample Average used for Design Biomass Fuel

daf = oven dried ash free basis. This is a method of comparing calorific value of Biomass fuel with varying moisture and ash contents.

The following References for the SGS and HRL reports are given below:

SGS Analytical Report NCM20-01874 RO Dated 1 June- 2020 SGS Australia – Mayfield West 6A Metal Pit Drive Steel River Industrial Estate	HRL Report 201187-1 Dated 21 October 2020 HRL Technology Group Pty Ltd Unit 4, level 1, 677 Springvale Road Mulgave Victoria 3070
--	---

The HRL results are not substantially different from SGS and they all fall within the expected variation for woody Biomass fuel which varies between tree species, growing location, soil types, method of harvesting etc.

B3.0 Comparison of Calorific Value with Published Data for Woody Biomass fuel

The variation in Higher Heating Value (HHV) or GCV for dry woody Biomass fuel is shown in Table IX below. This is an extract from “Combustion Fossil Power”, a reference book on fuel burning and steam generation published by Combustion Engineering, fourth edition 1991.

Note that the Gross Calorific Values for the SGS and HRL samples fall within the same range of typical values when compared on a dry basis to those in Table IX. The SGS and HRL values (last row of table 1) range between 19.98 and 20.71 MJ/kg and the typical values in table 2 (last column) range between 19.03 and 22.35 if the outlier 26.33 is disregarded.

It is B&PPS experience that wood Biomass fuel on a dry ash free basis found in Australia is normally in the range of 20 to 20.4 MJ/kg if the sample population is of reasonable size.

Table IX. Typical Analyses of Dry Wood

1 Btu/lb = 2.326 kJ/kg

	% by Weight						HHV,	HHV **
	C	H ₂	S	O ₂	N ₂	Ash	Btu/Lb	GJ/t dry
Softwoods†								
Cedar, white	48.80	6.37	...	44.46	...	0.37	8400*	19.54
Cypress	54.98	6.54	...	38.08	...	0.40	9870*	22.96
Fir, Douglas	52.3	6.3	...	40.5	0.1	0.8	9050	21.05
Hemlock, western	50.4	5.8	0.1	41.4	0.1	2.2	8620	20.05
Pine, pitch	59.00	7.19	...	32.68	...	1.13	11320*	26.33
white	52.55	6.08	...	41.25	...	0.12	8900*	20.70
yellow	52.60	7.02	...	40.07	...	0.31	9610*	22.35
Redwood	53.5	5.9	...	40.3	0.1	0.2	9040	21.03
Hardwoods†								
Ash, white	49.73	6.93	...	43.04	...	0.30	8920*	20.75
Beech	51.64	6.26	...	41.45	...	0.65	8760*	20.38
Birch, white	49.77	6.49	...	43.45	...	0.29	8650*	20.12
Elm	50.35	6.57	...	42.34	...	0.74	8810*	20.49
Hickory	49.67	6.49	...	43.11	...	0.73	8670*	20.17
Maple	50.64	6.02	...	41.74	0.25	1.35	8580	19.96
Oak, black	48.78	6.09	...	44.98	...	0.15	8180*	19.03
red	49.49	6.62	...	43.74	...	0.15	8690*	20.21
white	50.44	6.59	...	42.73	...	0.24	8810*	20.49
Poplar	51.64	6.26	...	41.45	...	0.65	8920*	20.75

*Calculated from reported high heating value of kiln-dried wood assumed to contain 8-percent moisture.

†The terms "hard" and "soft" wood, contrary to popular conception, have no reference to the actual hardness of the wood. According to the *Wood Handbook*, prepared by the Forest Products Laboratory of the U.S. Department of Agriculture, hardwoods belong to the botanical group of trees that are broad-leaved whereas softwoods belong to the group that have needle or scalelike leaves, such as evergreens: cypress, larch, and tamarack are exceptions.

** Conversion to GJ/t added by B&PPS

Note GJ/t = MJ/kg

However, while it is convenient to compare Biomass fuel on an oven dry basis, woody Biomass fuel in nature contains moisture ranging from about 15% to 25% for seasoned air-dried logs to over 50% for freshly cut green timber. For the 25% moisture and 0.4% ash in fuel as fired, the Fuel Gross Calorific Value on a DAF (Dry Ash Free) is calculated as follows:

Parameter	Value
Fuel moisture content	25%
Fuel Ash Content	0.4%
Fuel Gross Calorific Value (measured)	15.21 MJ/kg
Fuel DAF Calorific Value (calculated)	20.39 MJ/kg


Thus the measured calorific value is consistent with the values noted in Table IX, and with the considerations above.


APPENDIX C – DRAWINGS

The following drawings are provided as a part of this document.

Drawing No.	Rev	Dated	Description
80034-000-5001	7	18.10.2021	ALSTOM drawing marked-up to show proposed changes.
80034-007-P-PI-063-8551	2	29.09.1999	ABB/ USF Water Treatment Plant – Flow Balance Diagram
C12198-000-010	B	18.10.2021	Key Plan Showing Proposed Modifications
C12198-000-100	D	20.10.2021	Boiler Plant Area East Elevation “View A-A”
C12198-000-120	B	18.10.2021	Boiler Plant Area South Elevation “View B-B”
C12198-000-130	A	18.10.2021	Boiler Plant Area West Elevation “View C-C”
C12198-000-140	A	18.10.2021	Boiler Plant Area North Elevation “View D-D”
C12198-121-105	A	18.10.2021	Biomass Plant Area East Elevation “View E-E”
C12198-121-110	C	20.10.2021	Biomass Plant Area South Elevation “View F-F”
C12198-121-111	E	18.10.2021	Boiler Plant Area Conveyor System Plan
C12198-PFD-001	E	19.10.2021	Material Handling Process Flow Diagram

Figure 22 - Key Plan of Site Views in this report





APPROVED FOR CONSTRUCTION		POWER
REV	SIGNATURE	DATE
2	D. FANNER	10.6.99
3	D. FANNER	8.7.99
4	D. FANNER	23.7.99
5	D. FANNER	31.8.99
6	D. FANNER	18.10.99

REDBANK SITE LAYOUT MARKUP
TO SHOW LOCATIONS OF MODIFICATIONS
FOR BIOMASS FIRING

D. TANNER 18.10.2021

EQUIPMENT LIST:	
1.	ROLLER NUMBER ONE
2.	ROLLER NUMBER TWO
3.	STEAM TURBINE & GENERATOR SET
4.	COOLING TOWER
5.	FABRIC FILTER
6.	WASTE WATER HOLDING POND - 40 MEGA LITRE CAPACITY
7.	DIESEL OIL STORAGE TANK - 40,000 LITRE CAPACITY
8.	BACKUP FUEL (COAL) STORAGE AREA - 40,000 TONNES
9.	1.5 TON
10.	EMERGENCY ASH STORAGE SLOD
11.	RAW WATER HOLDING POND - 4 MEGA LITRE CAPACITY
12.	BACKUP FUEL (COAL) STORAGE SLOD
13.	WASTE HEAT RECLAIM STORAGE SLOD
14.	LIVESTOCK STORAGE SLOD
15.	COLDING WATER PRESHOWER - UNDERGROUND
16.	SWITCHBOARD
17.	STACK
18.	AUXILIARY BAY - ROLLER FEED PUMPS, FRESHWATER HEATERS/GENERATOR
19.	WATER STORAGE AREA & TRANSFER PUMPS
20.	15.7 M ³ BY 13.7 M HORIZONTAL TRANSFORMER
21.	4 M ³ BY 13.7 M HORIZONTAL TRANSFORMER
22.	TRANSMISSION/SLASH HANDLING MCC ROOM/TRANSFORMER
23.	FABRIC TRANSFORMER
24.	ROLLER ROOM
25.	SEWAGE TRANSFER PIT AND PUMPS
26.	ROAD BRIDGE
27.	ROAD BRIDGE
28.	ROAD BRIDGE
29.	FIRE WATER PUMP
30.	DIESEL FIRE WATER PUMP
31.	RIVER WATER PUMPS NOT SHOWN
32.	FIRST FLUSH OVERFLOW TO CREEK
33.	COOLING WATER FILTER STATION
34.	BOT FUEL CONVERTOR
35.	BACKUP FUEL (COAL) CONVERTOR
36.	BACKUP FUEL (COAL) STACK OUT CONVERTOR
37.	SITE CONSTRUCTION HUTS AND LAYDOWN AREA
38.	ROLLER LAYDOWN ROOM
39.	STATION CONTROL ROOM
40.	CRUSHER ROOM
41.	SWITCHGEAR ROOM
42.	WAREHOUSE/MAINTENANCE BUILDING
43.	CAR PARK
44.	BED SAND/LIVESTONE - INGROUND RECEIVAL HOPPER
45.	AUXILIARY COOLING WATER TANK UNDER COAL SLOD
46.	EARTHEN BERM STEADYWATER WALL
47.	LB. FAN
48.	FUTURE GAS TURBINE
49.	SEDIMENTATION/OILY WATER SEPARATORS
50.	WATER PIPE LINES TO FRESH WATER RIVER
51.	BACKUP FUEL (COAL) TRANSFER HOUSE
52.	FIRE TURN-OUT POINT
53.	CONDENSATE TANK RACK ROOM UNDER RACK ROOM
54.	INSULATED SHED
55.	FACILITY ADMINISTRATION BUILDING
56.	AIR COMPRESSOR HOUSE
57.	WATER TANK ROOM A/B
58.	EXISTING 40 KV TRANSMISSION LINE
59.	OVERLAND RAIL BACKUP (COAL) CONVERTOR TRANSFER STATION
60.	CHEMICAL LABORATORY
61.	FUTURE FUEL PYROLYSING PUMP
62.	FUEL OIL STORAGE TANK - 30,000 LITRE CAPACITY
63.	11 KV/4.133 KV TURBINE HALL SUPPLY TRANSFORMER
64.	PRIMARY CONTAINMENT BACKUP FUEL (COAL) STORAGE DAM
65.	OVERLAND FUEL CONVERTOR BAY OTHERS
66.	PERIMETER FENCE
67.	CRUSHER HOUSE
68.	MOBILE EQUIPMENT FUEL STATION
69.	CHEMICAL GENERATOR
70.	CHEMICAL FEED STATION
71.	NITROGEN STORAGE AREA
72.	ASH SLURRY HOPPER PUMP
73.	ASH SLURRY HOPPER PUMP
74.	FUTURE EXPANSION AREA
75.	LIVESTOCK INCUBATOR 55 CLINT NESTERS
76.	AUXILIARY COOLING WATER HEAT EXCHANGERS
77.	BACKUP FUEL (COAL) TRANSFER HOUSE
78.	BACKUP FUEL (COAL) TRANSFER HOUSE
79.	DIESEL OIL TRANSFER PUMPS
80.	DIESEL OIL PUMPS
81.	FUEL OIL TRANSFER PUMPS
82.	FUEL OIL PUMPS
83.	BOT AGITATOR TANK & INJECTOR PUMPS
84.	COMPRESSOR HOUSE MCC
85.	4.4 KV/4.133 KV COMPRESSOR HOUSE TRANSFORMER
86.	11 KV/4.133 KV TRANSFORMER ENERGY AUST1
87.	STEAM EMISSION MONITORING - CENS SHED
88.	ROLLER 312 & 02 MONITORING SHED
89.	ASH COOLER
90.	BED MATERIALS SLOD
91.	COAL DUST WATER SPRINKLER TANK
92.	COAL DUST SPRINKLER PUMP SHED
93.	SLURRY LINE FROM ASH/DUST PLANT TO WALKMOUTH MINE
94.	SERVICE WATER LINE FROM ASH/DUST PLANT TO FRESHWATER PUMPS
95.	AUXILIARY COOLING WATER PUMPS
96.	BOT AIR RECEIVER
97.	FABRIC FILTER AIR RECEIVER
98.	FIRST AID ROOM
99.	INLET PIT SUT AIRBORSTOR
100.	COAL SAMPLER
101.	BACKUP FUEL (COAL) STOCKPILE SPRAY PUMPS
102.	COAL SAMPLER
103.	COAL OVER MAGNET

WATER TREATMENT PLANT EQUIPMENT LIST

A1	RAW WATER FEED PUMPS	A25	CAUSTIC BULK STORAGE TANK AND DOSING PUMPS	A49	HYDROCHLORIC ACID STORAGE TANK & PUMP
A2	RAW WATER CLARIFIER	A31	SULPHURIC ACID BULK STORAGE TANK & DOSING PUMPS	A50	POTABLE WATER TANK
A3	SLUDGE THICKENER	A37	SODIUM HYDROXIDE BULK STORAGE TANK & DOSING PUMPS	A51	POTABLE WATER PUMP SYSTEM
A4	ELEVATED DESALINATING FACILITY	A38	FERRIC CHLORIDE DOSING SYSTEM	A52	BACKWASH AND DRAINAGE PIT
A5	4-10" DIA GRAVITY FILTERS	A39	LINE SLOD & WINGING TANKS/PUMPS	A53	IRRIGATION WATER TANK
A6	100" DIA TREATED WATER/FRESH WATER TANK	A40	WASTE WATER POSHDHAGE PUMPS	A54	AIR BLENDERS
A7	COOLING WATER MAKEUP PUMPS	A41	SODA ASH SLOD & WINGING TANKS/PUMPS	A55	FILTER PRESS CLEANING TANK & PUMP
A8	SERVICE WATER PUMPS	A42	100" DIA COOLING TOWER BLOWDOWN TANK		
A9	NOT USED	A43	WASTE WATER CLARIFIER FEED PUMPS		
A10	NOT USED	A44	95-10% WASTE WATER CLARIFIER		
A11	NO FEED PUMPS	A45	100" DIA SOFTENED WATER TANK		
A12	NO CARTRIDGE FILTER SLOD	A46	SAND FILTERS FEED/BACKWASH PUMPS		
A13	WASTE TREATMENT RO TREAT 1 AND 2	A47	NEUTRALIZATION TANK TRANSFER PUMPS		
A14	WASTE WATER TREATMENT TO UNIT	A48	PRESSURE SAND FILTER SLOD		
A15	MIXED BED POLYSER SLOD	A49	GRAVITY FILTERS ARE BLOWERS		
A16	PRESSURE FILTER AND PUMPS	A40	30" DIA HIGH PURITY WATER TANK		
A17	NEUTRALIZATION TANK AND PUMPS	A41	BOT RINSE PUMPS		
A18	SLUDGE HOLDING TANK	A42	MIXED BED FEED PUMPS		
A19	SLUDGE HOLDING COLLECTION PIT	A43	MANGROUSH DYE DOSING SYSTEM		
A20	30" DIA SLOD WASTE WATER TANK	A44	OP SLOD		
A21	WASTE AND REGEN WATER PUMPS	A45	PACKAGE SEWAGE TREATMENT PLANT		
A22	DESIGN WATER TRANSFER PUMPS	A46	TRANSFERRER		
A23	ACID/CALCINATE DOSING SLOD	A47	OPERATION OFFICE - LABORATORY		
A24	SODIUM BISULPHATE DOSING SLOD	A48	SWITCHROOM		

LEGEND :

CONCRETE/ASPHALT

HANDSTAND

COMPACTED GRAVEL


HARDSTAND

SCALE	DATE	REDAK CONSTRUCTION PTY. LTD.	NO	REV
1:10	10/10/2024		1	1

LEGEND:

	CONCRETE/ASPHALT
	HARDSTAND
	COMPACTED GRAVEL
	HARDSTAND

ALSTOM	Power	T : 15U UOIN	RED BANK POWER PROJECT
THIS DESIGN IS COPYRIGHT AND IS THE PROPERTY OF ALSTOM Power, AND IS ONLY ALLOWED TO BE USED BY EXPRESS PERMISSION AND LICENCE FROM ALSTOM Power, SYDNEY AUSTRALIA	SOURCE	ELECT.	CAPACITY
	MACHINE	POLYMER INCLUSION	NO PLANT SYSTEMS
	DRAWING NO. E-000000	1A,B,C,D	128 MW POWER PLANT
	DESIGN TIME	14.6.94	POWER PLANT ARRANGEMENT
			A O K R A T I V E
			AO
ALSTOM			Thomson



NOTES:

- FLOW BALANCE BASED ON EXPECTED OPERATING CONDITIONS (E.G. FIRE WATER FLOW SET TO ZERO)
- FIGURES ARE FOR INFORMATION ONLY & ARE NOT TO BE USED FOR GUARANTEES.
- WASTE WATER SYSTEM SIZED FOR THE 90 PERCENTILE CONDITION.

	STREAM																																						
DESIGN FLOW [KL/hr]	1	2	3	4	5	6	7	8	9	10	11A	11B	11C	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37
MEAN	366.8	9.0	401.7	4.7	397.0	12.3	384.7	0	411.3	302.1	15.0	44.0	15.0	0	50.2	26.0	40.2	40.2	30.0	10.2	10.0	10.0	10.0	0.2	36.2	1.3	34.9	34.9	1.7	33.2	6.6	64.0	4.2	1.8	1.5	0.3	19.7	26.6	5.0
90 PERCENTILE	368.1	9.0	405.1	6.7	398.4	12.3	386.1	0	418.7	309.5	15.0	44.0	15.0	0	50.2	33.5	40.2	40.2	30.0	10.2	10.0	10.0	10.0	0.2	43.7	1.2	42.5	42.5	1.7	40.8	8.2	64.0	5.5	2.4	1.9	0.5	21.4	32.6	5.0
MAXIMUM	300.2	9.0	404.2	8.4	395.7	12.3	388.4	0	430.2	321.0	15.0	44.0	15.0	0	50.2	45.0	40.2	40.2	30.0	10.2	10.0	10.0	10.0	0.2	55.2	1.3	53.9	53.9	1.7	52.2	10.4	64.0	6.8	2.9	2.4	0.5	23.2	41.8	5.0

REV	DRN	DATE	DESCRIPTION	CHK	APP
A	IR	23.7	ORIGINAL ISSUE		
1	BC	26.7	DESIGN REVIEW		
2	GG	29.9	REVISED TO CLIENT COMMENTS	MM	MM

ABB ABB POWER GENERATION LIMITED

THIS DESIGN IS COPYRIGHT AND IS THE PROPERTY OF ABB POWER GENERATION LIMITED, AND IS ONLY ALLOWED TO BE USED BY EXPRESS PERMISSION AND LICENCE FROM ABB POWER GENERATION LIMITED AUSTRALIA



A US FILTER COMPANY

U.S. FILTER (AUSTRALIA) PTY LTD A.C.N. 000 178 698
UNIT 1A 4-8 LYON PARK ROAD, NORTH RYDE, NSW 2113, AUSTRALIA
Tel: +61 2 8875 2880 Fax: +61 2 8875 2700 Email: usf@usfilter.com.au

SCALE: NTS (N.T.S. = NOT TO SCALE)

DRAWN	IR	24.99
CHECKED	MM	25.10.99
APPROVED	CH	25.10.99
DESIGN ENG	MM	25.10.99

CLIENT: REDBANK CONSTRUCTION PTY. LTD.
REDBANK POWER PROJECT

TITLE: AREA 05 WATER TREATMENT PLANT
WATER TREATMENT PLANT
PROCESS FLOW BALANCE DIAGRAM


USF CAD FILE: g:\area05\ip1001\pa01\ip1001.dwg

USF DRAWING No. IP1001-PA01

DRAWING No. 80034-007-P-PI-063-8551


ISSUE 2

ABB POWER GENERATION LIMITED



EQUIPMENT LIST (EXISTING):

- 1. BOILER NUMBER ONE
- 2. BOILER NUMBER TWO
- 5. FABRIC FILTER
- 8. SUPPLEMENTARY FUEL STORAGE
- 9. F.D. FAN
- 10. EMERGENCY ASH STORAGE SILO
- 13. BED MATERIAL STORAGE SILO
- 14. LIMESTONE STORAGE SILO
- 17. STACK
- 18. AUXILIARY BAY
- 19. BDT FUEL STORAGE SILO
- 23. FABRIC FILTER/ASH HANDLING MCC ROOM/TRANSFORMER
- 24. BOILER TRANSFORMER
- 26. SEWAGE TRANSFER PIT AND PUMPS
- 34. SUPPLEMENTARY FUEL CONVEYOR
- 35. BDT FUEL CONVEYOR
- 36. SUPPLEMENTARY FUEL STACK OUT CONVEYOR
- 38. BOILER BLOWDOWN TANK
- 41. WAREHOUSE/MAINTENANCE BUILDING
- 42. CAR PARK
- 43. BED SAND/LIMESTONE - INGROUND RECEIVAL HOPPER
- 44. AUXILIARY COOLING WATER TANK (UNDER COAL SILOS)
- 45. EARTHEN BERM STORMWATER WALL
- 46. I.D. FAN
- 47. FUTURE GAS TURBINE
- 48. SEDIMENTATION/OILY WATER SEPERATORS
- 49. WATER TO/FROM HUNTER RIVER
- 50. TRANSFER HOUSE
- 51. FIRE TURN-OUT POINT
- 55. AIR COMPRESSOR HOUSE
- 56. BOILER MCC ROOM A/B
- 57. OVERLAND FUEL CONVEYOR TRANSFER STATION
- 58. EXISTING 66 kV TRANSMISSION LINE
- 61. FUEL OIL STORAGE TANK - 380,000 LITRE CAPACITY
- 63. PRIMARY CONTAINMENT BACKUP FUEL STORAGE SUMP
- 64. OVERLAND FUEL CONVEYOR (BY OTHERS)
- 65. PERIMETER FENCE (FOLLOWS PLOT BOUNDARY)
- 66. CRUSHER HOUSE
- 67. MOBILE EQUIPMENT FUEL STATION
- 69. CHEMICAL FEED STATION
- 70. NITROGEN STORAGE AREA
- 71. ASH SLURRY MIX TANK
- 72. ASH SLURRY DISPOSAL PUMP
- 73. FUTURE EARTHING AREA
- 74. LIMESTONE STOCKPILE (56 CUBIC METRES)
- 76. SUPPLEMENTARY FUEL RECLAIM CONVEYOR
- 77. SUPPLEMENTARY FUEL RECLAIM FEEDER
- 78. EXCLUSION ZONE
- 79. DIESEL OIL TRANSFER PUMPS
- 80. DIESEL OIL PUMPS
- 81. FUEL OIL TRANSFER PUMPS
- 82. FUEL OIL PUMPS
- 83. BDT AGITATOR TANK
- 84. COMPRESSOR HOUSE MCC
- 85. 6.6 kV/0.433 kV COMPRESSOR HOUSE TRANSFORMER



KEY TO ELEVATION VIEWS

393740 mN

393720 mN

393700 mN

393680 mN

393660 mN

NOTES

REFERENCE DRAWINGS
- ALSTOM SITE LAYOUT 80034-000-5001

REV	DRN	DATE	DESCRIPTION	APP
B	DT	18.10	FOR ISSUE	


B&PPS Boiler & Power Plant
Services Pty Ltd

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE	SCALE	NOT TO SCALE
DRN.	SIGNATURE	DATE
REVIEW	DT	11.10.21
APP.		

CLIENT
REDBANK POWER STATION
TITLE
**BIOMASS CONVERSION PROJECT
KEY PLAN SHOWING PROPOSED
PLANT MODIFICATIONS**

DRAWING No.	C12198-000-010
REVISION	B
	A1
	Boiler & Power Plant Services Pty Ltd



NOTES		REV	DRN	DATE	DESCRIPTION	APP
REFER TO DRAWING C12198-000-010 FOR: - KEY PLAN TO SECTIONAL VIEWS - NUMBERED EQUIPMENT LOCATION IN PLAN VIEW		C	DT	18.10	FOR ISSUE	
		D	DT	20.10	FOR ISSUE	

B&PPS
*Boiler & Power Plant
Services Pty Ltd*

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE		
NOT TO SCALE		
	SIGNATURE	DATE
DRN.	DT	11.10.2021
REVIEW		
APP.		

CLIENT
REDBANK POWER STATION


TITLE
**BIOMASS CONVERSION PROJECT
BOILER PLANT AREA
EAST ELEVATION VIEW A-A**

DRAWING No.
C12198-000-100

REVISION
D

A1

*Boiler & Power Plant
Services Pty Ltd*



46. ID FAN

5. FABRIC FILTER [BAGHOUSE]

1. BOILER No. 1

1. FICIRC COMBUSTION CHAMBER

13. SAND SILO

12. SUPPLEMENTARY FUEL SILOS

NOTES

REFER TO DRAWING C12198-000-010 FOR:
- KEY PLAN TO SECTIONAL VIEWS
- NUMBERED EQUIPMENT LOCATION IN PLAN VIEW

REV	DRN	DATE	DESCRIPTION	APP
B	DT	18.10	FOR ISSUE	

B&PPS *Boiler & Power Plant
Services Pty Ltd*


THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE
NOT TO SCALE

	SIGNATURE	DATE
DRN.	DT	18.10.21
REVIEW		
APP.		

CLIENT
REDBANK POWER STATION
TITLE
**BIOMASS CONVERSION PROJECT
BOILER PLANT AREA
SOUTH ELEVATION VIEW B-B**

DRAWING No.
C12198-000-120
REVISION
B
*Boiler & Power Plant
Services Pty Ltd*



2. BOILER No. 2

5. FABRIC FILTERS

17. STACK

1. BOILER No. 1

NOTES

REFER TO DRAWING C12198-000-010 FOR:

- KEY PLAN TO SECTIONAL VIEWS
- NUMBERED EQUIPMENT LOCATION IN PLAN VIEW

REV	DRN	DATE	DESCRIPTION	APP
B	DT	18.10	FOR ISSUE	

B&PPS *Boiler & Power Plant
Services Pty Ltd*

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE
NOT TO SCALE

	SIGNATURE	DATE
DRN.	DT	18.10.21
REVIEW		
APP.		


CLIENT
REDBANK POWER STATION

TITLE
**BIOMASS CONVERSION PROJECT
BOILER PLANT AREA
WEST ELEVATION VIEW C-C**

DRAWING No.
C12198-000-130

REVISION
A

*Boiler & Power Plant
Services Pty Ltd*



35. SUPPLEMENTARY FUEL
CONVEYOR DISCHARGE

12. SUPPLEMENTARY FUEL SILOS
[BEHIND]

90. BED MATERIAL SILO

2. BOILER No. 2
FICIRC COMBUSTION CHAMBER

2. BOILER No. 2
CONVECTION PASS

5. FABRIC FILTERS [BAGHOUSE]

46. ID FAN

NOTES	REV	DRN	DATE	DESCRIPTION	APP
REFER TO DRAWING C12198-000-010 FOR: - KEY PLAN TO SECTIONAL VIEWS - NUMBERED EQUIPMENT LOCATION IN PLAN VIEW					


B&PPS *Boiler & Power Plant
Services Pty Ltd*

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE		
NOT TO SCALE		
	SIGNATURE	DATE
DRN.	DT	18.10.21
REVIEW		
APP.		

CLIENT	REDBANK POWER STATION	
TITLE	BIOMASS CONVERSION PROJECT BOILER PLANT AREA NORTH ELEVATION VIEW D-D	

DRAWING No.	C12198-000-140	
REVISION	A	A1
<i>Boiler & Power Plant Services Pty Ltd</i>		



NOTES		REV	DRN	DATE	DESCRIPTION	APP
REFER TO DRAWING C12198-000-010 FOR: - KEY PLAN TO SECTIONAL VIEWS - NUMBERED EQUIPMENT LOCATION IN PLAN VIEW						


B&PPS *Boiler & Power Plant Services Pty Ltd*

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE		
NOT TO SCALE		
	SIGNATURE	DATE
DRN.	DT	18.10.2021
REVIEW		
APP.		

CLIENT	REDBANK POWER STATION	
TITLE	BIOMASS CONVERSION PROJECT BIOMASS PLANT AREA EAST ELEVATION VIEW E-E	

DRAWING No.	C12198-121-105	
REVISION	A	A1
<i>Boiler & Power Plant Services Pty Ltd</i>		



NOTES		REV	DRN	DATE	DESCRIPTION	APP
REFER TO DRAWING C12198-000-010 FOR: - KEY PLAN TO SECTIONAL VIEWS - NUMBERED EQUIPMENT LOCATION IN PLAN VIEW		B	DT	18.10	FOR ISSUE	
		C	DT	20.10	FOR ISSUE	

B&PPS
*Boiler & Power Plant
Services Pty Ltd*



THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE NOT TO SCALE		
	SIGNATURE	DATE
DRN.	DT	13.10.2021
REVIEW		
APP.		

CLIENT
REDBANK POWER STATION

TITLE
**BIOMASS CONVERSION PROJECT
BIOMASS PLANT AREA
SOUTH ELEVATION VIEW "F-F"**

DRAWING No. C12198-121-110	
REVISION C	A1
Boiler & Power Plant Services Pty Ltd	



NOTE:
GREEN AREAS SHOW PROPOSED EQUIPMENT MODIFICATIONS

NOTES	REV	DRN	DATE	DESCRIPTION	APP
	E	DT	18.10.21	FOR ISSUE	


B&PPS *Boiler & Power Plant
Services Pty Ltd*

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS.
IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY
WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY
WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE NOT TO SCALE		
	SIGNATURE	DATE
DRN.	DT	28.07.21
REVIEW		
APP.		

CLIENT	REDBANK POWER STATION
TITLE	BIOMASS CONVERSION PROJECT BOILER PLANT AREA CONVEYOR SYSTEM PLANS

DRAWING No.		C12198-121-111
REVISION	E	A1
<i>Boiler & Power Plant Services Pty Ltd</i>		



NOTES

REVISIONS

REV	DRN	DATE	DESCRIPTION	APP
E	DT	19.10.21	FOR ISSUE	

B&PPS *Boiler & Power Plant Services Pty Ltd*

THIS DRAWING AND DESIGN IS THE PROPERTY OF B&PPS. IT MUST NOT BE COPIED OR REPRODUCED IN ANY WAY WHATSOEVER AND/OR PASSED ON TO ANY THIRD PARTY WITHOUT WRITTEN AUTHORITY FROM B&PPS.

SCALE NOT TO SCALE

	SIGNATURE	DATE
DRN.	DT	17.08.2020
REVIEW		
APP.		

CLIENT

REDBANK POWER STATION

TITLE

BIOMASS CONVERSION PROJECT
BIOMASS HANDLING PLANT
PROCESS FLOW DIAGRAM

DRAWING No.

C12198-PFD-001

REVISION

E

A3

Boiler & Power Plant Services Pty Ltd