

Fire Protection Design Statement

To	Architectus		
Attention	Chamille Lattouf	Date	15/03/2013
Address	Level 3, 341 George St	Email	Camille.lattouf@architectus.com.au
	Sydney, NSW 2000	Project No	SYD1300300
Project	North Eveleigh Affordable Housing	No of Pages	1
Copies			

The Fire Protection systems for the building works described below shall be designed in accordance with:

- General NCC2012
- Automatic Fire Detection and Alarm systems AS1670.1-2004/Amdt1-2005 & NCC2011 Spec E2.2a
- Building Occupant Warning Systems AS1670.1-2004/Amdt1-2005 & NCC2011 Spec E2.2a
- Portable Fire Extinguishers AS2444-2001 & NCC2011 Clause E1.6

Building Description and Location

Affordable Housing development comprising 39 basement carpark spaces, common areas and roof level amenity space. The development includes a total of 88 affordable housing units with a mixture of 1, 2 and 3 bedroom apartments, including a number of split level units.

The carpark and common areas shall be provided with a detection and warning system.

XXX

Documents to be included

Fire protection layout drawings

Fire protection specification

Owner

Details of Person Signing

Position in Company Fire Services Engineer

Qualifications and Experience	15 years industry experience
-------------------------------	------------------------------

Name John Vergara

15/03/2011

Signature

Date _____

This document shall in no way relieve the Builder and or Contractors of any legal responsibility or obligations with respect to the manufacture, installation, operation and respective certifications.