

24 October 2013

Ground Floor, Suite 01, 20 Chandos Street  
St Leonards, NSW, 2065  
PO Box 21  
St Leonards, NSW, 1590

Jason Shepherd  
General Manager Planning & Infrastructure  
Commercial & Industrial Property Pty Ltd  
Suite 59, Jones Bay Wharf  
26-32 Pirrama Road  
Pyrmont NSW 2009

T +61 2 9493 9500  
F +61 2 9493 9599  
E [info@emgamm.com](mailto:info@emgamm.com)  
[www.emgamm.com](http://www.emgamm.com)

Re: Food processing facility (RRM) Templar Rd Erskine Park


---

Dear Jason,

This note is to confirm that in assessing construction noise impacts for the above project, we considered the potential of ground vibration impacts and concluded that sensitive receivers (eg residences, retirement village and schools in the area). We find that these receivers are well removed from site (eg hundreds of meters) and therefore from any possible zones of vibration influences that could arise from the likely plant and equipment that would be used for the project. Hence in our opinion from 20 years of experience in noise and vibration, construction related vibration impact is highly unlikely.

We trust the above meets your needs and if you require any further clarification, please contact our office.

Yours sincerely



Najah Ishac (MEngSc; BE; MIEAust; MAAS)  
Director  
[nishac@emgamm.com](mailto:nishac@emgamm.com)