

Pascal Van De Walle

From: Borg Belinda <bborg@penrithcity.nsw.gov.au>
Sent: Tuesday, 20 May 2014 1:46 PM
To: Pascal Van De Walle
Subject: Re: Email from Department of Planning in relation to TNT - Modification 1 SSD 6040 MOD 1 at Lot 201 DP 1...

Dear Pascal,

We have reviewed the information and note the following amendments to the approved architectural plans:

1. Relocation of the fire pump room;
2. Construction of 2 x 375,000L fire sprinkler tanks instead of 1 x 750,000L;
3. Construction of 2 x 1000 kVA substations instead of a single 1000 kVA substation;
4. Relocation of the main switch room from inside the building to the Lockwood Road frontage (behind the landscaped area);
5. Relocation of the electricity generator next to the main switch room (Lockwood Road frontage); and
6. Relocation of 6 parking spaces to create space for the 8 tonne pick-up and delivery trucks.

Council raises no objection to the modifications, subject to the provision of appropriate landscaping within the adjoining beds to the fire pump room and fire sprinkler ranks.

Regards,

Belinda Borg
Senior Environmental Planner

E bborg@penrithcity.nsw.gov.au
T (02) 4732 7505 | F (02) 4732 7958 |
PO Box 60, PENRITH NSW 2751
www.penrithishere.com.au
www.penrithcity.nsw.gov.au

PENRITH
CITY COUNCIL



WARNING: This email is intended for the named recipient(s) only. It may contain information which is CONFIDENTIAL. Any rights and/or privilege are not waived or lost by reason of mistaken delivery or transmission of this email. If you are not the intended recipient, you must not read, use, copy, distribute or disclose the contents or take any action reliant on this email or attachments. If you have received this email in error, please notify us immediately by return email, facsimile or telephone and delete this email. Thank you.

This message has been scanned for malware by Websense. www.websense.com