

20 January 2025

TSA Riley
C/- Rain Wong
L15, 207 Kent Street
Sydney NSW 2000

Email: rain.wong@tsariley.au
Revision: 01

Dear Rain,

**SYD1611: Uniting Waverley – 124-164 Bronte Road, 7-8 Church Street, 101 – 125 Birrell Street, Waverley NSW 2024
Provide evidence of compliance with clause 91 of the Housing SEPP – Fire services**

ADP has been engaged to design fire sprinkler system for United Waverley.

Fire sprinkler systems to the Residential Care Facilities 9c building will be designed in accordance with E1D10 and Specification 17 of NCC 2022 and Automatic Fire Sprinkler System AS2118.1-2017 and AS2118.6-2012.

Yours sincerely



Paige Tan
Fire Protection Engineer

FPAS Accreditation No: F036181D

- Fire Detection and Alarm System – Level 3
- Fire Sprinkler System – Level 4
- Fire Hydrant and Hose Reel System – Level 3

Organisation Name: ADP Consulting

Postal Address: Level 6, 33 Erskine Street,
Sydney NSW 2000

Tel: 02 8203 5447

Email: b.watson@adpconsulting.com.au