

## Sally Munk

---

**From:** Airport Developments <Airport.Developments@AirservicesAustralia.com>  
**Sent:** Tuesday, 15 October 2024 8:15 AM  
**To:** Sally Munk; Peter Bleasdale  
**Cc:** Airspace.Protection@casa.gov.au  
**Subject:** AIRSERVICES RESPONSE: YSSY-CA-819 P2 - Dev, 2-4 Hale St, Botany

### OFFICIAL

Hi there,

I refer to your request for an Airservices assessment of the proposed controlled activity at 2-4 Hale St, Botany.

#### **Airspace Procedures**

With respect to procedures designed by Airservices in accordance with ICAO PANS-OPS and Document 9905, at a maximum height of 17m (56ft) AHD, the warehouse development will not affect any sector or circling altitude, nor any instrument approach or departure procedure at Sydney aerodrome.

The warehouse development will not affect the Sydney RTCC.

Note: procedures not designed by Airservices at Sydney aerodrome were not considered in this assessment.

#### **Communications/Navigation/Surveillance (CNS) Facilities**

We have assessed the proposed activity to the above specified height for any impacts to Airservices Non-Precision Navigation Aids, Anemometers, HF/VHF/UHF Communications, A-SMGCS, Radar, PRM, ADS-B, WAM or Satellite/Links and have no objections to it proceeding.

#### Precision (ILS)

From our analysis, Airservices believes that as per 4.10.6 of the supplied *Appendix E - Aviation Impact Assessment.pdf*, that the actions are reasonable to mitigate any post construction out of tolerance issues that had previously been identified.

#### **Air Traffic Control (ATC) Operations**

There are no additional instructions or concerns from our ATC.

#### **Summary**

The proposed activity does not impact Airservices operations or facilities at Sydney aerodrome.

This advice remains valid for any future time extensions if there is no change to the location and height of the proposed controlled activity for the purposes of sub-regulations 10(2)(b), 10(4)(b) and 13(d) of the *Airports (Protection of Airspace) Regulations 1996*.

If you have any further queries, please let our team know.

Kind regards,



## Richard Tomlinson

Airport Development & Engagement Advisor

---

OFFICIAL

**From:** Sally Munk <Sally.Munk@planning.nsw.gov.au>

**Sent:** Friday, September 29, 2023 11:27 AM

**To:** Airport Developments <Airport.Developments@AirservicesAustralia.com>; Airspace Protection <Airspace.Protection@casa.gov.au>; DPE PSVC Hazards Mailbox <hazards@planning.nsw.gov.au>; OEH HD Heritage Mailbox <HERITAGEMailbox@environment.nsw.gov.au>; LANDS <lands@jemena.com.au>; Laura Locke <Laura.Locke@planning.nsw.gov.au>; Airspace Protection <AirspaceProtection@syd.com.au>; urbangrowth@sydneywater.com.au; development@ausgrid.com.au

**Subject:** Proposed Waste Management Facility, Botany - SSD-62855708 - Request for Input to SEARs

You don't often get email from [sally.munk@planning.nsw.gov.au](mailto:sally.munk@planning.nsw.gov.au). [Learn why this is important](#)

**CAUTION:** This email was sent from an external email address. Do not click any links or open any attachments unless you trust the sender and know the content is safe.

The Department of Planning and Environment has received a request for Secretary's Environmental Assessment Requirements (SEARs) from Coombes Property Group for a Waste Management Facility, Botany. The proposed development is a State Significant Development under the *Environmental Planning and Assessment Act 1979*.

The Applicant proposes to construct and operate a waste transfer station with a capacity to process up to 300,000 tpa of construction and demolition waste, including new hardstand, purpose built warehouse, office and amenities, and two new crossovers.

The scoping report for the proposal may be viewed on the project page at:

<https://www.planningportal.nsw.gov.au/major-projects/projects/waste-management-facility-botany>

Your organisation is invited to provide input into the SEARs for the proposal including details of any key issues and assessment requirements by **Thursday 12 October 2023**.

If you have any enquiries, please contact me directly

Regards

Sally

### Sally Munk

Principal Planner

Industry Assessments

**Department of Planning and Environment**

T (02) 9274 6431 E [sally.munk@planning.nsw.gov.au](mailto:sally.munk@planning.nsw.gov.au)

4 Parramatta Square, 12 Darcy Street, Parramatta | Locked Bag 5022, Parramatta NSW 2124

[dpie.nsw.gov.au](http://dpie.nsw.gov.au)

---



I acknowledge the traditional custodians of the land and pay respects to Elders past and present. I also acknowledge all the Aboriginal and Torres Strait Islander staff working with NSW Government at this time.

Please consider the environment before printing this email.

**IMPORTANT:** This email and any attachments, may contain information that is confidential and privileged information. If you are not the intended recipient, you must not review, copy, disseminate, disclose to others or take action in reliance on, any material contained within this email. If you have received this email in error, please let Airservices Australia know by reply email to the sender informing them of the mistake and delete all copies of this email and any attachments.