

10 February 2020.

WE CARE. WE DELIVER.

REF: 1095_EGOVR:CK

via email.

Department of Planning, Industry and Environment
4 Parramatta Square, 12 Darcy Street
PARRAMATTA NSW 2150

PO Box 4
East Maitland NSW 2323

Four Mile Creek Road
Ashtonfield NSW 2323
AUSTRALIA

TEL + 61 2 4930 2600
FAX + 61 2 4933 8940

ABN 76 000 106 972

Attn: Mr. Matthew Sprott. Director Resource Assessments

RE: Meteorological Monitoring.

Dear Matthew,

Bloomfield Collieries Pty Limited received approval of the Rix's Creek South Continuation of Mining Project SSD 6300 on 12 October 2019.

In accordance with Schedule 2 Condition B28 of SSD 6300, Bloomfield Collieries provides the attached statement of compliance and calibration certificates to demonstrate that the following conditions have been satisfied:

METEOROLOGICAL MONITORING

B28. Prior to commencing mining operations under this consent and for the remaining life of the development, the Applicant must ensure that there is a suitable meteorological station operating in the vicinity of the site that:

- (a) complies with the requirements in the Approved Methods for Sampling and Analysis of Air Pollutants in New South Wales (DEC, 2007);*
- (b) is capable of continuous real-time measurement of wind speed, wind direction sigma theta and temperature; and*
- (c) is capable of measuring meteorological conditions in accordance with the NSW Industrial Noise Policy (EPA, 2000),*

Please note the Meteorological Station was fully operational on 10 February 2020, two weeks prior to commencement of Mining Operations under SSD 6300.

If you require any further information please do not hesitate to contact this office.

Yours sincerely



Chris Knight

Environment Manager

The Bloomfield Group

PO Box 4, EAST MAITLAND NSW 2323

Tele: 612 6578 8824 | Mob: 0403 058 777

Email: cknight@bloomcoll.com.au | Website: www.bloomcoll.com.au



CBased Environmental Pty Limited

ABN 62 611 924 264

20 December 2019

Attn: Chris Knight
Environment Manager
The Bloomfield Group
Via email: cknight@bloomcoll.com.au

Dear Chris,

RE: Rixs Creek Meteorological Station: Statement of Conformance to AS/NZS 3580.14:2014 and NSW EPA Approved Methods for the Sampling and Analysis of Air Pollutants In NSW

Thank you for engaging CBased Environmental to supply and install your meteorological station. **Table 1** provides a summary of the specification requirements associated with AS/NZS 3580.14:2014 (Methods for sampling and analysis of ambient air - Meteorological monitoring for ambient air quality monitoring applications), and the component specifications for equipment we have installed as part of your meteorological station installation. We are pleased to confirm the hardware installed meets or exceeds the requirements AS/NZS 3580.14:2014.

The station additionally meets the NSW EPA Approved Methods for the Sampling and Analysis of Air Pollutants (NSW EPA 2006), specifically method AM2: Guide for measurement of horizontal wind for air quality applications and method AM4: Meteorological monitoring guidance for regulatory modelling applications as the AS/NZS 3580.14:2014 requirements are equal to or more stringent than those detailed in AM2 or AM4.

Additional calculated parameters - Sigma Theta is calculated by the Yamatino method referenced in AM2 and Stability Class is calculated by the sigma theta method detailed in the Noise Policy for Industry (NSW EPA 2017). A temperature lapse differential is also calculated from the fan aspirated temperature sensors located at 2m and 10m.

Copies of calibration certificates issued by the original equipment manufacturers will be provided separately for your records.

Yours Faithfully

Colin Davies BSc MEIA CENVP
Environmental Scientist

Table 1: Parameter requirements and component specification summary

Component	AS/NZS Parameters – Minimum Requirements		Component Specification	Compliant
Gill Metpak 2 – wind speed sensor (anemometer)	Range	0.5 to 30 m/s	0-60 m/s (0-134mph)	Yes
	Total accuracy*	3% or ± 0.2 m/s (whichever is greater)	$\pm 2\%$ @ 12m/s	Yes
	Resolution	≤ 0.25 m/s	0.01m/s (0.02mph)	Yes
	Starting threshold	≤ 0.4 m/s	0.01m/s (0.02mph)	Yes
Gill Metpak 2 – wind direction sensor	Range	Mechanical 0 to 360° Output 0 to 355°	0 – 359° – no deadband	Yes
	Total accuracy*	$\pm 3^\circ$	$\pm 3^\circ$ @ 12m/s	Yes
	Resolution	1°	1°	Yes
Gill Metpak 2 – relative humidity sensor	Range	5 to 100% RH	0-100%	Yes
	Total accuracy: 10 to 90%	$\pm 2\%$ RH	$\pm 0.8\%$ @ 23°C	Yes
	Total accuracy: 90 to 100%	$\pm 4\%$ RH		
	Resolution	1% RH	0.1%	Yes
	Operating temperature	-10 to 55°C	-35°C to +70°C	Yes
Gill Metpak 2 – barometric pressure sensor	Range	750 to 1050 hPa	600 – 1100hPa	Yes
	Total accuracy	± 3 hPa	± 0.5 hPa	Yes
	Resolution	1 hPa	0.1hPa	Yes
	Operating temperature	-10 to 55°C	-20°C to +70°C	Yes
Environdata TA-60 – air temperature sensor	Range	-10° to 50°C	-10°C to +60°C	Yes
	Total accuracy (at 20°C)	$\pm 0.1^\circ$ C	$\pm 0.1^\circ$ C	Yes
	Time constant	<45 s	<30 seconds in air	Yes
Apogee TS-100 – fan aspirated shield	Aspirated shield face velocity	≥ 3 m/s	Aspiration rate: 6 m s^{-1} at full-speed; 3 m s^{-1} at half-speed	Yes
Hyquest Model TB4 Tipping Bucket Rain Gauge (0.2 mm capacity)	Minimum range	0 to 400 mm/h	700 mm/hr	Yes
	Total accuracy	$\pm 5\%$ (0 to 120 mm/h)	0-250 mm/hr: $\pm 2\%$ 250-500 mm/hr: $\pm 3\%$	Yes
	Minimum resolution	0.5 mm	0.2 mm	Yes

* excludes measurement deadband range

Product Test ReportRix Creek
AWS Met.**GILL****Product Tested: MetPak****Part Number: 1723-1B-2-111****Serial Number: 19170020****Test Date: 24/04/2019****Location: Gill Instruments Ltd**

GILL ensures that quality is inherent in all aspects of their activities and ensures that compliance with BS EN ISO9001: 2008 is maintained.

This report certifies that the above instrument has been tested in accordance with Gill internal procedures

Results

Test	Limits	Results
Wind Still Air Test (Zero Wind Speed)	Pass/Fail	Pass
Wind Tunnel Test (12m/s nominal)	Pass/Fail	Pass
Pressure Sensor (Comparison DPI 142)	Pass/Fail	Pass
Temperature Sensor (Comparison HC2-S (SCS certified))	Pass/Fail	Pass
Humidity Sensor (Comparison HC2-S (SCS certified))	Pass/Fail	Pass

Wind sensor generic calibration is traceable to the University of Southampton wind tunnel and Gill instrumentation is maintained in accordance with UKAS.

Comparisons for Temperature, Humidity and Pressure are done against reference UKAS traceable instruments. The reference system numbers of these instruments are listed above.

All tests have been successfully completed

On behalf of Gill Instruments Ltd



Les Rann
Quality Control

TEST REPORT

Rixs Creek
RT Noise
Met

Product family WXT530 series
 Product type WXT532
 Order code 2C1B1A2D1A1B
 Serial number R3350451
 Manufacturer Vaisala Oyj, Finland
 Test date 16 August 2019

This test report certifies that the product was thoroughly tested and inspected, and found to meet its published test limits when it was shipped from Vaisala.

Test results

Test	Result	Lower limit	Upper limit	Unit
Zero wind speed	0	0	0.4	m/s
Heating current	N/A	-	-	-
Current (service port)	1.21	0.5	2	mA
Communication (service port)	pass	PASS	PASS	-
Current (main port)	0.86	0.5	2	mA
Communication (main port)	pass	PASS	PASS	-

Ambient conditions / Humidity 41.44 ±5 %RH, Temperature 24.13 ±1 °C, Pressure 1011.41 ±1 hPa.

Signature

Technician

This report shall not be reproduced except in full, without the written approval of Vaisala. DOC233150-A.doc