


PCU56718

Sydney
WATER

3 November 2014

Attention: Thomas Mithen
Mr Ben Lusher
A/Director – Industry, Key Sites and Social Projects
Department of Planning and Infrastructure
PO Box 39
Sydney NSW 2000



Re: MLC Senior School, Burwood (SSD 6484)

Dear Mr Lusher,

Thank you for your letter notifying Sydney Water of the proposed development referenced above. We have reviewed the application and provide the following comments for your consideration.

Water

- The proposed development is able to connect to the 150mm drinking water main on the Eastern side of Park Road.

Wastewater


- The proposed development site is traversed by a number of wastewater mains. The closest wastewater main available for connection is the 225 mm main located on Park Road.
- Where proposed works are in close proximity to a Sydney Water asset, the developer may be required to carry out additional works to facilitate their development and protect the wastewater main. Subject to the scope of development, servicing options may involve adjustment/deviation and or compliance with the Guidelines for building over/adjacent to Sydney Water assets.

Sydney Water E-Planning

Sydney Water has an email address for planning authorities to submit statutory or strategic planning documents for review. This email address is urbangrowth@sydneywater.com.au

If you require any further information, please contact Hannah Gilvear of the Urban Growth Branch on 02 8849 5296 or e-mail hannah.gilvear@sydneywater.com.au.

Yours sincerely,



Greg Joblin
A/Manager, Growth Strategy