

Your ref
Our ref 238676-00
File ref

ARUP

Chris Michaels
City Plan Services
by email

Level 10 201 Kent Street
PO Box 76 Millers Point
Sydney 2000
Australia

t +61 2 9320 9320
d +61 2 9320 9824
f +61 2 9320 9321

neil.mcphail@arup.com
www.arup.com

29 January 2015

Dear Chris

UNSW Biological Science Building

Introduction

This letter considers the fire safety design of the new Biological Sciences Building at the University of NSW Kensington Campus, and specifically those aspects of the fire safety design that impact upon planning and the SSD Application for the building.

The proposed development will be split into 2 stages.

Stage 1 is for an nine storey building on the site of the existing Biomedical Theatres Building. Stage 1 also involves minor refurbishment of the lower ground floor of the existing D26 building and new pedestrian connections on the ground floor.

Stage 2 comprises refurbishment of the Ground Floor of Building D26 and the Ground Floor of the Biolink building. Stage 2 also involves the provision of a new facade to D26 and Biolink building.

The proposed new stage 1 building will be 9 storey mixed use including Class 8 laboratory, Class 9b education, Class 5 office and Class 7b storage as documented by Woods Bagot. It has an effective height more than 25m. The building features an atrium through all the levels.

Proposed Fire Safety Issues

The fire safety design of the building will generally satisfy the Performance Requirements of the Building Code of Australia (BCA) by complying with the Deemed-to-Satisfy (DtS) Provisions. However, there are some aspects of the design that are developed using performance based fire engineering to achieve compliance with the Performance Requirements of the BCA. The main aspects that affect the building layout are highlighted below.

The new building will abut the existing D26 development but is considered, for the purposes of the BCA, to be a separate building. The separation of buildings will need to be addressed through performance based fire engineering. There are a series of existing

that will demonstrate adequate separation is provided around the atrium that would limit fire spread floor to floor.

The stairs will comply with the deemed to satisfy provisions.

By the nature of the contents within the the lab fume cupboards are not to be provided with fire dampers as the duct passes into the shafts, An alternative solution will need to be prepared to assess this non compliance.

Egress from the floors appears to comply with the deemed to satisfy provisions, however to provide future flexibility, extended travel distances will be allowed for in the design, through the use of AS1670 smoke detection and possible enhanced warning systems. Due to the level of separation from the atrium it may not be necessary to exit all levels of the existing D26 and the new biological sciences buildings simultaneously. This will be assessed in more detail as the design progresses however it will be likely that both buildings will be notified of a fire regardless of the location due to the close interaction of the two, but if possible the evacuation would be staged to minimise disruption from nuisance alarms.

At this stage of the design, other fire safety aspects of the building appear to be DtS compliant. It is anticipated that there will be other non-compliances with the DtS Provisions of the BCA as the design develops, however it is considered that there are no issues that would affect the building layout arising from fire safety.

Yours sincerely



Neil McPhail
Senior Engineer