

PAVEMENT LEGEND	
	40mm Thickness asphaltic concrete (AC10) on 200mm Compacted thickness fine crushed rock (DGB20) on 350mm Compacted thickness fine crushed rock (DGS40) on CBR 3% (Assumed - to be confirmed by geotech)
	EXISTING PAVEMENT TO REMAIN
	EXISTING FOOTPATH TO REMAIN
	SUSPENDED SLAB BY STRUCTURAL ENGINEERS
	120mm Thickness concrete (f _c = 32 MPa) with SL72 fabric (40mm top cover) on 75mm Compacted thickness fine crushed rock (DGB20) on CBR 3% (Assumed - to be confirmed by Geotech)
	40mm Thickness concrete segmented pavers or landscaping (200x600 UNO) to landscape architect specification on 25mm Cement mortar on 120mm Thickness concrete (f _c = 32 MPa) with SL72 fabric (40mm top cover) on 75mm Compacted thickness fine crushed rock (DGB20) on CBR 3% (Assumed - to be confirmed by Geotech) or suspended slab by structural engineers.
	60mm Thickness concrete segmented pavers (300x600 UNO) or landscaping to landscape architect specification on 25mm Cement mortar on 160mm Thickness concrete (f _c = 32 MPa) with SL72 fabric (40mm top cover) on 75mm Compacted thickness fine crushed rock (DGB20) on CBR 3% (Assumed - to be confirmed by Geotech) or suspended slab by structural engineers.

Reference: 141191-NEWB-CV-DG-C3004.dwg - USES: jwmp - Plot File Overlaid: May 22, 2015 - 12:00pm

A1 2 1 2 3 4 5 6 7 8 9 10

Rev	Description	Eng	Draft	Date	Rev	Description	Eng	Draft	Date
P5	PRELIMINARY SSD ISSUE	HS	JW	23.01.15					
P4	SD/SSD ISSUE	HS	JW	08.12.14					
P3	PRELIMINARY SCHEMATIC DESIGN	HS	TB	21.11.14	P8	FINAL SD	HS	JW	22.05.15
P2	SSD DRAFT REPORT	HS	JW	18.11.14	P7	SSD ISSUE	HS	AS	09.04.15
P1	PRELIMINARY	SB	DS	31.10.14	P6	SSD ISSUE	HS	JW	06.03.15

Architect
JACOBS


TaylorThomsonWhitting
 Consulting Engineers
 48 Chandos Street St Leonards NSW 2065
 T: +61 2 9439 7288 F: +61 2 9439 3146 ttwesd@tw.com.au
 Taylor Thomson Whitting (NSW) Pty Ltd A.C.N. 113 578 377

Project
GOSFORD HOSPITAL REDEVELOPMENT - CIVIL SCHEMATIC DESIGN

Sheet Subject
SITeworks PLAN SHEET 3 OF 4

Scale: A1
 1:200
 Drawn: DWK
 Authorised:
 Job No: 141191-NEWB-CV-DG-C3004
 Drawing No: P8
 Revision: P8
 Plot File Created: May 22, 2015 - 12:00pm


PRELIMINARY



NOTE:
CLEANING & CCTV INVESTIGATION REQUIRED
TO VERIFY COUNCIL STORMWATER PIT & PIPE
CONDITION. ALLOW TO RECONSTRUCT IF ONLY
NECESSARY

PAVEMENT LEGEND	
	40mm Thickness asphaltic concrete (AC10) on 200mm Compacted thickness fine crushed rock (DGB20) on 350mm Compacted thickness fine crushed rock (DGS40) on CBR 3% (Assumed - to be confirmed by geotech)
	EXISTING PAVEMENT TO REMAIN
	EXISTING FOOTPATH TO REMAIN
	SUSPENDED SLAB BY STRUCTURAL ENGINEERS
	120mm Thickness concrete (f _c = 32 MPa) with SL72 fabric (40mm top cover) on 75mm Compacted thickness fine crushed rock (DGB20) on CBR 3% (Assumed - to be confirmed by Geotech)
	40mm Thickness concrete segmented pavers or landscaping (200x600 UNO) to landscape architect specification on 25mm Cement mortar on 120mm Thickness concrete (f _c = 32 MPa) with SL72 fabric (40mm top cover) on 75mm Compacted thickness fine crushed rock (DGB20) on CBR 3% (Assumed - to be confirmed by Geotech) or suspended slab by structural engineers.
	60mm Thickness concrete segmented pavers (300x600 UNO) or landscaping to landscape architect specification on 25mm Cement mortar on 160mm Thickness concrete (f _c = 32 MPa) with SL72 fabric (40mm top cover) on 75mm Compacted thickness fine crushed rock (DGB20) on CBR 3% (Assumed - to be confirmed by Geotech) or suspended slab by structural engineers.

File Name: 141191-NEWB-CV-DG-C3005.dwg - User: jenny - Plot File Created: May 22, 2015 - 12:03pm



Rev	Description	Eng	Draft	Date	Rev	Description	Eng	Draft	Date
P5	FINAL SD	HS	JW	22.05.15					
P4	SSD ISSUE	HS	AS	09.04.15					
P3	SSD ISSUE	HS	JW	06.03.15					
P2	PRELIMINARY SSD ISSUE	HS	JW	29.01.15					
P1	PRELIMINARY SSD ISSUE	HS	JW	23.01.15					

Architect
JACOBS


TaylorThomsonWhitting
Consulting Engineers
48 Chandos Street St Leonards NSW 2065
T: +61 2 9439 7288 F: +61 2 9439 3146 ttwsw@ttw.com.au
Taylor Thomson Whitting (NSW) Pty Ltd A.C.N. 113 578 377

Project
GOSFORD HOSPITAL REDEVELOPMENT - CIVIL SCHEMATIC DESIGN

Sheet Subject
SITWORKS PLAN SHEET 4 OF 4

Scale: A1 1:200
Drawn: DWK
Authorised:
Job No: 141191-NEWB-CV-DG-C3005
Drawing No:
Revision: P5
Plot File Created: May 22, 2015 - 12:03pm

PRELIMINARY



SECTION 1
 SCALE 1:100

File Name: H1191-NEWB-CV-DG-C4001.dwg User: jenny - Plot File Created: May 22, 2015 - 12:05pm

A1 0 1 2 3 4 5 6 7 8 9 10

Rev	Description	Eng	Draft	Date	Rev	Description	Eng	Draft	Date
P5	FINAL SD	HS	JW	22.05.15					
P4	SSD ISSUE	HS	JW	06.03.15					
P3	PRELIMINARY SSD ISSUE	HS	JW	23.01.15					
P2	SD/SSD ISSUE	HS	JW	09.12.14					
P1	PRELIMINARY	SB	DS	31.10.14					

Architect
JACOBS

TTW
TaylorThomsonWhitting
 Consulting Engineers
 48 Chandos Street St Leonards NSW 2065
 T: +61 2 9439 7288 F: +61 2 9439 3146 ttw@tdw.com.au
 Taylor Thomson Whitting (NSW) Pty Ltd A.C.N. 113 578 377

Project
GOSFORD HOSPITAL REDEVELOPMENT - CIVIL SCHEMATIC DESIGN

Sheet Subject
SECTION SHEET

Scale: A1
 1:500

Drawn
 DWK

Authorised

Job No
141191-NEWB-CV-DG-C4001

Drawing No
P5

Revision

Plot File Created: May 22, 2015 - 12:05pm

PRELIMINARY