

Job no SY140017

09/08/2016

Dez Wong
Level 14, Tower Three, International Towers Sydney
Exchange Place, 300 Barangaroo Avenue
Barangaroo NSW 2000

Dear Dez

One Sydney Harbour – Residential Building R5

Preliminary fire safety engineering review

This letter supports a State Significant Development Application (SSD 6966) submitted to the Minister for Planning pursuant to Part 4 of the Environmental Planning and Assessment Act 1979 (EP&A Act). The Development Application (DA) seeks approval for construction of a residential flat building (known as Residential Building R5) and associated works at Barangaroo South.

The Residential Building R5 DA seeks approval for the construction and use of a 29 storey residential flat building comprising 151 apartments, ground floor retail, the allocation of car parking, services, plant and storage within the Stage 1B Basement (subject of a separate concurrent DA), and the construction of ancillary landscaping and temporary public domain.

Approval for the construction of Residential Building R5's core and associated plant and services within the basement is being sought as part of the concurrent Stage 1B Basement DA and do not form part of this DA.

Defire has undertaken a preliminary fire safety engineering review to determine whether the design can be demonstrated to achieve compliance with the performance requirements of the National Construction Code Series 2014 Volume One – Building Code of Australia (BCA). The review was based on the drawings and information listed in Attachment 1.

The alternative solutions identified to date are listed in Table 1.

Item	Description of alternative solution	DTS provision	Performance requirement
1.	Reduction of fire rating in ground floor and podium level 1 retail to 2 hours instead of 3 hours. This includes the following areas: - Fire separation between the retail and residential portions on the ground floor and podium level 1. - Fire separation between the retail areas and the residential storeys above.	Clauses C1.1, C2.7, C2.8 and C2.9 and specification C1.1	CP1 and CP2
2.	The required fire rated floors and walls bounding the sole occupancy units do not extend to the outer skin of the double skin façade.	Clause C1.1 and specification C1.1	CP2
3.	Reduction of structural adequacy to 60 minutes instead of 90 minutes for floor slabs in wet areas. This is due to a reduced slab thickness in these areas.	Clause C1.1 and specification C1.1	CP1 and CP2
4.	Extended travel distance to point of choice of up to 30m in lieu of 20m – from non-residential areas.	Clause D1.4	DP4 and EP2.2



Item	Description of alternative solution	DTS provision	Performance requirement
5.	Extended travel to point of choice from the residential levels of up to 12m instead of 6m. This occurs on podium level 2 and residential levels 1 to 25.	Clause D1.4	DP4 and EP2.2
6.	The exit doors from the retail tenancies on the ground floor are proposed to swing against the direction of egress.	Clause D2.20	DP2 and DP4
7.	The fire control room is located within basement level B0 and involves a change in level to a road or open space in excess of 300mm – approximately 3m.	Clause E1.8 and specification E1.8	EP1.6
8.	The hydrant booster assembly facing Hickson Road is not within sight of the main building entry. The booster assembly is not provided with fire rated protection extending 2m each side of and 3m above the upper hose connections in accordance with AS 2419.1-2005. The external fire hydrants are located less than 10m from the building and are not provided with fire rated protection extending 2m each side of the fire hydrant outlet and not less than 3m above the ground adjacent to the fire hydrant.	Clause E1.3 and AS 2419.1-2005	EP1.3
9.	The sound systems and intercom systems for emergency purposes do not comply as the speech intelligibility (STI) requirement of ≥ 0.5 is not achieved in the bathrooms and balconies of the sole-occupancy units and the plant rooms.	Clause E4.9	EP4.3
10.	The proposed sprinkler system will include the following: - Proprietary FM approved type B monitoring switches are proposed to be used on isolation valves instead of type A switches retrofitted to the valve. - High pressure valves manufactured by Victaulic not covered under AS 4118.1.6-1995 are to be utilised on the high pressure stage of the combined sprinkler / hydrant system. - Use of 15mm (K-factor 8) sprinklers instead of 10mm (K-factor 5.6) sprinklers for residential common lobbies and concealed space protection. - Shower cubicles are not proposed to be provided with sprinkler coverage.	Clause E1.5 and AS 2118.1-1999, AS 2118.6-2012 and AS 4118.1.6-1995	EP1.4

Table 1 Preliminary list of alternative solutions

The areas of the design which impact upon fire brigade operations will be discussed with Fire & Rescue NSW. This includes perimeter vehicular access, location of fire control centres, fire hydrant booster and pump locations.

It is Defire's professional opinion that it is possible to develop alternative solutions for the issues identified to demonstrate compliance with the relevant performance requirements of the BCA without major changes to the proposed design.

The details of the proposed alternative solutions are subject to the outcome of the fire engineering brief and analysis which will be carried out in accordance with the International Fire Engineering Guidelines.



The alternative solutions for the building will be developed as part of the ongoing design and development process and documented in a format suitable for submission to the relevant approval authorities. It is noted that additional alternative solutions may be identified during the ongoing design development process in consultation with the design team.

Please contact me on 02 9211 4333 if you have any questions.

Yours sincerely

Victor Tung
Accredited fire safety engineer
Defire – Innovative fire safety



Attachment 1 Drawings and information

Drawing title	Dwg no	Drawn
Site Plan	BR5_ASD_PA1_0002	Lend Lease / Renzo Piano Building Workshop
Plan Ground Floor Level 00	BR5_ASD_PA1_2000	Lend Lease / Renzo Piano Building Workshop
Plan Podium Level 01	BR5_ASD_PA1_2001	Lend Lease / Renzo Piano Building Workshop
Plan Podium Level 02	BR5_ASD_PA1_2002	Lend Lease / Renzo Piano Building Workshop
Plan Lower Plate Typical Level 01-13	BR5_ASD_PA1_3001	Lend Lease / Renzo Piano Building Workshop
Plan Lower Plate Typical Level 14	BR5_ASD_PA1_3014	Lend Lease / Renzo Piano Building Workshop
Plan Mid Plate Typical Level 15-24	BR5_ASD_PA1_3015	Lend Lease / Renzo Piano Building Workshop
Plan Mid Plate / Plant Level 25	BR5_ASD_PA1_3025	Lend Lease / Renzo Piano Building Workshop
Plan Penthouse Level 26	BR5_ASD_PA1_3026	Lend Lease / Renzo Piano Building Workshop
Plan Roof Level 27	BR5_ASD_PA1_3027	Lend Lease / Renzo Piano Building Workshop
Elevation North-West (Park)	BR5_ASD_PA1_4001	Lend Lease / Renzo Piano Building Workshop
Elevation East (Hickson Rd)	BR5_ASD_PA1_4002	Lend Lease / Renzo Piano Building Workshop
Elevation South-West (Lift Lobby)	BR5_ASD_PA1_4003	Lend Lease / Renzo Piano Building Workshop
Elevation South (Watermans Quay)	BR5_ASD_PA1_4004	Lend Lease / Renzo Piano Building Workshop
Overall Section AA	BR5_ASD_PA1_5001	Lend Lease / Renzo Piano Building Workshop
Overall Section BB	BR5_ASD_PA1_5002	Lend Lease / Renzo Piano Building Workshop

Other information	Ref no	Date	Prepared by
Building Code of Australia Report – One Sydney Harbour Residential Building R5	068048-18BCA rev E	23/02/16	McKenzie Group Consulting