



Our ref. DOC17/379374-01
Sender's ref. SSD 7075 MOD1

Ms Bianca Thornton
Team Leader – Industry Assessments
NSW Department of Planning & Environment
GPO Box 39
SYDNEY NSW 2001

E-MAIL & STANDARD POST

31 July 2017

Attention: Bianca Thornton

Dear Ms Thornton

Modification Application – Erskine Park Resource Management Facility – (SSD 7075 MOD 1)

I refer to your letter dated 18 July 2017 inviting the NSW Environment Protection Authority (**EPA**) to comment on the Modification Application for the development consent for the Erskine Park Resource Management Facility located at 85-57 Quarry Road, Erskine Park (**the Development**).

I have reviewed the proposed changes to the development, particularly the revised storm water management system. The proposed change to install a smaller detention basin (710 m³ compared to 740 m³) is justified by a reduced hardstand area (which will result in a reduction the volume of stormwater runoff and increase the area of the permeable stabilised embankment).

Based on the information provided in the Modification Application, the volume reduction to the storm water detention basin will not alter the conditions recommended by the EPA in the General Terms of Approval on 18 March 2016 and as such the EPA has no further submission to make in respect of the Modification Application for the Development.

Please contact Lara Barrington on 9995 5713 if you have any questions.

Yours sincerely

A handwritten signature in blue ink, appearing to read 'Trevor Wilson'.

TREVOR WILSON
Unit Head Waste Compliance
Environment Protection Authority