

## Appendix E Civil statement

---

*Prepared by ARUP*

*January 2016*

Your ref  
Our ref 236482-30  
File ref

# ARUP

For the attention of Jane Fielding  
Architectus Pty Ltd  
Level 18 MLC Centre  
19 Martin Place  
SYDNEY NSW 2000

Level 10 201 Kent Street  
PO Box 76 Millers Point  
Sydney 2000  
Australia

t +61 2 9320 9320  
d +61 2 9320 9495  
f +61 2 9320 9321

mal.knight@arup.com  
www.arup.com

14 January 2016

Dear Jane

## **Westmead - Multi Storey Carpark EIS, EPA Review Response**

We refer to your email dated 11 January 2016 and the attached letter from the EPA (their reference EF15/9530, DOC15/508402-01) on their review of the EIS for the Westmead Multistorey Carpark prepared by Architectus.

Arup have review the EPA letter and their comments on the Water Quality and civil aspects and wish to advise that we believe that the information requested in the EPA review of the EIS is addressed in detail in Appendix J – Part 1 the Arup Darcy Road Multi Storey Car Park SSD – Civil Report, Rev B, dated 29 October 2015 and Appendix J – Part 2 the associated Arup drawings of the EIS and is sufficient for the tender reference design which was being prepared.


Since the submission of the SSD report and drawings and the further development of the documentation to tender reference design stage, the documentation has changed as follows:

- The multi story carpark (MSCP) has been moved 1.9 metres north and raised 300mm.
- The overland flow path has been relocated from between the MSCP and Dental Clinic Building to the west of the MSCP adjacent Darcy Road.
- The landscape area mounds have been enlarged to accommodate more spoil material.
- The overall result of the above has significantly reduced the amount of spoil to be disposed of offsite to an approved land fill site.
- The drainage has been adjusted to suit accordingly.



We hope this addresses the answers to the EPA letter for you.

Yours faithfully

A handwritten signature in black ink, appearing to read "Malcolm B Knight". The signature is fluid and cursive, with the first name "Malcolm" being more legible than the last name "Knight".

Malcolm B Knight  
Associate

cc Matt Ellis PwC