



Core Engineering Group • Fire • Risk • Emergency Management

Compass Project Management Pty Ltd
Suite 3, Level 7
56 Berry Street
North Sydney NSW 2060

11 March 2016 | Final issue | Report No. s141588_FSS_03

Fire Safety Strategy

Australia Habitat and Taronga Wildlife Retreat

Bradleys Head Road, Mosman NSW

Sydney

Suite 401, Grafton Bond Building
201 Kent Street, Sydney NSW 2000

Phone | + 61 2 9299 6605

Fax | + 61 2 9299 6615

Email | sydney@coreengineering.com.au

Melbourne

Suite 25, Level 27
101 Collins Street, Melbourne VIC 3000

Phone | + 61 3 9653 7460

Email | melbourne@coreengineering.com.au

www.coreengineering.com.au

Report Details

Project: Australia Habitat and Taronga Wildlife Retreat
Bradleys Head Road, Mosman NSW 2088

Document: Fire Safety Strategy

Report No.: s141588_FSS_03

Report Revision History

REV	DATE ISSUED	COMMENT	PREPARED BY	REVIEWED BY
01	01/12/15	Draft Issue for comment	Tass Georgas <i>B.Tech (Building Surveying)</i> <i>Grad.Dip (Fire Safety & Risk Engineering)</i> <i>M.Eng (Construction Management)</i> <i>Registered Building Practitioner (Vic): EF31029</i> <i>AffillEAust</i> <i>MAIB</i>	Vicky Trajkovski <i>BE (Architectural)</i> <i>Grad.Dip (Building Fire Safety & Risk Engineering)</i>
02	08/03/16	Final issue	Vicky Trajkovski <i>BE (Architectural)</i> <i>Grad.Dip (Building Fire Safety & Risk Engineering)</i>	Sandro Razzi <i>BE (Building), Grad. Dip. (Performance Based Building and Fire Codes),</i> <i>Accredited Fire Engineer BPB 0501,</i> <i>FIEAust,</i> <i>CPEng 2180287</i>
03	11/03/16	Final issue		

Copyright ©

All rights reserved. No part of this document may be reproduced, published, transmitted or adapted in any form or by any means without the written permission of CORE Engineering Group.

Disclaimer

The information contained in this document is provided for the sole use of the recipient and no reliance should be placed on the information by any other person. In the event that the information is disclosed or furnished to any other person, CORE Engineering Group accepts no liability for any loss or damage incurred by that person whatsoever as a result of using the information.

TABLE OF CONTENTS

EXECUTIVE SUMMARY	ii
1 INTRODUCTION	1
1.1 OVERVIEW	1
1.2 FIRE SAFETY OBJECTIVES	1
1.3 REGULATORY FRAMEWORK OF THE FIRE ENGINEERING ASSESSMENT	2
2 PROJECT SCOPE	4
2.1 OVERVIEW	4
2.2 RELEVANT STAKEHOLDERS	4
2.3 SOURCES OF INFORMATION	4
2.4 LIMITATIONS AND ASSUMPTIONS	5
3 PRINCIPAL BUILDING CHARACTERISTICS	6
3.1 OVERVIEW	6
3.2 SITE LOCATION	6
3.3 BUILDING DESCRIPTION	9
3.4 BCA ASSESSMENT SUMMARY	16
3.5 EXISTING EMERGENCY PROCEDURES	16
4 DOMINANT OCCUPANT CHARACTERISTICS	17
4.1 OVERVIEW	17
4.2 OCCUPANT NUMBERS AND DISTRIBUTION	17
4.3 OCCUPANT ATTRIBUTES	17
4.4 OCCUPANT FAMILIARITY	18
4.5 EMERGENCY TRAINING	18
5 FIRE BRIGADE CHARACTERISTICS	19
5.1 OVERVIEW	19
5.2 FIRE BRIGADE ACCESS	19
5.3 FIRE FIGHTING EQUIPMENT	20
6 FIRE HAZARDS AND PROTECTIVE MEASURES	21
6.1 OVERVIEW	21
6.2 FIRE STATISTICS	21
6.3 SPRINKLER EFFECTIVENESS & RELIABILITY	27
6.4 FIRE LOAD	27
6.5 FIRE GROWTH RATE AND INTENSITY	28
6.6 FIRE HAZARDS	29
6.7 PREVENTATIVE AND PROTECTIVE MEASURES	30
7 BCA DTS NON-COMPLIANCE ASSESSMENT	32
7.1 OVERVIEW	32
7.2 BCA DTS NON-COMPLIANCE ASSESSMENT	32
8 PROPOSED FIRE SAFETY STRATEGY	39
8.1 OVERVIEW	39
8.2 EGRESS PROVISIONS	39
8.3 PASSIVE FIRE PROTECTION	40
8.4 ACTIVE FIRE PROTECTION SYSTEMS	40
8.5 FIRST AID FIRE FIGHTING	40

8.6	FIRE BRIGADE INTERVENTION	40
8.7	BUILDING MANAGEMENT PROCEDURES	41
9	REFERENCES	42

1 INTRODUCTION

1.1 OVERVIEW

This Fire Engineering Report has been undertaken to nominate a proposed Alternative Solution for assessing compliance with the nominated Performance Requirements of the Building Code of Australia 2015 (BCA) [1] in accordance with the methodologies defined in the International Fire Engineering Guideline IFEG [3].

In order to develop and assess the nominated non-compliances the following flowchart process is to be adopted.




Figure 1-1: Fire Safety Strategy Process

The scope of the Fire Safety Strategy is to detail the nominated non-complying BCA Deemed-to-Satisfy (DTS) provisions with the performance requirements of the BCA and provide methodologies for establishing a workable and safe Fire Safety Strategy through a trial design.

1.2 FIRE SAFETY OBJECTIVES

The objective of this Fire Engineering Assessment is to develop a Fire Safety System, which satisfies the performance requirements of the BCA whilst maintaining an acceptable level of life safety, protection of adjacent property and adequate provisions for Fire Brigade intervention. At a community level, fire safety objectives are met if the relevant legislation and regulations are complied with. As stated in the BCA, “A Building Solution will comply with the BCA if it satisfies the Performance Requirements”. In addition to this certain non-regulatory objectives exist as detailed below.

1.2.1 Building regulatory objectives

The following items are a summary of the fire and life safety objectives of the BCA:

- **Life safety of occupants** - the occupants must be able to leave the building (or remain in a safe refuge) without being subject to hazardous or untenable conditions. The objective of the Fire Engineering Assessment is to demonstrate that the proposed building design and fire safety systems would minimise the risk of exposing building occupants to hazardous or untenable conditions in an event of a fire.
- **Life safety of fire fighters** - fire fighters must be given a reasonable time to rescue any remaining occupants before hazardous conditions or building collapse occurs. The objective of the Fire Engineering Assessment is to demonstrate that the proposed building design and fire safety systems would facilitate fire brigade intervention and minimise the risk of exposing fire fighters to hazardous or untenable conditions in an event of a fire.
- **Protection of adjoining buildings** - structures must not collapse onto adjacent property and fire spread by radiation should not occur. The objective of the Fire Engineering Assessment is to demonstrate that the proposed building design and fire safety systems would minimise the risk of fire spreading from one building to another.

1.2.2 Fire Brigade objectives

The overall philosophical Fire Brigade objectives throughout Australia are to protect life, property and the environment from fire according to the Fire Brigade Intervention Model (FBIM) [14] as per the Fire Services State and Territory Acts and Regulations.

Over and above the requirements of the BCA, the Fire Brigade has functions with regard to property and environmental protection and considerations regarding occupational health and safety for its employees.

1.2.3 Non-prescribed objectives

Fire Engineering has an overarching benefit to many facets of the built environment where non-prescribed objectives can have an influence on the Fire Safety Strategy adopted. Although not assessed within, the following can be considered if requested.

- **Business continuity** - will the loss of a particular facility due to fire / smoke damage result in excessive financial impact on the client? For example, is the facility critical to business continuity?
- **Public perception** - should a fire occur within the facility is there likely to be questionable public perception about the safety and operation of the facility?
- **Environmental protection** - fires of excessive sizes can have significant effects on the environment which may require a detailed risk assessment to minimise such outcomes.
- **Heritage salvation** - buildings can have a heritage value for both cultural and educational purposes which can be destroyed by insufficient fire protection.
- **Risk mitigation / insurance limitations** - are there specific limitations on insurance with respect to risk mitigation and fire safety design? i.e. Does the relevant insurer have concerns with respect to open voids through the building?
- **Future proofing (isolation of systems)** - what flexibility is required in the overall design to allow for future development or changes in building layout?
- **Occupational Health and Safety (OHS) requirements** - buildings may have specific fire safety requirements pertaining to OHS requirements.

1.3 REGULATORY FRAMEWORK OF THE FIRE ENGINEERING ASSESSMENT

1.3.1 Building Code of Australia

One of the goals of the BCA is the achievement and maintenance of acceptable standards of safety from fire for the benefit of the community. This goal extends no further than is necessary in the public interest and is considered to be cost effective and not needlessly onerous in its application.

Section A0.5 of the BCA [1] outlines how compliance with the Performance Requirements can be achieved. These are as follows:

- (a) *complying with the Deemed-to-Satisfy Provisions; or*
- (b) *formulating an Alternative Solution which –*
 - (i) *complies with the Performance Requirements; or*

- (ii) *is shown to be at least equivalent to the Deemed-to-Satisfy Provisions or*
- (c) *a combination of (a) and (b).*

Section A0.9 of the BCA provides several different methods for assessing that an Alternate Solution complies with the Performance Requirements. These methods are summarised as follows:

- (a) *Evidence to support that the use of a material, form of construction or design meets a Performance Requirement or a Deemed-to-Satisfy Provision.*
- (b) *Verification Methods such as:*
 - (i) *the Verifications Methods in the BCA; or*
 - (ii) *such other Verification Methods as the appropriate authority accepts for determining compliance with the Performance Requirements.*
- (c) *Comparison with the Deemed-to-Satisfy Provisions.*
- (d) *Expert Judgment.*

Section A0.10 of the BCA provides methods for complying with provisions A1.5 (to comply with Sections A to J of the BCA inclusive). The following method must be used to determine the Performance Requirements relevant to the Alternative Solution: These methods are summarised as follows:

- (a) *Identify the relevant Deemed-to-Satisfy Provision of each Section or Part that is to be the subject of the Alternative Solution.*
- (b) *Identify the Performance Requirements from the same Section or Part that are relevant to the identified Deemed-to-Satisfy Provisions.*
- (c) *Identify Performance Requirements from the other Sections and Parts that are relevant to any aspects of the Alternative Solution proposed or that are affected by the application of the Deemed-to-Satisfy Provisions that are the subject of the Alternative Solution.*

1.3.2 International Fire Engineering Guidelines 2005

The IFEG [3] document has been developed for use in fire safety design and assessment of buildings and reflects world's best practice. The document is intended to provide guidance for fire engineers as they work to develop and assess strategies that provide acceptable levels of safety.

The document is particularly useful in providing guidance in the design and assessment of Alternative Solutions against the Performance Requirements of the BCA. The prescribed methodology set out in the IFEG has been generally adopted in the Fire Engineering Report.

2 PROJECT SCOPE

2.1 OVERVIEW



CORE Engineering Group has been engaged to develop a Fire Safety Strategy for the construction of Taronga Wildlife Retreat at Bradleys Head Road, Mosman NSW. The purpose of this fire safety strategy is to outline the fire engineering principles that will be utilised in ensuring that the prescriptive Deemed-to-Satisfy (DTS) non-compliances noted in the Building Code of Australia (BCA) report are resolved in order to conform to the building regulations and permit development approval.

The complete fire engineered analysis will be included within the Fire Engineering Report, and as such is not documented herein. This document does however outline the construction and management requirements considered necessary to achieve an acceptable level of life safety within the building as a result of the Alternative Solution and to satisfy the Performance Requirements of the BCA.

2.2 RELEVANT STAKEHOLDERS

This Alternative Solution has been developed collaboratively with the relevant stakeholders as identified below:

Table 2-1: Relevant Stakeholders

ROLE	NAME	ORGANISATION
Client/Project Manager	Matthew Spooner	Taronga Conservation Society Australia
Development Manager	Paul McDonald	Compass Project Management
Principal Certifying Authority/BCA Consultant	Andrew Brohier Andrew Maxon	McKenzie Group
Architect	Mark Davey Lei Li	Cox Richardson
Fire Safety Consultant	Vicky Trajkovski	Core Engineering Group
Fire Safety Engineer	Sandro Razzi	

It should be noted that at times some parties may have a vested interest in the outcome of the Fire Engineering assessment. Such parties can include local fire brigades, insurers, Environmental Protection Authority (EPA), project control groups, end users and community representatives. Although not always a legislative requirement, the design team should give due consideration to their inclusion in the Fire Engineering process. Where not required by legislation it is the client's decision to involve such parties, especially local fire brigade, to ensure a transparent and adequate fire safety solution for all. Where we are not notified of the inclusion of such parties it is assumed the client / representative has given due consideration to the above.

2.3 SOURCES OF INFORMATION

The following sources of information have been provided by the design team:

- BCA Compliance report prepared by McKenzie Group. Project Ref. 067876 – 04BCA Revision D, 10.02.2016.
- Architectural plans provided by COX Architects, as indicated in Table 2-2.

Table 2-2: Drawings

DRAWING NO.	DESCRIPTION	REVISION	DATE
AR-DA-1001	LOCATION PLAN	03	10.03.16
AR-DA-2101	LEVEL A – RL51 PLAN	03	10.03.16
AR-DA-2102	LEVEL B – RL54 PLAN	03	10.03.16
AR-DA-2103	LEVEL C – RL57 PLAN	03	10.03.16

DRAWING NO.	DESCRIPTION	REVISION	DATE
AR-DA-2104	LEVEL D –RL60 PLAN	03	10.03.16
AR-DA-2105	LEVEL E - RL63 PLAN	03	10.03.16
AR-DA-2106	LEVEL 1 – RESTAURANT RL67 PLAN	03	10.03.16
AR-DA-2107	LEVEL 2 – TERRACE RL71 PLAN	03	10.03.16


2.4 LIMITATIONS AND ASSUMPTIONS

In this instance the Fire Safety Strategy is developed based on applicable limitations and assumptions for the development which are listed as follows:

- The report is specifically limited to the project described in Section 3.
- The report is based on the information provided by the team as listed above in Section 2.3.
- Building and occupant characteristics are as per Section 3 and 4 respectively of this report. Variations to these assumptions may affect the Fire Engineering Strategy and therefore they should be reviewed by a suitably qualified Fire Engineer should they differ.
- As per any building design, DTS or otherwise, the report is limited to the fire hazards and fuel loads as prescribed in Section 6.2. The report does not provide guidance in respect of areas, which are used for Dangerous Good storage, processing of flammable liquids, explosive materials, multiple fire ignitions or sabotage of fire safety systems.
- The development complies with the fire safety DTS provisions of the BCA [1] with all aspects for fire and life safety unless otherwise stated in this report. Where not specifically mentioned, the design is expected to meet the BCA DTS requirements of all relevant codes and legislation at the time of construction and / or at the time of issue of this report.
- The assessment is limited to the objectives of the BCA and does not consider property damage such as building and contents damage caused by fire, potential increased insurance liability and loss of business continuity.
- Malicious acts or arson with respect to fire ignition and safety systems are limited in nature and are outside the objectives of the BCA. Such acts can potentially overwhelm fire safety systems and therefore further strategies such as security, housekeeping and management procedures may better mitigate such risks.
- This report is prepared in good faith and with due care for information purposes only, and should not be relied upon as providing any warranty or guarantee that ignition or a fire will not occur.
- The Fire Engineering Strategy is only applicable to the completed building. This report is not suitable, unless approved otherwise, to the building in a staged handover.
- Where parties nominated in Section 2.2 have not been consulted or legislatively are not required to be, this report does not take into account, nor warrant, that fire safety requirements specific to their needs have been complied with.

3 PRINCIPAL BUILDING CHARACTERISTICS

3.1 OVERVIEW



Building characteristics are assessed as part of the Fire Engineering Review due the following:

1. The location can affect the time for fire brigade intervention and potential external fire exposure issues.
2. The structure will impact on the ability to resist a developing fire and support condition to allow occupants to escape the building and the fire brigade to undertake fire fighting to the degree necessary.
3. The floor area determines the potential fire size and area required to be evacuated in the event of a fire.
4. BCA details such as Type of Construction, Class and Height will dictate passive and active fire safety systems.

3.2 SITE LOCATION

The development site is located on the shores of Sydney Harbour in the suburb of Mosman, approximately 8km north-east of Sydney’s central business district.

Given the location of the Taronga Zoo accommodation buildings relatively close proximity to vegetation to the east of the site, the site is exposed to high bushfire risks.

The site is divided into eight zoogeographic regions across 21 hectares. The Taronga Wildlife Retreat is located to the east of the site along the Bradleys Head Road.




Figure 3-1: Site Location

Source: www.googlemaps.com.au




Figure 3-2: Plan

The building site influences the likely fire brigade intervention times, and given the close proximity to the nearest fire station is expected to facilitate a relatively convenient and expedient fire brigade response. Furthermore being located in an inner suburb of a major city, the development is provided with the services and facilities expected in an urban setting. The two nearest fire brigade stations provided with permanent staff are Mosman and Neutral Bay approximately 2.0 km and 3.5 km from the site respectively when considering actual driving directions.




Figure 3-3: Proposed site plan

3.3 BUILDING DESCRIPTION

The subject development comprises of 5 residential buildings which are connected via external stairways and open passageways in order to form a single building. The passageways between buildings, although covered, are open and therefore provide well ventilated egress paths. The Class 3 portion of the building has a rise in storeys of 6, with a single Class 3 “building” located at the bottommost level and increasing the number of “buildings” at each level due to the steep sloping topography of the site. In addition to the Class 3 parts (Guest Lodge), a new restaurant and terrace have been proposed to the north-east end of the Class 3 parts. The restaurant will be located on Level 1, and associated kitchen will be located on Level E. The Class 6 parts will be connected to the Class 3 parts by open elevated passageways.




Figure 3-4: Level A




Figure 3-5: Level B



Figure 3-6: Level C



Figure 3-7: Level D



Figure 3-8: Level E




Figure 3-9: Level 1 – Restaurant




Figure 3-10: Level 2 – Terrace




Figure 3-11: Site section

3.4 BCA ASSESSMENT SUMMARY

Table 3-1: BCA Building Characteristics


CHARACTERISTIC	DESCRIPTION
Classification	3 – Residential Accommodation 6 – Restaurant and retail
Construction Type	A
Rise in Storeys	7 storeys
Effective Height	12 m
Floor Area	Approximately 1,100 m ² for class 6 parts

3.5 EXISTING EMERGENCY PROCEDURES

The existing Taronga Conservation Society Australia (TCSA) facility is subject to a range of emergency procedures owing to the secure nature of the facility. The zoo is monitored on a 24-hour basis by security staff and an emergency control organisation (ECO) exists to manage identified emergencies. In relation to bushfire threats from the immediate zoo surrounds, it is also understood that TCSA has developed specific emergency procedures to manage and mitigate the risk to the zoo’s visitors, zoo property, staff and animals.

4 DOMINANT OCCUPANT CHARACTERISTICS

4.1 OVERVIEW



Occupant characteristics are considered in the fire engineering process for the following reasons:

1. Population numbers can dictate the time required to evacuate the building and the required life safety systems to be provided due to evacuation times.
2. Physical and mental attributes affects the occupants capacity to respond to various fire cues and react accordingly.
3. Familiarity of occupants can affect the time taken to evacuate the building and subsequent active / passive requirements.

4.2 OCCUPANT NUMBERS AND DISTRIBUTION

The population to be used for the purposes of this fire engineering assessment will be based on:

- BCA DTS Table D1.13 for the Class 6 areas, which equates to 1m² person;
- Residential accommodation units: 3 occupants per room; and
- Larger residential accommodation units on Level D: 3 occupants per room.

Where relevant subordinate NSW legislation prescribes an alternative floor area to occupant ratio in respect of the use of dormitories, boarding houses and similar shared accommodation buildings, the ratios specified within the relevant NSW legislation will be used to determine the design population for the residential accommodation areas.

4.3 OCCUPANT ATTRIBUTES

Occupants throughout the building will vary from alert and able bodied, to occupants who are asleep, affected by medication and or alcohol and people with disabilities.

The occupant group generally represents the broader population, i.e. all age groups, levels of mobility and disability are likely to be present. At times, a portion may be affected by alcohol, medication or other drugs that could inhibit their response time and actions/reactions in a fire emergency.

- **Taronga Conservation Society Australia Staff and Security** are expected to be mobile with normal hearing and visual abilities, and occupants in this group are considered to take and implement decisions independently, and require minimal assistance during evacuation in a fire emergency. This occupant group is expected to be awake and fully conscious at all times when inside the building; and
- **Short-term Guests** are unlikely to be familiar with the building's layout. Further knowledge of the egress provisions cannot be depended upon as they will most likely rely upon the exit and emergency evacuation signage available in the event of a fire emergency; and
- **Visitors** to the zoo's facilities are expected to be mobile with normal hearing and visual abilities, this occupant group are expected to be capable of making and implementing decisions independently however may require assistance in locating the nearest and safest egress path in an emergency; and
- **External Maintenance Contractors** are expected to be mobile with normal hearing and visual abilities and occupants in this group are considered to take and implement decisions independently and require minimal assistance during evacuation in a fire emergency. The contractors are expected to be awake and aware of their surroundings at all times when inside the building; and
- **FRNSW** are expected to be equipped with safety equipment and will be educated in fire fighting activities and the dangers associated with fire incidents. This occupant group would be expected to be in a position to assist other occupants requiring assistance to evacuate. It is not expected that this occupant group would be present in the building at the time of fire ignition; however, they are expected to enter the building at a later stage to assist with the evacuation of occupants, if required, and to undertake fire suppression activities.

4.4 OCCUPANT FAMILIARITY

- **Taronga Conservation Society Australia Staff and Security** can be expected to have a good familiarity with the building and the fire safety systems provided and may be trained in emergency procedures; and
- **Visitors and Short-term Residents** may or may not be familiar with the layout of the building and may require assistance in locating the exits; and
- **External Maintenance Contractors** are expected to have a reasonable familiarity with the building as they would have to undergo site specific induction prior to commencement of work on site; and
- **FRNSW** are not expected to have any familiarity of the building layout, however are assumed to obtain the required information from the site block plans and tactical fire plans available prior to entering the building. Notwithstanding this they will be equipped with breathing apparatus and specialist equipment to prevent them from being adversely affected by fire hazards.

4.5 EMERGENCY TRAINING

Occupants should be familiar with escape procedures through fire drills and designated fire wardens being appointed to mitigate risks under Workplace Health and Safety legislation (AS 3745:2010). Clear escape routes should be maintained with doors unlocked, and no obstructions or rubbish to hinder evacuation.

Staff and visitors are not expected to have fire suppression training and such training is not relied upon for this building population; however staff are expected to possibly attempt to extinguish a fire or limit fire spread by removing objects in the vicinity of the fire in order to defend their belongings.

5 FIRE BRIGADE CHARACTERISTICS

5.1 OVERVIEW



The fire brigade characteristics are assessed within the Fire Engineering Report due to the fact that Fire Brigade characteristics can dictate the time required for fire brigade intervention including search and rescue and fire attack.

5.2 FIRE BRIGADE ACCESS

Taronga Zoo is located within the Fire and Rescue New South Wales (FRNSW) jurisdictional turnout area. The closest two fire stations to the site that are provided with permanent staff are located in Neutral Bay and Mosman, which are located approximately 3.5km and 2.0km away from Taronga Zoo and shown in Figures 5-1 and 5-2 below.




Figure 5-1: Neutral Bay Fire Station Location

Source: www.googlemaps.com.au

On the basis of the site’s major use being that of a zoological facility, it is anticipated that any fire, rescue or emergency medical related response to Taronga Zoo will be based on a predetermine plan, which FRNSW fire fighters from Mosman and Neutral Bay are considered to be reasonably familiar with.




Figure 5-2: Mosman Fire Station Location

Source: www.googlemaps.com.au

5.3 FIRE FIGHTING EQUIPMENT

The fire fighting equipment that is to be provided to facilitate a FRNSW response at the site includes:-

- External and internal fire hydrants and booster connections;
- Sprinkler system booster connections;
- Monitored sprinkler system and fire alarm system;
- Fire indicator panel; and
- SSISEP panel that is provided with red manual call points.

6 FIRE HAZARDS AND PROTECTIVE MEASURES

6.1 OVERVIEW



The fire hazard analysis forms the basis for the review of non-compliances within the building. In assessing expected and statistically validated hazards, preventative and protective measures are developed commensurate with those expected risks. The following section reviews applicable hazards and recommends possible measures to address those risks. Furthermore, hazards identified can form a justified basis for selected scenarios.

6.2 FIRE STATISTICS

In order to assess the most likely fire hazards within the building, and subsequently the risk presented by these hazards it is necessary to develop an understanding of the factors that have an influence on the fire safety of building occupants. The best method in doing so is to review existing statistical data.

Existing data is an invaluable tool in providing an overview of the situations in which occupant deaths have, and are likely to occur, and factors that contribute to more severe fires. This aids in understanding, and helps evaluate the effectiveness of, and the need for various fire safety systems. Reference is made to the American database as it is significantly larger than Australian data sets, but is generally considered to be representative of the Australian situation.

Table 6-1: Fire Statistics in all Building Types [5]

STRUCTURE USE	FIRES PER YEAR	CIVILIAN FATALITIES PER YEAR	CIVILIAN FATALITIES PER 1000 FIRES
Hospitals	1,288	0	0
Schools	4,060	0	0
Public assembly	14,650	5	0.34
Retail/Department Store	1,150	1	0.87
Eating and Drinking Establishments	7,480	3	0.40
Business offices	2,890	3	1.04
Manufacturing	5,303	7	1.32
Vehicle Storage/Garage	6,200	10	1.61
24-hour nursing homes	2,749	5	1.82
Hotels or motels	3,610	11	3.05
Warehouse	1,270	4	3.15
Apartments	106,380	410	3.85
Homes	260,180	2165	8.32

From the NFPA 'Structure Fires by Occupancy 2007-2011' Report [5], The civilian fatality rates from 2007 to 2011 highlighted in Table 6-1 show that hotels and motels have a medium risk to life compared to other property types with 3.05 civilian deaths per 1000 fires on average. Fires in Eating and Drinking Establishments represent a lower risk to life compared to other property type, with 0.40 civilian deaths per 1000 fires. Hotel and motels fires indicates a much greater risk per fire than other non-residential occupancies; however, this is balanced by the relatively low number of fires that occur.

6.2.1 Hotel facility fire statistics

As can be seen in Table 6-1, hotel and motel buildings present a significant threat to life compared to other occupancy types. This is in large part because, unlike in many other buildings, people are regularly asleep and not able to immediately respond to fire threats.

Statistics taken from the NFPA report “U.S. Hotel and Motel Structure Fires” by Evarts [28] allow an analysis of the peak times that fires occur, death rates, the cause of fires and their area of origin and the extent of fire spread, based on data from 2006-2010.

During 2006-2010 an estimated annual average of 3,700 structure fires were reported at hotel and motel properties. These fires caused an average annual of 12 civilian fatalities and 143 civilian injuries.

Alarm time:

Figure 6-1 presents the percentage of fires by time of alarm. Fires in hotel and motel structures are more common during the evening hours between 18:00 and 21:00 due to the prevalence of confined cooking fires.




Figure 6-1: Fires by alarm time for hotels and motels [28]

Causes of fires:

Figure 6-2 presents the leading cause of fire in hotels and motels and illustrates that cooking equipment (45% of fires) is the most probable cause of fires in these properties as it leads to significantly more fires than other causes. Relatively few fires started by cooking equipment lead to fatalities, most likely due to their function; occupants are generally awake and reasonably alert to fire when cooking. Smoking materials (causing 10% of fires) lead to a disproportionately large number of deaths, most likely because of the very slow initial growth rate of fires started by cigarette butts. This allows the fire to grow for a significant amount of time before detection would occur, often when people are asleep, further delaying response to a fire incident.




Figure 6-2: Leading causes of hotel and motel fires and their associated fatality rates [28]

Areas of fire origin:

Figure 6-3 presents the area of origin of fires in hotels and motels, and confirms the data concerning leading causes. The most probable area of origin for these properties is a kitchen or cooking area (36%). A significant number of fires begin in the kitchen, as would be expected with the rate of fires caused by cooking equipment; however the high death rates from smoking materials can also be seen in the high death rates from fires originating in bedrooms (72%) since this is an area where hotel and motel occupants will spend significantly more time, and hence are more likely smoke in. Bedroom fires can also present a significant threat to life because an occupant will be asleep, and can be overcome by conditions without ever waking up.




Figure 6-3: Areas of origin of hotel and motel fires and their associated fatality rates [28]

Extent of fire spread:

Figure 6-4 presents data on the extent of fire spread for hotels and motels. Nearly three-quarters (73%) of hotel and motel fires were confined to the object of origin, and 91% were confined to the room of origin.

It should be noted that the probability of whether a fire spreads beyond the room of origin is considered approximately equivalent to the occurrence of that fire reaching flashover [28]. This is based upon the reasonable assumption that if automatic or human/manual fire suppression was to occur to control fire growth, that this is likely to only be effective if it is carried out prior to a fire spreading beyond the room of origin - due to high risk to life safety in the room of origin and the fact that if a fire has spread from a room, it has most likely fully involved the room of origin.




Figure 6-4: Extent of fire spread for hotels and motels [28]

6.2.2 Eating Establishment fire statistics

As shown in the Table 6-1, during 2007-2011 the estimated annual average of structure fires in eating and drinking establishments were reported to be 7,480. These fires caused average annual losses of 3 civilian fatalities.

Statistics taken from the NFPA report “Structure Fires in Eating and Drinking Establishments” by Evarts [30] allow an analysis of the peak times that fires occur, death rates, the cause of fires and their area of origin and the extent of fire spread, based on data from 2006-2010.

Fires by time of day:

Figure 6-5 presents the percentage of fires that occur at various intervals in a 24-hour period. The figure illustrates that fires are less common during the overnight hours between 00:00 and 06:00 but are relatively common throughout the day.




Figure 6-5: Fires by time of day for eating establishments [30]

Causes of fires:

As Figure 6-6 presents the leading cause of fires in eating and drinking establishments. The figure clearly illustrates that the most probable cause of fire is cooking equipment, accounting for 57% of fires. Heating equipment is the second most probable cause, accounting for 10% of fires.




Figure 6-6: Leading causes of fires in eating establishments [30]

Areas of fire origin:

Figure 6-7 presents data on the area of origin of fires in eating and drinking establishments. The most probable area of origin is a kitchen or cooking area (56%). This is unsurprising given the prevalence of cooking fires in these properties.




Figure 6-7: Leading areas of origin for fires in eating establishments [30]

Extent of fire spread:

Figure 6-8 presents data on the extent of fire spread for eating and drinking establishments. Seven out of ten (71%) of fires in these properties stay relatively small, and do not spread beyond the object of origin. It should be noted that the probability of whether a fire spreads beyond the room of origin is considered approximately equivalent to the occurrence of that fire reaching flashover [29]. This is based upon the reasonable assumption that if automatic or human/manual fire suppression was to occur to control fire growth, that this is likely to only be effective if it is carried out prior to a fire spreading beyond the room of origin - due to high risk to life safety in the room of origin and the fact that if a fire has spread from a room, it has most likely fully involved the room of origin.




Figure 6-8: Extent of fire spread for eating establishments [30]

6.3 SPRINKLER EFFECTIVENESS & RELIABILITY

The effectiveness of automatic fire sprinklers in general in limiting fire spread and growth is supported by statistics and studies undertaken into the effects of automatic fire sprinklers within buildings. These studies show that fire sprinkler systems operate and control fires in 81% to 99.5% of fire occurrences [3]. The lower reliability estimates of 81.3% [19] as well as some of the higher values of 87.6% [20] appear to reflect significant bias in data in terms of the small number of fire incidents and the lack of differentiation between fire sprinklers and other fire suppression systems. A number of the lower figures are results of dated studies.

It must be noted that the higher reliability of fire sprinklers reported by Marrayatt [22] of 99.5% reflect fire sprinkler systems where inspections, testing and maintenance exceeded normal expectations and applies to installations specifically in Australia and New Zealand. The statistical data indicate that sprinklers with appropriate maintenance are highly effective in reducing the loss of life and limiting fire spread and in particular the storage (ESFR) system has an exemplary record.

With reference to FM Global data sheet (2-2) as of 2002 [17] there had been six known fires involving suppression mode sprinkler protection.

In all of these incidents, the sprinkler system was successful in suppressing the fire and no more than four sprinkler heads operated. Therefore for the purposes of this assessment, on the activation of the ESFR fire sprinkler system, the fire growth is considered to be suppressed within the area of activation.

FM Global Data Sheet 2-0 states, “loss history over the past twenty years indicates approximately 25% of the time, the operation of a single sprinkler will control or suppress a fire if the sprinkler system has been properly designed and installed.” This percentage increases to approximately 50% of the time with the operation of 3 or fewer sprinklers, and 75% of the time with the operation of nine or fewer sprinklers.

In addition analysis of the likelihood of sprinkler failure shows that most sprinkler system failures are due to impaired water supplies such as closed valves, blocked pipes, impaired sources, etc., which tend to affect sections of or the entire system [20]. As such, system reliability can be increased by active monitoring of water supplies and controls. The general consensus within the fire protection industry is that problems with individual sprinkler heads are rare. This information combined with sprinkler reliability data is favourable when compared with the reliability of fire compartmentation [3].

Moinuddin and Thomas [20] have found that masonry fire rated construction had a reliability of 81-95%, and gypsum 69-95%, with the upper level in both instances having been reported within the IFEG [3]. Both reported ranges are considered to be less than that offered by automatic sprinkler systems. Table 6-2 lists the effectiveness of sprinkler systems in the event of a fire growing to a size that facilitates sprinkler head activation [20].

Table 6-2: Effectiveness of Sprinkler systems

PROPERTY TYPE	EFFECTIVENESS OF SPRINKLERS IN EVENTS WHERE SPRINKLERS OPERATE
Public Assembly	90%
Educational	93%
Health care / Correctional Centre	95%
Residential (average)	97%
Office / Retail	91%
Manufacturing	93%
Storage	86%
Cold Storage	89%

6.4 FIRE LOAD

The fire load within a room or compartment will influence the duration and severity of a fire and resultant hazard to occupants. The effective fire load for the building has been estimated by consideration of the typical spaces within the building.

The following fire loads have been extracted from Chapter 3.4 of the International Fire Engineering Guidelines [3] and are listed in Table 6-3. This data is derived from Switzerland, however is also deemed applicable to buildings in Australia of similar use.

Table 6-3: Fire Load Densities

OCCUPANCY	MEAN	PERCENT FRACTILE		
		80	90	95
Hotel bedroom	310 MJ/m ²	400 MJ/m ²	460 MJ/m ²	510 MJ/m ²
Retail	600 MJ/m ²	900 MJ/m ²	1100 MJ/m ²	1300 MJ/m ²

6.5 FIRE GROWTH RATE AND INTENSITY

As the fire increases in size, the rate of fire growth accelerates. The growth rate of a fire can result in various hazards for occupants due to the following:

- Protective and preventative measures may not be adequate.
- Occupants may have insufficient time to evacuate.
- Occupants may perceive a reduced threat from slow growing fires.

The rate of fire growth is generally expressed in terms of an energy release rate. The most commonly used relationship is what is commonly referred to as a quadratic time-squared fire. The basis of the time squared fire arises from the fact that the growth during the flaming stage can be approximated by a smooth curve that can be expressed mathematically. The rate of heat release is given by the expression:

$$Q = (t/k)^2$$

Where: t = time from after ignition of the fire (seconds)
 K = the growth time (seconds)
 Q = a heat release output of 1.055 MW.

Studies of actual fires have led to the adoption of five (5) standard fire growth rates covering a wide range of potential fire scenarios and fuel loads. It should be noted, the times of fire incubation are not included in the time-squared growth fire models. National Fire Protection Association Standard NFPA 92B [20] provides information on the relevance of time-squared approximation to real fire as depicted in the figure below.




Figure 6-9: NFPA 92B: T-squared fire, rates of energy release




Figure 6-10: NFPA 92B: Relation of t-squared fires to some fire tests

The rate of fire growth can also be estimated from data published in British Standard (BS) 9999:2008 [4] as shown below in Table 6-4.

Table 6-4: Summary of Fire Growth Rates per Building Type

BUILDING AREA PROVIDING FUEL	GROWTH RATE	BUILDING AREA PROVIDING FUEL	GROWTH RATE
Shop	Fast	Hotel room	Medium

From the above tables it is concluded that the likely fire scenarios may be approximated by a medium standard time-squared fire growth rate curve.

6.6 FIRE HAZARDS

Subsequent to a review of the relevant fire statistics and hazards presented in Section 6.2, the fire hazards are specific to this building are summarised below.

6.6.1 General Layout

The building comprises of five residential pods, where pods are connected to each other and the existing parts of the building and proposed restaurant by an open passageway. Each pod is provided with an external stair, whereby access to a road and open space is provided at the topmost level due to the topography of the site.

6.6.2 Activities

It is not expected that regular hot work processes, use of highly flammable materials, manufacturing processes or operation of high friction or high temperature machinery will be performed within the building. However there are restaurants and other kitchen areas within the building which will have cooking equipment and other ignition sources.

6.6.3 Ignition Sources

Based on the statistical review contained in Section 6.2 ignition sources relevant to this site, in order of occurrence:

Hotel:

- Cooking equipment (45%)
- Smoking materials (10%)
- Heating equipment (9%)
- Clothes dryer or washer (9%)
- Intentional (8%)
- Electrical distribution (6%)

- Candles (2%)

Retail:

- Cooking equipment (19%)
- Electrical / lighting equipment (12%)
- Heating equipment (11%)
- Intentional (11%)
- Clothes dryer or washer (9%)
- Smoking materials (9%)
- Exposure to other fire (5%)

6.6.4 Fuel Sources

Quantity of Materials

- Hotel bedroom – Mean fuel load of 310MJ/m². 90% fractile fuel load 460MJ/m².
- Retail - Mean fuel load of 600MJ/m². 90% fractile fuel load 1100MJ/m².

Fire Behaviour

Fire growth rates will vary with fuel type and conditions of ventilation and compartmentation. The most likely outcome of any fire outbreak within the building is a sprinkler controlled fire. This would be expected to grow at a medium time-squared fire growth rate until sprinkler activation in the hotel areas, at which point the sprinklers are expected to suppress or control the fire. A fast t^2 fire growth rate is expected in the retail areas.

6.7 PREVENTATIVE AND PROTECTIVE MEASURES

6.7.1 Fire Initiation and Development and Control (Sub-System A)

To minimise the risk of fires initiating and growing to a size which may impact on building occupants, fire safety systems are provided within the building as listed in the following sections.

6.7.2 Smoke Development and Spread and Control (Sub-System B)

It is recognised that smoke is one of the most serious threats to life safety in the event of a fire, in this instance, the passageways are open and smoke may dissipate to the atmosphere.

6.7.3 Fire Spread and Impact and Control (Sub-System C)

To limit the extent and impact of fire spread through the buildings, the following are implemented in the building.

- Type A construction throughout.
- Combination of lightweight and Cross Laminated Timber (CLT) construction to the accommodation pods.
- Sprinkler systems documented in Sub System D
- The use of building materials, wall cladding, roofing and glazing systems that comply with the AS3959 construction requirements for BAL 29 and 40 exposures.

6.7.4 Fire Detection, Warning and Suppression (Sub-System D)

The following active systems provided within the buildings to facilitate occupant warning and suppress a potential fire.

- Smoke alarms within the residential accommodation units
- Occupant Warning System
- Sprinkler system
- Fire Hose Reels
- Fire Extinguishers

6.7.5 Occupant Evacuation and Control (Sub-System E)

The building is provided with the following systems to assist in the evacuation of occupants:

- Emergency Lighting
- Exit Signage

6.7.6 Fire Services Intervention (Sub-System F)

The building is provided with the following systems to assist in fire brigade intervention:

- Fire Hydrants
- Fire hose reels
- Automatic fire sprinkler system
- Automatic link to Fire Brigade

7 BCA DTS NON-COMPLIANCE ASSESSMENT

7.1 OVERVIEW



In this instance the BCA DTS non-compliances have been formulated based on the regulatory review as provided by the principal certifying authority. Where not listed herein the building is required to achieve compliance with relevant DTS provisions or if existing, comply with relevant codes, reports and / or Standards approved at the time of consideration.

The following table lists the departures from the DTS provisions of the BCA for the proposed building and the analysis methodology proposed for the Fire Engineering assessment, which is to be generally in accordance with the IFEG [3].

7.2 BCA DTS NON-COMPLIANCE ASSESSMENT

Table 7-1: Summary of Alternative Solutions

BCA DTS PROVISIONS & PERFORMANCE REQUIREMENT	PERFORMANCE BASED SOLUTION
<p>BCA DTS Provisions</p> <p>Specification C1.1</p> <p>Performance Requirement(s) CP1 and CP2</p>	<p>BCA DTS Provision <u>Clause C1.1</u> requires the Class 3 parts to be of Type A construction. Whereby Type A construction requires building elements to be constructed of non-combustible and concrete masonry construction. <u>Specification C1.1</u> requires that the floors to the Class 3 parts to have an FRL of 90/90/90.</p> <p>DTS Non-conformance The Accommodation Pods (Class 3 parts) are proposed to comprise of a combination of lightweight and CLT construction in lieu of non-combustible and concrete masonry construction. However, the walkway connecting the accommodation pods and the exit stairs are to be constructed of non-combustible and concrete masonry construction. The structural steel elements supporting the concrete walkways are proposed to be exposed. A method of fire-protection shall be provided to the structural steel supporting the walkways (e.g. intumescent paint). The fire-rating to all building elements shall be in accordance with Type A construction.</p> <p>Alternative Solution The Alternative Solution will rely upon the provision of the sprinkler system in accordance with AS 2118.1-1999 throughout the building.</p> <p>Assessment Methodology The assessment methodology will adhere to Clauses A0.5(b)(i) and A0.9(b)(ii) of the BCA. The analysis will be absolute and utilise a combination of qualitative and quantitative methods, which will be measured directly against the agreed acceptance criteria.</p>

BCA DTS PROVISIONS & PERFORMANCE REQUIREMENT	PERFORMANCE BASED SOLUTION
<p>BCA DTS Provisions</p> <p>Clause D1.3</p> <p>Performance Requirement(s) DP5 and EP2.2</p>	<p>BCA DTS Provision Clause D1.3 requires stairs that connect more than three (3) storeys in a sprinkler protected Class 3 building to be fire isolated.</p> <p>DTS Non-conformance The Southern Fire Isolated Stair is not fire isolated and it connects up to 5 storeys.</p> <p>Alternative Solution The Alternative Solution will rely upon the use of relatively open egress routes to demonstrate that occupants will not be exposed to untenable conditions resulting from a fire occurring within an adjoining accommodation room (SOU).</p> <p>Assessment Methodology The assessment methodology will adhere to Clauses A0.5(b)(i) and A0.9(b)(ii) of the BCA. The analysis will be absolute and utilise a combination of qualitative and quantitative methods, which will be measured directly against the agreed acceptance criteria.</p>
<p>BCA DTS Provisions</p> <p>Clause D1.4: Distance to the nearest exit. Clause D1.5: Distance between alternative exits.</p> <p>Performance Requirement(s) DP4 and EP2.2</p>	<p>BCA DTS Provision Clause D1.4 travel distance to a single exit must not exceed 6 metres from the SOU doorway; Clause D1.4 travel distance to a single exit must not exceed 20 metres from areas not within an SOU; and Clause D1.4 the distance between alternative exits must not exceed 45m.</p> <p>DTS Non-conformances The following areas exceed the maximum allowable travel distance:- Accommodation:</p> <ul style="list-style-type: none"> ■ Level A – Travel distance from entrance doorway of SOU is up to 15m in lieu of 6m to a single exit (as shown in Figure 7-1); ■ Levels B, C, D – Travel distance from entrance doorway of SOU is up to 14m in lieu of 6m to a single exit (as shown in Figure 7-2, Figure 7-3 and Figure 7-4). <p>Commercial:</p> <ul style="list-style-type: none"> ■ Level D, E – Distance between alternative exits is up to 78m in lieu of 45m (as shown in Figure 7-4 and Figure 7-5). <p>Alternative Solution The Alternative Solution will rely upon the use of relatively open egress routes to demonstrate that occupants will not be exposed to untenable conditions resulting from a fire within an accommodation room (SOU).</p> <p>Assessment Methodology The assessment methodology will adhere to Clauses A0.5(b)(i) and A0.9(b)(ii) of the BCA. The analysis will be absolute and utilise a combination of qualitative and quantitative methods, which will be measured directly against the agreed acceptance criteria.</p>

BCA DTS PROVISIONS & PERFORMANCE REQUIREMENT	PERFORMANCE BASED SOLUTION
<p>BCA DTS Provisions</p> <p>Clause D1.7</p> <p>Performance Requirement(s) DP5 and EP2.2</p>	<p>BCA DTS Provision Clause D1.7 prohibits a doorway from a room opening directly into a stairway, passageway or ramp that is required to be fire-isolated.</p> <p>DTS Non-conformance The commercial kitchen on Level E opens directly onto the existing fire isolated staircase of the Taronga Centre.</p> <p>Alternative Solution A new dual leaf exit door will be constructed within 6m of the subject door serving the existing fire isolated stair case that will provide direct egress to the outside. Additionally, the existing door will not be identified as an exit.</p> <p>Assessment Methodology The assessment methodology will adhere to Clauses A0.5(b)(i) and A0.9(b)(ii) of the BCA. The analysis will be absolute and qualitative in nature, and will be measured directly against the expectations of Performance Requirement DP5.</p>
<p>BCA DTS Provisions</p> <p>Clause D1.8 (c): Protection of openings</p> <p>Performance Requirement(s) CP2 and DP5</p>	<p>BCA DTS Provision Clause D1.8 (c) requires openings within 6m of an external stair to be protected Clause C3.4 of the BCA.</p> <p>DTS Non-conformance Existing openings within the wall of the Taronga Centre are within 4m of the stair serving Level D – Level 1 in the Wildlife Retreat.</p> <p>Alternative Solution The acceptance of the above non-conformances is based on the following fire safety systems/measures provided.</p> <ul style="list-style-type: none"> ■ The specification and use of construction materials and methods that are able to withstand radiation heat fluxes of 29 kW/m². This level of radiation heat flux is also consistent with the BAL rating requirements that the building is required to comply with for the purpose of complying with Part G5 of the BCA; ■ The window openings of the subject residential accommodation building will not cause heat flux in excess of 29 kW/m²; and ■ The provision of on-site external fire hydrants that have both feed and attack performance and a sealed accessible footpath, which fire fighters can utilise to protect exposures between the proposed building (Wildlife Retreat) and the existing building (Taronga Centre). <p>Assessment Methodology The assessment methodology follows Clauses A0.5(b)(i) and A0.9(b)(ii) of the BCA. The risk of fire spread to the stair, from the nearest adjoining residential accommodation unit (SOU) will be examined using a quantitative and qualitative approach to demonstrate that occupant and fire fighter tenability criteria are not breached.</p>

BCA DTS PROVISIONS & PERFORMANCE REQUIREMENT	PERFORMANCE BASED SOLUTION
<p>BCA DTS Provisions</p> <p>Clause D2.4: Separation of rising and descending stairs</p> <p>Performance Requirement(s) DP4</p>	<p>BCA DTS Provision</p> <p>Clause D2.4: If a stairway serving as an exit is required to be fire-isolated, there must be no direct connection between a flight rising from a storey below the lowest level of access to a road or open space and a flight descending from a storey above that level.</p> <p>DTS Non-conformance</p> <p>Access to a road and open space is achieved from level E, being the top most level. Being a significantly sloping site, the occupants will be required to travel in an upward direction in order to evacuate the building.</p> <p>Alternative Solution</p> <p>The acceptance of the above non-conformances is based on the following fire safety systems/measures provided.</p> <ul style="list-style-type: none"> ■ Illuminated exit signage and additional evacuation information and signage within the stair at each level. ■ Open stairway. <p>Assessment Methodology</p> <p>The assessment methodology follows Clauses A0.5(b)(i), A0.9(b)(ii) and A0.10 of the BCA. A qualitative assessment shall be conducted including discussions on the provided signage within the stair indicating the level of discharge, the occupant characteristics and level indicators on each level. In addition, the signage, the stairway will be open, allowing for smoke ventilation, therefore occupants will not travel in the direction of smoke.</p>




Figure 7-1: Extended distance of travel on Level A




Figure 7-2: Extended distances of travel on Level B




Figure 7-3: Extended distances of travel on Level C




Figure 7-4: Extended distances of travel to an exit and between exits on Level D




Figure 7-5: Extended distances of travel between exits on Level E

8 PROPOSED FIRE SAFETY STRATEGY

8.1 OVERVIEW



The fire safety strategy outlined below has been proposed to satisfy the fire and life safety objectives specified for this project by the relevant stakeholders. In addition, the fire safety strategy is required to adequately address the specific fire and life safety hazards identified for the proposed development, and as such have been generally derived from the preventative and protective measures outlined within the BCA, and fire engineering literature and research. Where items of non-compliance have not been identified by the design team in the concept design it is considered that those items are expected to be deemed-to-satisfy solutions.

This Section provides guidance for the design and application of fire safety measures. It highlights specific design considerations for a range of fire safety measures that will undergo analysis as part of the Fire Engineering Report to ascertain whether the relevant Performance Requirements of the BCA are satisfied. Design guidance (general informative details and specific requirements) for a range of specific fire safety measures is provided. This list is not exhaustive and the use of other fire safety measures including new technologies will require additional review.

8.2 EGRESS PROVISIONS

8.2.1 Evacuation Strategy – Residential Accommodation Buildings

The activation of any sprinkler heads and smoke detection in the residential accommodation buildings shall initiate the operation of the occupant warning system and therefore the evacuation of all residential accommodation buildings. TCSA staff, who are trained as fire wardens, shall ensure that all residential guests are promptly evacuated.

8.2.2 Evacuation Strategy – Restaurant Building

The activation of any sprinkler heads and smoke detection within the restaurant building shall initiate the operation of the occupant warning system and therefore the evacuation of all guests and staff within this area. Restaurant staff, who have undertaken emergency evacuation training, shall ensure that commercial kitchen and dining areas of the restaurant have been evacuated.

8.2.3 Door Hardware, Operation and Mechanisms

All exit doors and doors in a path of travel to an exit are required to be DTS compliant throughout the building. This includes the swing of doors, the applied latching and locking mechanisms and the force required on mechanism used to open sliding doors.

8.2.4 Signage and Lighting

Emergency lighting is to be provided throughout the building in accordance with DTS Provisions E4.2 and E4.4 of the BCA 2015 and AS2293.1:2005.

Exit signage is to be provided throughout the building in accordance with the DTS Provisions E4.5, E4.6, E4.8 of the BCA 2015 and AS2293.1:2005.

Noting that as part of the proposed Alternative Solution, the exit sign to the fire isolated stair from the kitchen on level E is to be removed.

Additional informative signage and level indicators shall be provided at each level in a visually prominent position from within the stair and on route to the stair.

The signage shall state:

- “EXIT AT LEVEL E” on levels A, B, C and D;
- “EXIT AT THIS LEVEL” on level E.

The text shall be in capitals, no less than 20mm high and in a colour contrasting to the background.

Level indicators shall be provided at each level, the text shall be no less than 50mm high, in a colour contrasting to the background.

8.3 PASSIVE FIRE PROTECTION

8.3.1 Type of Construction Required

The building shall be built in accordance with the BCA DTS provisions for Type A fire-resisting construction with the exception that the Class 3 accommodation pods are proposed to be constructed of a combination of lightweight and CLT materials in lieu of concrete masonry construction.

The walkways connecting the accommodation pods and the exit stairs shall comprise of compliant Type A construction. The structural steel elements supporting the concrete walkways are proposed to be exposed. A method of fire-protection shall be provided to the structural steel supporting the concrete walkways (e.g. intumescent paint).

Additionally, the specification and use of building materials, wall cladding, roofing and glazing systems must comply with AS3959 construction requirements for BAL 29 and 40 exposures.

8.4 ACTIVE FIRE PROTECTION SYSTEMS

8.4.1 Building Occupant Warning System

A building occupant warning system shall be provided throughout all parts of the building. The system shall be in accordance with the prescriptive requirements of Specification E1.5 and Clause 6 of Specification E2.2a of the BCA 2015 and AS1670.1:2004.

- The occupant warning alarm shall be sounded throughout all areas of the building upon fire detection by the smoke detection or sprinkler systems.

8.4.2 Smoke Detection System

An Automatic Smoke Detection and Alarm System shall be provided throughout the building in accordance with BCA Specification E2.2a and AS 1670.1-2004.

8.4.3 Fire Sprinkler System

Sprinkler protection shall be provided throughout the building in accordance with AS 2118.1-1999. The building occupant warning system shall be activated on fire detection in accordance with Specification E1.5 of the BCA.

8.5 FIRST AID FIRE FIGHTING

8.5.1 Fire Hose Reels

Fire hose reel shall be provided throughout the building in accordance with Clause E1.4 of the BCA and AS2441:2005.

Locations should be signposted and readily accessible to occupants. Use of facilities should be monitored for abuse, mistreatment and servicing. The fire hose reels shall be located within 4m of an exit and provide coverage to all areas of the building based on a 36m hose length with a 4m water stream (i.e. maximum 40m coverage from the hose location).

8.5.2 Portable Fire Fighting Equipment

Portable fire extinguishers are to be provided throughout the building in accordance with Table E1.6 of the BCA and selected, located, and distributed in accordance with AS2444:2001. As a guidance:

■ General office areas	Dry Powder (ABE type)	2.5Kg
■ Computer/server rooms	CO ₂	3.5 Kg
■ Plant rooms	Dry Powder (ABE)	2.5 Kg
■ Designated exits	Dry Powder (ABE)	4.5 Kg
■ Adjacent each fire hose reel cabinet	Dry Powder (ABE)	4.5 Kg

8.6 FIRE BRIGADE INTERVENTION

8.6.1 Fire Indicator Panels

The residential accommodation buildings shall be served by a Sub-Fire Indicator Panel (FIP) that is interfaced to operate with the Taronga Zoo's main fire indicator panel. The specific location of the Sub-FIP shall be determined in consultation with NSWFR.

The Sub-FIP must be installed in accordance with BCA Specification E2.2a and AS1670.1:2004 and have the following capabilities.

- The Sub-FIP panel must be capable of isolating, resetting, and determining the fire location within the residential accommodation buildings.
- A red strobe shall be installed at the highest level of approach to every residential accommodation building to provide a visual indication of the origin of alarm (sprinkler activation).

The sprinkler system serving the class 6 restaurant shall be interfaced to the Sub-FIP or main FIP that serves the Taronga Centre building.

8.6.2 Fire Hydrants

The fire hydrant system shall be provided in accordance with BCA Clause E1.3 and AS2419.1:2005.

8.7 BUILDING MANAGEMENT PROCEDURES

The ongoing management of the building is as important in maintaining a high level of life safety as the provisions recommended during the design phase of the building.

8.7.1 Maintenance of Fire Safety Equipment

The fire detection systems, fire sprinkler systems, emergency warning systems, fire hydrants, hose reels, portable fire extinguishers, emergency lighting and any other fire safety equipment shall be tested and maintained in accordance with Australian Standard AS1851 or other relevant testing regulatory.

The smoke clearance system shall be tested in accordance with the AS1851 requirements for an automatic smoke clearance system as applicable.

8.7.2 Evacuation Plan

A specific evacuation plan should be developed for the site in accordance with AS3745:2010 that takes into consideration fire risks associated with a fire originating within the residential accommodation units.

The existing Taronga Centre's evacuation plan shall be modified to encompass the new restaurant facility that will adjoin it.

The provision of fire orders that are consistent with the requirements of Clause G4.9 of the BCA are to be displayed next to entry door to every residential accommodation unit.

9 REFERENCES

1. ABCB, “Building Code of Australia, Volume One”, CanPrint Communications, Canberra 2015.
2. ABCB, “Guide to the BCA 2014”, CanPrint Communications, Canberra 2015.
3. ABCB, “International Fire Engineering Guidelines”, ABCB, Canberra, 2005.
4. BS 9999: Code of practice for fire safety in the design, management and use of buildings, October 2008.
5. Campbell, R., “Structure Fires in U.S. Warehouses”, National Fire Protection Association, Quincy MA, June 2013.
6. Campbell, R., “U.S. Structure Fire in Office Properties”, National Fire Protection Association, Quincy MA, August 2013.
7. Fire Analysis Research Division, “Structure Fires by Occupancy, 2007-2011 – Annual Averages”, National Fire Protection Association, Quincy MA, April 2013.
8. Society of Fire Protection Engineers “Engineering Guide to Human Behaviour in Fire”, Review Draft August 2002, The SFPE Engineering Guide to Human Behaviour in Fire, June 2002.
9. Society of Fire Protection Engineers, ‘Handbook of Fire Protection Engineers’, 3rd Edition, 2002.
10. National Fire Protection Association, ‘Fire Protection Handbook’, 19th edition, Volumes I and II, 2003.
11. Technical Report FCRC-TR 96-02: Building Fire Scenarios – An analysis of Fire Incident Statistics, Fire Code Reform Research Program, March 1996
12. PD 7974-6:2004., “Human factors: Life safety strategies – Occupant evacuation, behaviour and condition (Sub-system 6)”, British Standard, 1 July 2004.
13. The Chartered Institute of Building Services Engineers, ‘CIBSE Guide E, “Fire engineering’, 2nd Edition, September 2003.
14. “Fire Brigade Intervention Model V2.2”, Australasian Fire Authorities Council, October 2004.
15. Fire & Rescue NSW, “Annual report 2011/12 – Gearing up for the Future”, 29 October 2012
16. National Fire Protection Association Standard NFPA 92B, “Smoke Management Systems in Malls, Atria, and Large Areas”, 2000.
17. FM Global Data Sheet 2-0, Installation Guidelines for Automatic Sprinklers, March 2010.
18. FM Global Data Sheet 8-9, Storage of Class 1, 2, 3, 4 and Plastic Commodities, September 2010.
19. McGrattan, Kevin. “Sprinkler, Smoke & Heat Vent, Draft Curtain Interaction – Large Scale Experiments and Model Development” NISTIR 6196-1, National Institute of Standards and Technology, United States Department of Commerce, Gaithersburg Maryland, September 1998.
20. Technical Standard, “NFPA 92B: Standard for Smoke Management Systems in Malls, Atria and Large Spaces”, National Fire Protection Association (NFPA), 2009.
21. Technical Report FCRC-TR 96-02: Building Fire Scenarios – An analysis of Fire Incident Statistics, Fire Code Reform Research Program, March 1996
22. Marryatt, H.W., “Fire: A Century of Automatic Sprinkler Protection in Australia and New Zealand 1886-1986”, Australian Fire Protection Association, Melbourne, Australia, 1988.
23. Rohr, KD 2003, “US Experience with Sprinklers”, National Fire Protection Association, Quincy, MA.
24. Technical Report FCRC-TR 96-02: Building Fire Scenarios – An analysis of Fire Incident Statistics, Fire Code Reform Research Program, March 1996
25. Flynn, Jennifer, “U.S. Structure Fires in Eating and Drinking Properties”, National Fire Protection Association, Quincy Massachusetts, February 2007.
26. Marty Ahrens, (2001) “U.S. Fire Problem Overview Report”, NFPA, Quincy, MA.

27. Fire Analysis Research Division, 'Structure Fires by Occupancy' 2007-2011 – Annual Averages', National Fire Protection Association, Quincy MA, April 2013.
28. Evarts. B., "U.S. Hotel and Motel Structure Fires", National Fire Protection Association, Quincy MA, July 2012
29. England, J., "Guide for the design of fire resistance barriers and structures", Building Control Commission, Australia, 2000.
30. Evarts, B., "Structure Fires in Eating and Drinking Establishments", National Fire Protection Association, Quincy MA, November 2012.