



File Ref. No: FRN25/356 BFS25/349 8000040373
TRIM Doc. No: D25/6541
Contact: Senior Firefighter Michael Millar

24 January 2025

LAUREN CLEAR
NSW Department of Planning, Housing and Infrastructure
Locked Bag 5022
PARRAMATTA NSW 2124

Dear Lauren,

Re: Advice on Secretary's Environmental Assessment Requirements (SEARs) – BEN BULLEN WIND FARM – 25 KM NORTH-WEST OF LITHGOW (SSD-79294216).

Fire and Rescue NSW (FRNSW) acknowledge correspondence received on 16 January 2025, requesting input into the preparation of the SEARs for the BEN BULLEN WIND FARM – 25 KM NORTH-WEST OF LITHGOW (SSD-79294216). FRNSW have reviewed the SEARs along with the Scoping Report with particular focus to Section 6.3.6 Hazards and Risk.


The Scoping Report details a 200MW/800MWH Battery Energy Storage System (BESS). It has been the experience of FRNSW that BESS Facilities present special problems of fighting fire and suitable additional provisions are likely to be required in accordance with E1D17 and E2D21 of the National Construction Code 2022¹.

FRNSW will likely recommend a Fire Safety Study (FSS) be developed in accordance with the Hazardous Industry Planning Advisory Paper No 2² as a condition of consent. The FSS should be used to inform the design and as such it is FRNSW Position³ that the FSS be developed to the satisfaction of FRNSW prior to any further submission being made to FRNSW; this includes: an Initial Fire Safety Report (IFSR) and / or Performance-Based Design Brief / Fire Engineering Brief Questionnaire (FEBQ).

The FSS should be prepared consistent with the relevant FRNSW Fire Safety Guidelines and FRNSW Technical Information Sheets⁴ with particular focus to Large-scale external lithium-ion battery energy storage systems – Fire safety study considerations⁵.

Project proponents undertaking the FSS are to engage directly with FRNSW by submitting all correspondence electronically to FireSafety@fire.nsw.gov.au and reference FRNSW file number FRN25/356. Further information regarding FRNSW Meetings⁶ and FRNSW Written Reports⁷ can be found at the FRNSW Building Fire Safety Industry Portal⁸.

Yours sincerely,



Superintendent James O'Carroll
Manager
Operational Liaison and Special Hazards Unit

Cc: lauren.clear@dpie.nsw.gov.au

¹ <https://ncc.abc.gov.au/editions/ncc-2022>

² <https://www.planning.nsw.gov.au/sites/default/files/2023-03/hazardous-and-offensive-planning-advisory-paper-no-2-fire-safety-study-guidelines.pdf>

³ <https://www.fire.nsw.gov.au/page.php?id=9447&position=51>

⁴ <https://www.fire.nsw.gov.au/page.php?id=9166>

⁵ <https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/Tech%20info%20sheet%20-%20Large-scale%20external%20LiBESS%20-%20Fire%20safety%20study%20considerations.pdf>

⁶ <https://www.fire.nsw.gov.au/page.php?id=9193>

⁷ <https://www.fire.nsw.gov.au/page.php?id=9156>

⁸ <https://www.fire.nsw.gov.au/page.php?id=9140>