



NCC 2022 Section J - J1V3 Assessment Report

461 Chapel Rd,
Bankstown NSW



Revision History

| REVISION | DATE | BY | CHECKED | COMMENTS |
|----------|------------|----|---------|----------|
| 1 | 20/02/2025 | BS | SM | Issue 1 |

The recipient of the latest issue as noted above will be responsible for superseding/destroying all previous documents.

Contents

| | | |
|--------|---|----|
| 1. | Executive Summary | 5 |
| 2. | Introduction | 7 |
| 3. | National Construction Code - Section J | 8 |
| 3.1 | NCC J1V3 - Verification using a reference building | 8 |
| 3.2 | Provisions to Comply with J1V3 – Thermal Comfort Level | 9 |
| <hr/> | | |
| 4. | Building Description | 10 |
| 4.1 | NCC Climate Zone & Building Classification | 10 |
| 4.2 | Scope of Analysis | 11 |
| 4.3 | Information Used | 11 |
| 4.4 | General Assumptions for Glazing and J1V3 Analysis | 11 |
| 4.5 | Architectural Drawings | 12 |
| 4.6 | General Modelling Parameters | 15 |
| 4.7 | Space Summary | 16 |
| 4.8 | Building Geometry | 16 |
| <hr/> | | |
| 5. | Energy Modelling | 17 |
| 5.1 | Process | 17 |
| 5.1.1 | Computer Simulation | 17 |
| 5.2 | Modelling Input Data - General | 18 |
| 5.2.1 | Weather Data | 18 |
| 5.2.2 | Area | 19 |
| 5.2.3 | Air Conditioning, Zoning and Simulation | 19 |
| 5.2.4 | Infiltration Rates | 19 |
| 5.2.5 | Internal Loads & NCC Default Values | 20 |
| 5.2.6 | Internal heat loads, lighting loads and occupancy density | 22 |
| 5.2.7 | Internal Lighting System | 22 |
| 5.2.8 | Ancillary Mechanical Ventilation Fans | 23 |
| 5.2.9 | Schedules of Usage | 23 |
| 5.2.10 | Air Conditioning Simulation | 31 |
| 5.2.11 | Greenhouse gas emissions factors | 32 |
| 5.2.12 | Onsite Energy Generation | 32 |
| 5.2.13 | Solar PV | 32 |

| | | |
|-------|---|----|
| 5.3 | Modelling Case 1 - Reference Building with DTS Services | 34 |
| 5.3.1 | Inputs | 34 |
| 5.3.2 | Results | 34 |
| 5.4 | Modelling Case 2 - Proposed Building with DTS Services | 35 |
| 5.4.1 | Inputs | 35 |
| 5.4.2 | Results | 35 |
| 5.5 | Modelling Case 3 - Proposed Building with Proposed Services | 36 |
| 5.5.1 | Inputs | 36 |
| 5.5.2 | Results | 36 |
| <hr/> | | |
| 6. | Summary of the Simulation Results and Conclusion | 37 |
| 7. | Summary of the Section J Requirements | 38 |
| 7.1 | Part J 4 – Building Fabric Requirements | 38 |
| 7.1.1 | Overview | 38 |
| 7.1.2 | Part J4D2– Application | 38 |
| 7.1.3 | J4D3 Thermal Construction General | 38 |
| 7.1.4 | J4D4 Roof and Ceiling Construction | 39 |
| 7.1.5 | J4D5 Roof Lights | 39 |
| 7.1.6 | J4D6 Walls and Glazing (addressed through J1V3) | 40 |
| 7.1.7 | J4D7 Floors (Addressed as part of J1V3) | 40 |
| 7.2 | Part J5 – Building Sealing | 40 |
| 7.3 | Part J6 – Air Conditioning and Ventilation Systems | 41 |
| 7.4 | Part J7 – Artificial Lighting and Power | 42 |
| 7.5 | Part J8 – Hot Water Supply | 42 |
| 7.6 | Part J9 – Facilities for Energy Monitoring and on-site distributed energy resources | 42 |
| 7.6.1 | J9D3Facilities for energy monitoring | 42 |
| 7.6.2 | J9D4Facilities for electric vehicle charging equipment | 43 |
| 7.6.3 | J9D5Facilities for solar photovoltaic and battery systems | 44 |
| <hr/> | | |
| 8. | Disclaimer | 45 |
| | Glossary | 46 |

1. Executive Summary

JN has been engaged to review the non-residential areas of the proposed development at 461 Chapel Road, Bankstown NSW against the requirements for the National Construction Code 2022 provisions for energy efficiency under Section J (NCC 2022 Volume 1, Part J1).

This report details the outcome of a National Construction Code (NCC) 2022 Section J assessment (J1V3) to determine compliance requirements for the proposed development. Energy simulations were undertaken to provide an alternative method of verification (J1V3) in relation to NCC Section J in order to allow for glazing and insulation variations within the development.

J1V3 requires the comparison of a reference building (Case 1) to two proposed building models, one having the reference building services (Case 2) and one having the same services as the proposed services (Case 3). The comparison is based on the forecasted annual greenhouse gas emissions. Furthermore, in the proposed building (case 3), a thermal comfort level of between a Predicted Mean Vote of -1 to +1 is required across not less than 95% of the floor area of all occupied zones for not less than 98% of the annual hours of operation of the building.

Table 1 details the approximated computer simulation results for the simulation cases undertaken in compliance with the J1V3 Verification Method. The simulation process is detailed as part of this report.

Table 1. Result Summary.

| | CASE 1 Reference Building [DTS Fabric and DTS Services] | CASE 2 Proposed Building [Proposed Fabric and DTS Services] * | CASE 3 Proposed Building [Proposed Fabric and Proposed Services] * | Compliance Achieved |
|---------------------------------|---|---|--|---------------------|
| Annual Greenhouse Gas Emissions | 334,999 kg/annum | 332,540 kg/annum | 332,540 kg/annum | YES |

* The "proposed services" under the modelling case 3 have been conservatively set at the "DTS services" level. The estimated results of modelling cases 2 and 3 are therefore the same (332,540 kg/annum).

The results show that the total annual energy consumption of the Proposed Building models is less than the annual energy consumption of the Reference Building. The glazing and insulation systems utilised within the proposed building are therefore compliant with the performance requirement of J1P1 under J1V3 method of verification.

Building Fabric and Services Compliance Options

Table 2 outlines the glazing and thermal insulation levels utilised in the Proposed Building simulations. Based on this assessment, systems with the performance level of equal or better will achieve NCC Part J4 compliance under the J1V3 method of verification.

Table 2 Minimum Building Fabric and Services Requirements.

| Item | Minimum Requirements |
|--------------|---|
| Roof/ceiling | Total Thermal Insulation: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. |
| Walls | External Walls: Minimum total R1.5 thermal insulation. Internal Walls: Minimum total R1.0 thermal insulation. |
| Glazing | All Glazing Components: Glazing Option 1 (Without Solar PV): <ul style="list-style-type: none"> Total system U-Value \leq 4.0; Total system SHGC \leq 0.30. Glazing Option 2 (With 12 kW Solar PV): <ul style="list-style-type: none"> Total system U-Value \leq 4.5; Total system SHGC \leq 0.35. |

| Item | Minimum Requirements |
|--------|---|
| Floors | Suspended Floors (if any): no insulation needed (addressed via J1V3). Concrete Slab on Ground (if any): no added insulation required. |
| Other | Building services: minimum DTS performance or better. Minimum Solar PV capacity of 12 kW for glazing option 2 (Energy to be used on site). |

A summary of the NCC Section J requirements is provided in section 7 of this report.

Subject to satisfaction of the provisions outlined in this report, this development is expected to comply with the requirements of Section J of NCC 2022. The location of the development is shown in Figure 1.




Figure 1. Location – 461 Chapel Road, Bankstown NSW – Source: Google Map.

2. Introduction

JN has been engaged to review the non-residential areas of the proposed development at 461 Chapel Road, Bankstown NSW against the requirements for the National Construction Code 2022 provisions for energy efficiency under Section J.

The minimum required deemed- to-satisfy (DTS) provisions for Section-J, has been established as per Volume One of NCC 2022.

Energy simulation was undertaken to provide an alternative method of verification (J1V3) in relation to NCC Section J in order to allow for glazing and thermal insulation variations within the development.

The assessment process under J1V3 requires a comparison of simulated annual energy consumption of a reference building to the proposed building utilising the required assumptions and inputs for J1V3. The reference building is based on the proposed building with the performance of all features set to the minimum performance in order to achieve DTS compliance with the provisions of Part J3 to J8.

The proposed building in this assessment also utilises DTS compliance performance of the provisions of Part J3 to J9 excluding those of Part J4 in relation to the glazing and insulation system performance as outlined in section 7 of this report.

On this basis, the outcome of this J1V3 assessment demonstrates achievement of compliance for the proposed glazing and thermal insulation variations for the building (outlined in section 7). Compliance with the DTS provisions for all the other parts is therefore required by all the applicable design trades of the development.

A summary of the NCC Section J requirements for the development is provided in section 7 of this report.

Compliance with J1P1 has been verified in accordance with J1V3 requirements and utilising the Design Builder energy modelling software package that is ABCB protocol compliant and strictly in accordance with the following guideline:

- NCC Section J Part J1V3 Verification Using a Reference Building

3. National Construction Code - Section J

The National Construction Code (NCC) 2022 includes mandatory minimum energy performance requirements for buildings (Class 2 to 9) in Section J. The objective is to reduce building greenhouse gas emissions by efficiently using operational energy. Section J is focused on establishing a minimum acceptable practice in the building industry.

To meet the performance requirements J1P1 of Section J of the NCC, compliance with the design and function of the building can be demonstrated with the Deemed-To-Satisfy (DTS) provisions of Section J Parts J3 to J9. Alternatively, achievement of the performance requirements can be demonstrated through Verification Method J1V3.

- Part J3 Elemental provisions for a sole-occupancy unit of a Class 2 building or a Class 4 part of a building
- Part J4 Building Fabric relates to the building fabric and minimum thermal performance for constructions according to climate zone for roofs, ceilings, roof lights, walls, glazing and floors.
- Part J5 Building Sealing details requirements to restrict unwanted infiltration into a building.
- Part J6 Air-Conditioning and Ventilation Systems details requirements to ensure these services are used and use energy in an efficient manner.
- Part J7 Artificial Lighting and Power details requirements for lighting and power to ensure energy is used efficiently by these systems.
- Part J8 Heated Water Supply and Swimming Pool & Spa Pool Plant details hot water supply design requirements.
- Part J9 Facilities for Energy Monitoring and on-site distributed energy resources.

3.1 NCC J1V3 - Verification using a reference building

Compliance with J1P1 is verified when:

- a) it is determined that the annual greenhouse gas emissions of the proposed building are not more than the annual greenhouse gas emissions of a reference building when—
 - i. the proposed building is modelled with the proposed services; and
 - ii. the proposed building is modelled with the same services as the reference building; and
- b) in the proposed building, a thermal comfort level of between a Predicted Mean Vote of -1 to +1 is achieved across not less than 95% of the floor area of all occupied zones for not less than 98% of the annual hours of operation of the building; and
- c) the building complies with the additional requirements in Specification 33.

The annual greenhouse gas emissions of the proposed building may be offset by—

- i. renewable energy generated and used on-site; and
- ii. Another process such as reclaimed energy, used on site.

The calculation method used for (A) and (B) must comply with—

- i. ANSI/ASHRAE Standard 140; and
- ii. Specification 34.

The following section summarises the process of performing the NCC Section J Performance Solution J1V3 used in this study:

Modelling Case 1 (Reference Building): Calculated the theoretical annual greenhouse gas emissions by modelling a reference building. This was the DTS complying building based on the J1V3 criteria provided in this report.

Modelling Case 2: Calculated the theoretical annual greenhouse gas emissions of the proposed Alternative Solution with the services modelled as if they were the same as those of the reference building.

Modelling Case 3: Calculated the theoretical annual greenhouse gas emissions of the proposed Alternative Solution (building and services).

The theoretical greenhouse gas emissions calculated in cases 2 and 3 were then compared to the annual greenhouse gas emissions calculated in case 1 to ensure that in both cases, the annual emissions of the reference building in case 1 is not exceeded by that in cases 2 and 3.

The following tables outline the NCC requirements for the J1V3 method of verification which were considered in all the modelling runs for the Reference Building.

| |
|--|
| (a) The reference building must— (i) comply with Deemed-to-Satisfy Provisions in Parts J4 to J8; and (ii) have the minimum amount of mechanical ventilation required by Part F6. |
| (b) The external walls must have a solar absorptance of 0.6. |
| (c) The air-conditioning must— (i) for 98% of the annual hours of operation, achieve temperatures between— (A) 18°CDB to 25°CDB for conditioned spaces with transitory occupancy; and (B) subject to (ii), 21°CDB to 24°CDB in all other conditioned spaces; and (ii) if the proposed building has no mechanically provided cooling or has mixed mode cooling, have the same method of control and control set points for non-mechanical cooling as the proposed building. |
| (d) The infiltration rate in each zone must be— (i) 0.7 air changes per hour throughout all zones when there is no mechanically supplied outdoor air; and (ii) 0.35 air changes per hour at all other times. |
| (e) The artificial lighting must achieve the required maximum Illumination power density in Part J7 without applying the control device adjustment factors. |
| (f) Minimum Energy Performance Standards must be applied to services not covered by Parts J6 to J8. |

3.2 Provisions to Comply with J1V3 – Thermal Comfort Level

Based on the assessment undertaken as summarised in the following sections of this report, it is demonstrated that the thermal comfort requirements of J1V3 are met and the proposed building achieves the minimum PMV levels between -1.0 and 1.0 for areas not less than 95% of the occupied zones for 98% of the year.

4. Building Description

4.1 NCC Climate Zone & Building Classification

The climate zone is defined by the NCC as “an area for specific locations, having energy efficiency provisions based upon a range of similar climatic characteristics”.

The development will be located in Bankstown NSW, within the NCC climate zone 5 (warm temperate). The climate zone map of the development is depicted in Figure 2.




Figure 2 Climate Zone Map.

4.2 Scope of Analysis

The scope of this report is based on;

1. Review & interpretation of the architectural drawings to determine the Section J envelope and orientation of the building for assessment.
2. Parts J4 compliance (see sections 5 and 7 of the report)
 - Review and interpretation of façade and glazing dimensions based on the architectural drawings
 - Establish glazed areas of the building envelope to conduct Part J4 DTS analysis (wall-glazing).
 - Input parameters (façade area, external shading devices and glazing dimensions) into the NCC - J1 Calculator (Facade) which is currently available in the Beta version only.
3. J1V3 compliance (see Section 6)
 - Conduct energy modelling for a reference building using the DTS results of the Parts J4 assessment and inputs reflecting achievement of minimum performance under the DTS provisions of Parts J5-J9. The energy modelling conducted is based on geometry development from the architectural and facade documentation.
 - Conduct energy modelling runs for the proposed building using glazing system thermal performances to reflect products in alignment with the architectural design intent.
 - Comparison of the annual energy consumption to determine J1V3 compliance for the building with proposed level of glazing and wall insulation performance.

4.3 Information Used

The assessment within the report presents the requirements of Section J Part J1V3 with respect to the documented design of the development. The assessment format generally follows the layout of Clauses within NCC Section J, to demonstrate the compliance requirements for Part J4.

The assessment is based on the following documentations.

- Architectural drawings by Plus architecture Sydney Pty Ltd are listed in Table 3.

Table 3 Drawing List.


| Drawing Title | Drawing Number | Date of Issue |
|------------------------------|---------------------|---------------|
| Basement Plan | PLA-DA-10B1 | 14/01/2025 |
| Ground to Level22 Floor plan | PLA-DA-1000 to 1011 | 14/01/2025 |
| Roof Plan | PLA-DA-1016 | 14/01/2025 |
| Elevations | PLA-DA-2000 to 2003 | 14/01/2025 |
| Sections | PLA-DA-3000 & 3001 | 14/01/2025 |

- NCC 2022 Volume One - Section J.
- Sydney Bankstown Airport NSW Typical Meteorological Year (TMY) recorded Weather Data.

4.4 General Assumptions for Glazing and J1V3 Analysis

- Glazing areas defined as glazing in the building envelope (as per Section J) include the area of any associated framing.
- The glazing thermal performance properties are inclusive of frame effects (Total system: Glass + Frame).
- Relevant shading must comply with the requirements of the NCC 2022.
- Except for Part J4 (outlined in section 7.1 of this report), all other elements of the building design are required to achieve the DTS compliance provisions of NCC 2022 under Section J.

Level 1 - Floor Plan





Level 2 - Floor Plan





Level 10 - Floor Plan



North and South Elevations



West and East Elevations



4.6 General Modelling Parameters

The parameters presented in Table 4 applied for both the Reference and the Proposed building models developed for this project.

Table 4 General modelling parameters.

| Items | Reference Building | Proposed Building |
|---|--|----------------------------|
| Climate zone | NCC climate zone 5 | Same as Reference Building |
| Weather data (location and data format) | Sydney Bankstown Airport NSW (TMY) | Same as Reference Building |
| Building orientation | As per Architectural Drawings | Same as Reference Building |
| Heating fuel(s) | Electricity | Same as Reference Building |
| Cooling fuel(s) | Electricity | Same as Reference Building |
| Infiltration | <ul style="list-style-type: none"> 0.7 air changes per hour throughout all zones when there is no mechanically supplied outdoor air; 0.35 air changes per hour at all other times. | Same as Reference Building |

4.7 Space Summary

Modelling parameters for each of the space types included in the building simulation models are described in Table 5 below:

Table 5 Space summary.

| | |
|---|--|
| Space Type | Class 5 Areas |
| Occupancy profiles | NCC Class 5 profile |
| Temperature control range | 21°C to 24°C |
| Occupant density m ² /person | 10 |
| Space Type | Class 9b theatre Areas |
| Occupancy profiles | NCC Class 9b theatre profile |
| Temperature control range | 21°C to 24°C |
| Occupant density m ² /person | 1 |
| Space Type | Class 9b school Areas |
| Occupancy profiles | NCC Class 9b school profile |
| Temperature control range | 21°C to 24°C |
| Occupant density m ² /person | 2 |
| Space Type | Class 6 Areas |
| Occupancy profiles | NCC Class 6 restaurant profile |
| Temperature control range | 21°C to 24°C |
| Occupant density m ² /person | 1 |
| Space Type | Conditioned Common Areas |
| Temperature control range | 21°C to 24°C |
| Occupant density m ² /person | - |
| Space Type | Conditioned Common Areas – Transitory spaces |
| Temperature control range | 18°C to 25°C |
| Space Type | Unconditioned Common Areas |
| Temperature control range | - |
| Occupant density m ² /person | - |

4.8 Building Geometry

The building was modelled as per architectural plans and elevations.

5. Energy Modelling

5.1 Process

A Reference Building energy model was generated using the NCC compliant energy simulation software (Design Builder). This model was based on the deemed to satisfy provisions (J3-9) and solar absorbance of 0.6 for external walls. This reference model provided the annual greenhouse gas emissions target for J1P1 verification. This target was measured in kg/annum.

The following two modelling cases were generated and compared with the reference building:

- The proposed building as modelled with the proposed design services.
- The proposed building as modelled with the same services used in the modelling of the Reference Building.

The above process has been detailed in the following sections of this report.

5.1.1 Computer Simulation

Computer modelling was performed using the Design Builder software to predict the annual mechanical energy consumption requirements for the building. This program uses a dynamic simulation to assess the building envelope response as well as space and surface temperatures, internal loads and energy consumption.

To ensure appropriate results are derived from the software package, ABCB requires that the software conform to appropriate BESTEST validation test or be certified in accordance with ANSI/ASHRAE Standard 140-2001: "Standard Method of Test for Evaluation of Building Energy Analysis Computer Programs". Design Builder satisfies this requirement

The Design Builder program models the heat exchange between the air-conditioned space and the external environment to the space, hot or cold bodies in the space including people, lighting, machines, and the air-conditioning system. The external environment includes the external ambient conditions and adjacent spaces.

The heat exchange analysis includes convection to and from surfaces, radiation exchange to and from the external environment, radiation exchange between the space internal surfaces, conduction through surfaces, and changes in humidity.

The software addressed all the main aspects of thermal modelling such as:

- Energy flow through the building's envelope, including at adiabatic surfaces and also including thermal storage effects;
- Accurately modelling the performance of the air-conditioning and ventilation systems, including plant and equipment using their energy input ratios, coefficients of performance, or efficiency at full and part load;
- Control strategies, sequencing of plant and equipment, controlled settings and types of controls;
- Relative humidity range; and
- Use of different energy types.

The energy consumption outputs from the program were used as inputs to this assessment.

This Energy Simulation analysis has been carried out using the Energy Plus energy simulation developed by the USDOE. Energy Plus development is continually tested using industry standard methods as major builds are completed. Three major types of tests are currently conducted:

a. Analytical tests:

- HVAC tests, based on ASHRAE Research Project 865
- Building fabric tests, based on ASHRAE Research Project 1052

b. Comparative tests:

- ANSI/ASHRAE Standard 140-2011
- International Energy Agency Solar Heating and Cooling Programme (IEA SHC) BESTEST (Building Energy Simulation Test) methods not yet in Standard 140
- Energy Plus HVAC Component Comparative tests
- Energy Plus Global Heat Balance tests

c. Release and executable tests

The BESTEST suites compare the results of multiple simulation programs for a series of load-related attributes.

Therefore, the Design Builder simulation suite complies with the ABCB software protocol. The Design Builder graphic user interface (GUI) has been used to develop the complex building geometry with external shading and to access the power of Energy Plus. The energy simulation analysis software description is shown in Table 6.

Table 6 Energy simulation analysis software description.

| | |
|------------------------------|-------------------------------------|
| Software name and version | Design builder v7.0.0.082 |
| Software Developer | Design builder software ltd / USDOE |
| Software validation standard | BESTEST |

5.2 Modelling Input Data - General

In accordance with Verification Method J1V3, the following input data were used to calculate the annual energy consumption for the reference building.

5.2.1 Weather Data

Historical hourly local weather data, in the form of twelve months' data, was used to represent the building's external ambient data at the building location and to accurately model the dynamic nature of building thermal response. The weather data contains hourly records of radiation, temperature, humidity, sunshine duration and wind speed and direction for a typical meteorological year.

Based on the location of the development, the weather data from the closest weather station was used for the simulation of all models (Sydney Bankstown Airport NSW, approx. 4.5 km from the site). The weather station distance from site is illustrated in Figure 3. Table 7 below outlines details of the simulation weather file. The Typical Meteorological Year (TMY) weather file represents a year without unusual extremes in temperature or typical average conditions, suitable for energy simulation modelling.

Table 7 Simulation weather file details.

| Weather file property | Value |
|-----------------------|---------------------------------------|
| Location | Sydney Bankstown Airport NSW |
| Weather File Type | The Typical Meteorological Year (TMY) |




Figure 3 Weather Station distance from site.

5.2.2 Area

The building geometry is based on the latest architectural drawing prepared by Plus architecture Sydney Pty Ltd.

5.2.3 Air Conditioning, Zoning and Simulation

The HVAC systems used in both the Proposed Building and Reference Building models were predefined in Design Builder. In compliance with NCC J1V3, the following temperature bands were adopted for 98% of the plant operation time.

- 18°CDB to 25°CDB for conditioned spaces with transitory occupancy; and
- 21°CDB to 24°CDB in all other conditioned spaces

The mechanical systems for both the Proposed Building and Reference Building models were simulated with the input parameters in accordance with the DTS Requirements of NCC Part J6.

5.2.4 Infiltration Rates

The infiltration has been included in both the Reference and Proposed models as Specification 34.

5.2.5 Internal Loads & NCC Default Values

In compliance with NCC Section J requirements, there are parameters that must be the same in all modelling runs (i.e., the reference building as well as the proposed building). This is to avoid using energy efficiency criteria or calculations that could result in a more generous allowance using the reference building and then criteria or calculations that result in lower annual energy consumption values for the proposed building.

| |
|---|
| <p>In compliance with NCC Section J, the following parameters remained unchanged in all the simulation runs:</p> |
| <p>(a) General—</p> <ul style="list-style-type: none"> (i) annual greenhouse gas emissions calculation method; and (ii) greenhouse gas emissions factors (based on Table S34C3); or (iii) location, being either— <ul style="list-style-type: none"> (A) the location where the building is to be constructed if appropriate climatic data is available; or (B) the nearest location with similar climatic conditions, for which climatic data is available; and (iv) adjacent structures and features; and (v) orientation; and (vi) building form, including— <ul style="list-style-type: none"> (A) the roof geometry; and (B) the floor plan; and (C) the number of storeys; and (D) the location, extent and configuration of ground floors and basements; and (E) the size and location of glazing; and (F) external doors; and (vii) testing standards including for insulation, glazing, water heater and unitary air-conditioning equipment; and |
| <p>(b) Fabric and glazing—</p> <ul style="list-style-type: none"> (i) quality of insulation installation; and (ii) thermal resistance of air films including any adjustment factors, moisture content of materials and the like; and (iii) dimensions of external, internal and separating walls; and (iv) internal shading devices, their colour and their criteria for operation; and |
| <p>(c) Services—</p> <ul style="list-style-type: none"> (i) range and type of services and energy sources, other than renewable energy generated on-site; and (ii) assumptions and means of calculating the temperature difference across air-conditioning zone boundaries; and (iii) floor coverings and furniture and fittings density; and (iv) internal artificial lighting illumination levels; and (v) internal heat gains including people, lighting, appliances, meals and other electric power loads; and (vi) air-conditioning, including chiller, fan and boiler equipment, system configuration and zones; and (vii) profiles for occupancy, air-conditioning, lighting and internal heat gains from people, hot meals, appliances, equipment and heated water supply systems based on— |

- (A) Specification 35; or
- (B) NABERS Energy simulation requirements; or;
- (C) Green Star simulation requirements; or
- (D) the actual building if—
 - (aa) the operating hours per year are not less than 2,500; or
 - (bb) the daily operating profiles are not listed in Specification 35; and
- (viii) supply heated water temperature and rate of use; and
- (ix) infiltration values, unless the following have been specified—
 - (A) additional sealing provisions to those required by Part J5; and
 - (B) an intended building leakage of less than 10 m³ /hr.m² at 50Pa; and
 - (C) pressure testing to verify the achievement of the intended building leakage, in which case the intended building leakage at 50Pa may be converted into a whole building infiltration value for the proposed building infiltration using Tables 4.16 to 4.24 of CIBSE Guide A; and
- (x) sequencing for water heaters, refrigeration chillers and heat rejection equipment such as cooling towers; and
- (xi) representation of clothing and metabolic rate of the occupants; and
- (xii) control of air-conditioning except—
 - (A) the reference building must have variable temperature control for chilled and heated water that modulates the chilled water and heated water temperatures as required to maximise the efficiency of the chiller or boiler operation during periods of low load; and
 - (B) if the controls for the proposed building are not adequately specified or cannot be simulated, the sample control specifications in Appendix B of AIRAH-DA28 must be used; and
- (xiii) environmental conditions such as ground reflectivity, sky and ground form factors, temperature of external bounding surfaces, air velocities across external surfaces and the like; and
- (xiv) number, sizes, floors and traffic served by lifts and escalators.

For the modelling of services for the purposes of calculating annual greenhouse gas emissions, for both proposed and reference building:

- (a) system demand and response for all items of plant must be calculated on a not less frequent than hourly basis; and
- (b) energy usage of all items of plant must be calculated with allowances for—
 - (i) part load performance; and
 - (ii) staging to meet system demand; and
- (c) energy usage of cooling plant must be calculated with allowances for—
 - (i) the impact of chilled water temperature on chiller efficiency; and
 - (ii) the impact of condenser water temperature on water-cooled plant efficiency; and
 - (iii) the impact of ambient temperature on air-cooled plant efficiency; and
 - (iv) the energy use of primary pumps serving individual chillers; and
 - (v) the energy use of auxiliary equipment, including controls and oil heating for chillers; and
 - (vi) thermal losses in the chilled water system; and
 - (vii) the impact of chilled water temperature on thermal losses in the chilled water system; and
- (d) energy usage of water heating systems for space heating must be calculated with allowances for—
 - (i) the impact of water temperature on water heater efficiency; and
 - (ii) the energy use of primary or feedwater pumps serving individual water heaters; and
 - (iii) thermal losses in water heating systems; and

(iv) the thermal mass of water heating systems, accounting for thermal losses during periods when the system is not operating; and

(e) energy usage of fan and pump systems must be calculated with allowances for—

(i) the method of capacity regulation; and

(ii) the use of either fixed or variable pressure control; and

(f) energy usage of pump systems must be calculated with allowances for the system fixed static pressure head; and

(g) energy usage of auxiliary equipment associated with co-generation and tri-generation systems, including pumps, cooling towers and jacket heaters, must be calculated; and

(h) where the energy usage of the heated water supply for food preparation and sanitary purposes or the energy usage of lifts and escalators is the same in the proposed building and the reference building, they may be omitted from the calculation of both the proposed building and the reference building; and

(i) energy use of a lift in a building with more than one classification may be apportioned according to the number of storeys of the part for which the annual greenhouse gas emissions and thermal comfort level are being calculated.

5.2.6 Internal heat loads, lighting loads and occupancy density

The internal heat loads applied to both the Reference and Proposed models are provided in Table 8. The occupancy, lighting and equipment loads have been uniformly distributed throughout the building.

Table 8 Internal heat loads, lighting loads and occupancy density

| Item | Details |
|--|---|
| People load | <ul style="list-style-type: none"> For a restaurant, or café: 80 W sensible heat gain and 80 W latent heat gain. An average adjusted metabolic rate from Table 45 of AIRAH-DA09. A heat emission rate from Table 6.3 of CIBSE Guide A. For other applications: 75 W sensible heat gain and 55 W latent heat gain. An average adjusted metabolic rate from Table 45 of AIRAH-DA09. A heat emission rate from Table 6.3 of CIBSE Guide A. |
| Hourly profile | The schedule is provided in section 5.2.9– based on NCC Specification Tables S35C2c, S35C2d, S35C2e, S35C2f, S35C2h, and S35C2j. |
| Internal heat gains for appliances and equipment | Based on NCC Specification Table S35C2l. |

5.2.7 Internal Lighting System

The Reference and Proposed buildings have been modelled with Illumination power density in accordance with Table J7D3a of NCC 2022 and listed in Table 9 below.

Table 9 Internal lighting system.

| Zone | Illumination power density (w/m ²) | |
|-------------------|--|----------------------------|
| | Reference building | Proposed building |
| NCC Class 5 | 4.5 | Same as Reference Building |
| NCC Class 6 | 14.0 | Same as Reference Building |
| Multipurpose Hall | 8.0 | Same as Reference Building |
| NCC Class 9b | 4.5 | Same as Reference Building |
| Communal Spaces | 4.5 | Same as Reference Building |

| Zone | Illumination power density (w/m ²) | |
|------------------|--|----------------------------|
| | Reference building | Proposed building |
| Car Park | 2.0 | Same as Reference Building |
| Foyer & Corridor | 5.0 | Same as Reference Building |
| Pre-Function | 9.0 | Same as Reference Building |
| Kitchen | 4.0 | Same as Reference Building |
| Plant | 4.0 | Same as Reference Building |
| Services | 1.5 | Same as Reference Building |
| Storage | 1.5 | Same as Reference Building |
| Stair | 2.0 | Same as Reference Building |
| WC | 3.0 | Same as Reference Building |

5.2.8 Ancillary Mechanical Ventilation Fans

The energy calculated for the mechanical ventilation systems are applied to both the Proposed and the Reference building simulations. The estimated annual energy consumption of ancillary mechanical ventilation fans is summarized in Table 10.

Table 10 Ancillary mechanical ventilation fans.

| | Annual energy consumption (kWh) | |
|------------------------------|---------------------------------|-------------------|
| | Reference building | Proposed building |
| Ventilation and exhaust fans | 26,443 | 26,443 |

5.2.9 Schedules of Usage

The internal load schedules used in the model are as per the Specification 35 Modelling profiles provided in NCC Section J. Details of the schedules used are contained in the following tables;

- (a) The air-conditioning, must be modelled on the basis of—
- (i) the daily occupancy and operation profiles in Tables S35C2a to S35C2k (see the schedules provided in the following table); and
 - (ii) the internal heat gains in a building—
 - (A) from occupants and hot meals, in accordance with one of the options in Table S35C2n; and
 - (B) from appliances and equipment, in accordance with Table S35C2l; and
 - (C) from artificial lighting, determined in accordance with (b).
- (b) The artificial lighting must be modelled on the basis of the proposed level of artificial lighting in the building with the daily profile in Tables S35C2a to S35C2k.
- (c) The heated water supply, must be modelled on the basis of the consumption rates of Table S35C2m.

Occupancy and operation profiles

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2c Weekday occupancy and operation profiles of a Class 5 areas.

| Time period | Occupancy | Artificial lighting | Appliances and equipment | Air-conditioning |
|--------------------|--------------------|---------------------|--------------------------|--------------------|
| | (Monday to Friday) | (Monday to Friday) | (Monday to Friday) | (Monday to Friday) |
| 12:00am to 1:00am | 0% | 15% | 25% | Off |
| 1:00am to 2:00am | 0% | 15% | 25% | Off |
| 2:00am to 3:00am | 0% | 15% | 25% | Off |
| 3:00am to 4:00am | 0% | 15% | 25% | Off |
| 4:00am to 5:00am | 0% | 15% | 25% | Off |
| 5:00am to 6:00am | 0% | 15% | 25% | Off |
| 6:00am to 7:00am | 0% | 15% | 25% | Off |
| 7:00am to 8:00am | 10% | 40% | 65% | On |
| 8:00am to 9:00am | 20% | 90% | 80% | On |
| 9:00am to 10:00am | 70% | 100% | 100% | On |
| 10:00am to 11:00am | 70% | 100% | 100% | On |
| 11:00am to 12:00pm | 70% | 100% | 100% | On |
| 12:00pm to 1:00pm | 70% | 100% | 100% | On |
| 1:00pm to 2:00pm | 70% | 100% | 100% | On |
| 2:00pm to 3:00pm | 70% | 100% | 100% | On |
| 3:00pm to 4:00pm | 70% | 100% | 100% | On |
| 4:00pm to 5:00pm | 70% | 100% | 100% | On |
| 5:00pm to 6:00pm | 35% | 80% | 80% | On |
| 6:00pm to 7:00pm | 10% | 60% | 65% | Off |
| 7:00pm to 8:00pm | 5% | 60% | 55% | Off |
| 8:00pm to 9:00pm | 5% | 50% | 25% | Off |
| 9:00pm to 10:00pm | 0% | 15% | 25% | Off |
| 10:00pm to 11:00pm | 0% | 15% | 25% | Off |
| 11:00pm to 12:00am | 0% | 15% | 25% | Off |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under NCC Part J7.
3. The appliances and equipment profile are expressed as a percentage of the maximum internal heat gain in NCC Section - Table S35C2l.
4. The air-conditioning profile is expressed as the plant status.

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2d Weekend occupancy and operation profiles of a Class 5 areas.

| Time period | Occupancy | Artificial lighting | Appliances and equipment | Air-conditioning |
|--------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|
| | (Saturday, Sunday and holidays) | (Saturday, Sunday and holidays) | (Saturday, Sunday and holidays) | (Saturday, Sunday and holidays) |
| 12:00am to 1:00am | 0% | 15% | 25% | Off |
| 1:00am to 2:00am | 0% | 15% | 25% | Off |
| 2:00am to 3:00am | 0% | 15% | 25% | Off |
| 3:00am to 4:00am | 0% | 15% | 25% | Off |
| 4:00am to 5:00am | 0% | 15% | 25% | Off |
| 5:00am to 6:00am | 0% | 15% | 25% | Off |
| 6:00am to 7:00am | 0% | 15% | 25% | Off |
| 7:00am to 8:00am | 0% | 15% | 25% | Off |
| 8:00am to 9:00am | 5% | 25% | 25% | Off |
| 9:00am to 10:00am | 5% | 25% | 25% | Off |
| 10:00am to 11:00am | 5% | 25% | 25% | Off |
| 11:00am to 12:00pm | 5% | 25% | 25% | Off |
| 12:00pm to 1:00pm | 5% | 25% | 25% | Off |
| 1:00pm to 2:00pm | 5% | 25% | 25% | Off |
| 2:00pm to 3:00pm | 5% | 25% | 25% | Off |
| 3:00pm to 4:00pm | 5% | 25% | 25% | Off |
| 4:00pm to 5:00pm | 5% | 25% | 25% | Off |
| 5:00pm to 6:00pm | 0% | 15% | 25% | Off |
| 6:00pm to 7:00pm | 0% | 15% | 25% | Off |
| 7:00pm to 8:00pm | 0% | 15% | 25% | Off |
| 8:00pm to 9:00pm | 0% | 15% | 25% | Off |
| 9:00pm to 10:00pm | 0% | 15% | 25% | Off |
| 10:00pm to 11:00pm | 0% | 15% | 25% | Off |
| 11:00pm to 12:00am | 0% | 15% | 25% | Off |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under Part J7.
3. The appliances and equipment profile are expressed as a percentage of the maximum internal heat gain in Table S35C2I.
4. The air-conditioning profile is expressed as the plant status.

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2e Occupancy and operation profiles of a NCC Class 6 Retail.

| Time period | Occupancy | Artificial lighting | Appliances and equipment | Air-conditioning |
|--------------------|-----------|---------------------|--------------------------|------------------|
| | (Daily) | (Daily) | (Daily) | (Daily) |
| 12:00am to 1:00am | 0% | 25% | 25% | Off |
| 1:00am to 2:00am | 0% | 25% | 25% | Off |
| 2:00am to 3:00am | 0% | 25% | 25% | Off |
| 3:00am to 4:00am | 0% | 25% | 25% | Off |
| 4:00am to 5:00am | 0% | 25% | 25% | Off |
| 5:00am to 6:00am | 0% | 25% | 25% | Off |
| 6:00am to 7:00am | 0% | 25% | 25% | Off |
| 7:00am to 8:00am | 10% | 100% | 70% | On |
| 8:00am to 9:00am | 20% | 100% | 70% | On |
| 9:00am to 10:00am | 20% | 100% | 70% | On |
| 10:00am to 11:00am | 15% | 100% | 70% | On |
| 11:00am to 12:00pm | 25% | 100% | 70% | On |
| 12:00pm to 1:00pm | 25% | 100% | 70% | On |
| 1:00pm to 2:00pm | 15% | 100% | 70% | On |
| 2:00pm to 3:00pm | 15% | 100% | 70% | On |
| 3:00pm to 4:00pm | 15% | 100% | 70% | On |
| 4:00pm to 5:00pm | 15% | 100% | 70% | On |
| 5:00pm to 6:00pm | 5% | 100% | 70% | On |
| 6:00pm to 7:00pm | 5% | 100% | 70% | Off |
| 7:00pm to 8:00pm | 0% | 10% | 10% | Off |
| 8:00pm to 9:00pm | 0% | 10% | 10% | Off |
| 9:00pm to 10:00pm | 0% | 10% | 10% | Off |
| 10:00pm to 11:00pm | 0% | 10% | 10% | Off |
| 11:00pm to 12:00am | 0% | 10% | 10% | Off |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under Part J7.
3. The appliances and equipment profile are expressed as a percentage of the maximum internal heat gain in Table S35C2I.
4. The air-conditioning profile is expressed as the plant status.

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2f Occupancy and operation profiles of Class 6 café areas.

| Time period | Occupancy | Artificial lighting | Appliances and equipment | Air-conditioning |
|--------------------|----------------------|----------------------|--------------------------|----------------------|
| | (Monday to Saturday) | (Monday to Saturday) | (Monday to Saturday) | (Monday to Saturday) |
| 12:00am to 1:00am | 0% | 5% | 15% | Off |
| 1:00am to 2:00am | 0% | 5% | 15% | Off |
| 2:00am to 3:00am | 0% | 5% | 15% | Off |
| 3:00am to 4:00am | 0% | 5% | 15% | Off |
| 4:00am to 5:00am | 0% | 5% | 15% | Off |
| 5:00am to 6:00am | 0% | 5% | 15% | Off |
| 6:00am to 7:00am | 5% | 40% | 40% | Off |
| 7:00am to 8:00am | 5% | 40% | 40% | On |
| 8:00am to 9:00am | 5% | 60% | 60% | On |
| 9:00am to 10:00am | 5% | 60% | 60% | On |
| 10:00am to 11:00am | 20% | 90% | 90% | On |
| 11:00am to 12:00pm | 50% | 90% | 90% | On |
| 12:00pm to 1:00pm | 80% | 90% | 90% | On |
| 1:00pm to 2:00pm | 70% | 90% | 90% | On |
| 2:00pm to 3:00pm | 40% | 90% | 90% | On |
| 3:00pm to 4:00pm | 20% | 90% | 90% | On |
| 4:00pm to 5:00pm | 25% | 90% | 90% | On |
| 5:00pm to 6:00pm | 50% | 90% | 90% | On |
| 6:00pm to 7:00pm | 80% | 90% | 90% | On |
| 7:00pm to 8:00pm | 80% | 90% | 90% | On |
| 8:00pm to 9:00pm | 80% | 90% | 90% | On |
| 9:00pm to 10:00pm | 50% | 90% | 90% | On |
| 10:00pm to 11:00pm | 35% | 50% | 50% | On |
| 11:00pm to 12:00am | 20% | 30% | 30% | On |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under Part J7.
3. The appliances and equipment profile are expressed as a percentage of the maximum internal heat gain in Table S35C2I.
4. The air-conditioning profile is expressed as the plant status.
5. Sunday profile is 5% continuous artificial lighting and 5% continuous appliances and equipment. There is no occupancy and the air-conditioning is "off".

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2h weekday Occupancy and operation profiles of a NCC Class 9b theatre.

| Time period | Occupancy | Artificial lighting | Air-conditioning |
|--------------------|--------------------|---------------------|--------------------|
| | (Monday to Friday) | (Monday to Friday) | (Monday to Friday) |
| 12:00am to 1:00am | 0% | 5% | Off |
| 1:00am to 2:00am | 0% | 5% | Off |
| 2:00am to 3:00am | 0% | 5% | Off |
| 3:00am to 4:00am | 0% | 5% | Off |
| 4:00am to 5:00am | 0% | 5% | Off |
| 5:00am to 6:00am | 0% | 5% | Off |
| 6:00am to 7:00am | 0% | 5% | Off |
| 7:00am to 8:00am | 0% | 5% | Off |
| 8:00am to 9:00am | 0% | 100% | Off |
| 9:00am to 10:00am | 0% | 10% | Off |
| 10:00am to 11:00am | 0% | 10% | Off |
| 11:00am to 12:00pm | 0% | 10% | On |
| 12:00pm to 1:00pm | 20% | 100% | On |
| 1:00pm to 2:00pm | 70% | 5% | On |
| 2:00pm to 3:00pm | 70% | 5% | On |
| 3:00pm to 4:00pm | 70% | 5% | On |
| 4:00pm to 5:00pm | 70% | 5% | On |
| 5:00pm to 6:00pm | 20% | 100% | On |
| 6:00pm to 7:00pm | 20% | 100% | On |
| 7:00pm to 8:00pm | 70% | 100% | On |
| 8:00pm to 9:00pm | 70% | 5% | On |
| 9:00pm to 10:00pm | 70% | 5% | On |
| 10:00pm to 11:00pm | 70% | 5% | On |
| 11:00pm to 12:00am | 10% | 100% | On |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under Part J7.
3. The air-conditioning profile is expressed as the plant status.

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2h weekend Occupancy and operation profiles of a NCC Class 9b theatre.

| Time period | Occupancy | Artificial lighting | Air-conditioning |
|--------------------|-----------------------|-----------------------|-----------------------|
| | (Saturday and Sunday) | (Saturday and Sunday) | (Saturday and Sunday) |
| 12:00am to 1:00am | 0% | 5% | Off |
| 1:00am to 2:00am | 0% | 5% | Off |
| 2:00am to 3:00am | 0% | 5% | Off |
| 3:00am to 4:00am | 0% | 5% | Off |
| 4:00am to 5:00am | 0% | 5% | Off |
| 5:00am to 6:00am | 0% | 5% | Off |
| 6:00am to 7:00am | 0% | 5% | Off |
| 7:00am to 8:00am | 0% | 5% | On |
| 8:00am to 9:00am | 20% | 100% | On |
| 9:00am to 10:00am | 70% | 10% | On |
| 10:00am to 11:00am | 70% | 10% | On |
| 11:00am to 12:00pm | 70% | 10% | On |
| 12:00pm to 1:00pm | 20% | 100% | On |
| 1:00pm to 2:00pm | 70% | 5% | On |
| 2:00pm to 3:00pm | 70% | 5% | On |
| 3:00pm to 4:00pm | 70% | 5% | On |
| 4:00pm to 5:00pm | 70% | 5% | On |
| 5:00pm to 6:00pm | 20% | 100% | On |
| 6:00pm to 7:00pm | 20% | 100% | On |
| 7:00pm to 8:00pm | 70% | 100% | On |
| 8:00pm to 9:00pm | 70% | 5% | On |
| 9:00pm to 10:00pm | 70% | 5% | On |
| 10:00pm to 11:00pm | 70% | 5% | On |
| 11:00pm to 12:00am | 10% | 100% | On |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under Part J7.
3. The air-conditioning profile is expressed as the plant status.

The following table provides the occupancy and operation profiles used for modelling runs in accordance with Table S35C2j Occupancy and operation profiles of a NCC Class 9b school areas.

| Time period | Occupancy | Artificial lighting | Appliances and equipment | Air-conditioning |
|--------------------|--------------------|---------------------|--------------------------|--------------------|
| | (Monday to Friday) | (Monday to Friday) | (Monday to Friday) | (Monday to Friday) |
| 12:00am to 1:00am | 0% | 5% | 5% | Off |
| 1:00am to 2:00am | 0% | 5% | 5% | Off |
| 2:00am to 3:00am | 0% | 5% | 5% | Off |
| 3:00am to 4:00am | 0% | 5% | 5% | Off |
| 4:00am to 5:00am | 0% | 5% | 5% | Off |
| 5:00am to 6:00am | 0% | 5% | 5% | Off |
| 6:00am to 7:00am | 0% | 5% | 5% | Off |
| 7:00am to 8:00am | 5% | 30% | 30% | On |
| 8:00am to 9:00am | 75% | 85% | 85% | On |
| 9:00am to 10:00am | 90% | 95% | 95% | On |
| 10:00am to 11:00am | 90% | 95% | 95% | On |
| 11:00am to 12:00pm | 90% | 95% | 95% | On |
| 12:00pm to 1:00pm | 50% | 80% | 70% | On |
| 1:00pm to 2:00pm | 50% | 80% | 70% | On |
| 2:00pm to 3:00pm | 90% | 95% | 95% | On |
| 3:00pm to 4:00pm | 70% | 90% | 80% | On |
| 4:00pm to 5:00pm | 50% | 70% | 60% | On |
| 5:00pm to 6:00pm | 20% | 20% | 20% | Off |
| 6:00pm to 7:00pm | 20% | 20% | 20% | Off |
| 7:00pm to 8:00pm | 20% | 20% | 20% | Off |
| 8:00pm to 9:00pm | 10% | 10% | 10% | Off |
| 9:00pm to 10:00pm | 5% | 5% | 5% | Off |
| 10:00pm to 11:00pm | 5% | 5% | 5% | Off |
| 11:00pm to 12:00am | 5% | 5% | 5% | Off |

Note:

1. The occupancy profile is expressed as a percentage of the maximum number of people that can be accommodated in the building.
2. The artificial lighting profile is expressed as a percentage of the maximum illumination power density permitted under Part J7.
3. The appliances and equipment profile are expressed as a percentage of the maximum internal heat gain in Table S35C2l.
4. The air-conditioning profile is expressed as the plant status.
5. Saturday and Sunday profile is 5% continuous artificial lighting and 5% continuous appliances and equipment, where there is no occupancy and the air-conditioning is "off".

5.2.10 Air Conditioning Simulation

The HVAC systems for both the Proposed Building and Reference Building models were simulated in Design Builder software package. In compliance with NCC J1V3, the following temperature bands were adopted for 98% of the plant operation time.

- 18°CDB to 25°CDB for conditioned spaces with transitory occupancy; and
- 21°CDB to 24°CDB in all other conditioned spaces.

The mechanical systems for both the Proposed Building and Reference Building models were simulated with the input parameters in accordance with the DTS Requirements of NCC Part J6. The design heating and cooling COPs are set at 2.9, 3.1 and 3.22 for the Proposed Building HVAC system. Figure 4 and Figure 5 demonstrate the HVAC detail applied to the models.

The HVAC systems were simulated based on a selected set of monthly design day temperatures and coincident wet bulb temperatures. The part load performance curves adjust the efficiency of the system based on the capacity, as well as the supply air and environmental conditions.




Figure 4 Detailed HVAC system modelled.

| VRF Outdoor Unit | |
|--|-------------------------------|
| General Cooling Heating Heat Recovery | |
| General | |
| Gross rated total cooling capacity (W) | Autosize |
| Gross rated cooling COP | 3.10 |
| Minimum outdoor temperature in cooling mode (°C) | -6.00 |
| Maximum outdoor temperature in cooling mode (°C) | 43.00 |
| Piping | |
| Equivalent piping length used for piping correction factor in cooling mode (m) | 50.00 |
| Piping correction factor for height in cooling mode coefficient | -0.000386000 |
| <input checked="" type="checkbox"/> Piping correction factor for length in cooling mode curve | CoolingLengthCorrectionFactor |
| Cooling Capacity Ratio Modifier Function of Temperature Curves | |
| Use single or multiple curves | 2-Multiple curves |
| <input checked="" type="checkbox"/> Cooling capacity ratio boundary curve | VRFCoolCapFTBoundary |
| <input checked="" type="checkbox"/> Cooling capacity ratio modifier function of low temperature curve | VRFCoolCapFT |
| <input checked="" type="checkbox"/> Cooling capacity ratio modifier function of high temperature curve | VRFCoolCapFTHi |
| Cooling Energy Input Ratio (EIR) Curves | |
| Function of Temperature Curves | |
| Use single or multiple curves | 2-Multiple curves |
| <input checked="" type="checkbox"/> Cooling energy input ratio (EIR) boundary curve | VRFCoolEIRFTBoundary |
| <input checked="" type="checkbox"/> Cooling energy input ratio (EIR) modifier function of low temperature curve | VRFCoolEIRFT |
| <input checked="" type="checkbox"/> Cooling energy input ratio (EIR) modifier function of high temperature curve | VRFCoolEIRFTHi |
| Function of Part-Load Ratio Curves | |
| <input checked="" type="checkbox"/> Cooling energy input ratio (EIR) modifier function of low part-load ratio curve | CoolingEIRLowPLR |
| <input checked="" type="checkbox"/> Cooling energy input ratio (EIR) modifier function of high part-load ratio curve | CoolingEIRHiPLR |
| Other Curves | |
| <input checked="" type="checkbox"/> Cooling combination ratio correction factor curve | CoolingCombRatio |
| <input checked="" type="checkbox"/> Cooling part-load fraction correlation curve | VRFCPLFFPLR |

Figure 5 Sample of input data for detailed HVAC modelling – outdoor units.

5.2.11 Greenhouse gas emissions factors

The annual greenhouse gas emissions for the proposed building and the reference building have been calculated using the following greenhouse gas emissions factors (kg CO₂-e/GJ) listed in Table 11.

Table 11 Greenhouse gas emissions factors.

| Energy source | GHG emissions factors (KgCO ₂ -e/GJ) |
|---------------|---|
| Electricity | 236 |

5.2.12 Onsite Energy Generation

J1V3 allows the renewable energy generated on-site or the “free” energy derived from another process (e.g., heat from cogeneration) to be deducted from the annual energy consumption of the proposed building. This means that the “annual energy consumption” is the sum of the energy drawn annually from the electrical grid, the gas network or fuel brought in by road transport and not the total of the energy consumed by the services that use energy.

5.2.13 Solar PV

Table 12 outlines the Photovoltaic (PV) system for glazing option 2 may consist of the following main components or equal capacity.


| | |
|----------------------------------|-------------------|
| Total nominal power: | 12 kW |
| Approx. roof space requirements: | 75 m ² |

Table 12 Main components of photovoltaic (PV) system.

| Components | Brand, Model & Quantity |
|--------------------------------------|--|
| Sample PV Inverter | Sungrow 10kW - Quantity: 1 |
| Sample PV Panels | Trina Vertex 600 W - TSM-DEG20C.20 Quantity: 20 |
| Battery Storage | The system to be sized during the detailed design stage, based on the final PV capacity as well as the electrical design for lower reliance on electrical network due to maximum demand constraints. |
| PV mounting frame and system balance | Quantity: depending on the requirements and final design |


The exact sizing, configuration and final design will be completed during the final design stage.

Roof Plan with approx. Solar PV Space:



5.2.13.1.1. Solar PV - Projected Energy Generation for a 12-kW System

| System summary | | | |
|----------------|-----------------------|----------------------|----------------------|
| Nominal power | 12.0 kWp | Total area | 75 m ² |
| Module type | Standard | Supports for modules | Flat roof |
| Technology | Monocrystalline cells | Ventilation property | Free air circulation |



| | Horizontal global | Coll. plane | System output | System output |
|------|-------------------------|-------------------------|---------------|---------------|
| | kWh/m ² /day | kWh/m ² /day | kWh/day | kWh |
| Jan. | 6.91 | 4.91 | 49.55 | 1536 |
| Feb. | 5.83 | 4.27 | 43.03 | 1205 |
| Mar. | 5.03 | 3.74 | 37.75 | 1170 |
| Apr. | 4.05 | 2.81 | 28.36 | 851 |
| May | 3.07 | 0.85 | 8.58 | 266 |
| June | 2.39 | 0.59 | 5.98 | 179 |
| July | 2.55 | 0.64 | 6.44 | 200 |
| Aug. | 3.44 | 2.10 | 21.14 | 655 |
| Sep. | 4.28 | 3.16 | 31.82 | 955 |
| Oct. | 5.30 | 3.90 | 39.32 | 1219 |
| Nov. | 6.05 | 4.34 | 43.80 | 1314 |
| Dec. | 6.25 | 4.42 | 44.58 | 1382 |
| Year | 4.59 | 2.97 | 29.95 | 10932 |

5.3 Modelling Case 1 - Reference Building with DTS Services

5.3.1 Inputs

Building Fabric: The building fabric was modelled based on the minimum Deemed to Satisfy (DTS) provisions outlined in the NCC Part J4 for building fabric (summarised in the Table 13).

Building Services: Based on the minimum NCC Section J Deemed to Satisfy provisions.

Table 13 further outlines the DTS building fabric thermal performance and services used within the simulation model 1 (reference case).

Table 13 Modelling Case 1 - Reference Building with DTS Services.

| Items (Where separating conditioned and non-conditioned zones) | | Reference Building Case (Model 1) |
|---|-------------------|---|
| J4 (DTS) | Roof / Ceiling | Total R-Value: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. |
| | Walls & Glazing | <ul style="list-style-type: none"> Total System U-Value of wall-glazing construction \leq U2.0; Total System R-Value of wall components of the wall-glazing construction: <ul style="list-style-type: none"> Where the wall is less than 80% of the area of the wall-glazing construction \geqR1.0; Where the wall is 80% or more of the area of the wall-glazing construction \geqR1.4. Maximum wall-glazing construction solar admittance: 0.13, Process: As expected, the "proposed" glazing and insulation did not meet the NCC part J4 'deemed to satisfy' calculators. Specification of the DTS external glazing and insulation were refined to be as close as possible to 100% to ensure the highest possible energy consumption figure was achieved for the reference building. |
| | Floors | Minimum total thermal insulation R-Value: R2.0 |
| J5-9 (DTS) | Building Services | Set at the minimum NCC 2022 DTS requirements. |
| Other | Solar Absorptance | Solar absorptance of 0.6 for external walls in accordance with J1V3. |

5.3.2 Results

The estimated emission for the Reference Building with DTS services is 334,999 kg/annum.

5.4 Modelling Case 2 - Proposed Building with DTS Services

5.4.1 Inputs

Building Fabric: The building was modelled based on the proposed fabric which is the same as the NCC Section J deemed to satisfy provisions with the following exceptions:

- J4 – Building Fabric: modelling is based on the proposed glazing and insulation performance specification (provided in the Table 14 and summarised in section 6.1 of the report);

Building Services: Based on the minimum NCC Section J Deemed to Satisfy provisions.

Table 14 further outlines the performance inputs applied to the simulation model 2 (proposed building with DTS services):

Table 14 Modelling Case 2 - Proposed Building with DTS Services.

| Items (Where separating conditioned and non-conditioned zones) | | Proposed Building Case (Model 2) |
|---|--|---|
| J4 (DTS) | Roof / Ceiling | Total Insulation: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. |
| | Walls (Addressed through J1V3 assessment) | External Walls: Minimum total R1.5 thermal insulation. Internal Walls: Minimum total R1.0 thermal insulation. |
| | Glazing (Addressed through J1V3 assessment) | All Glazing Components: Glazing Option 1 (Without Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.0; • Total system SHGC ≤ 0.30. Glazing Option 2 (With 12 kW Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.5; • Total system SHGC ≤ 0.35. |
| | Floors | Suspended Floors (if any): no insulation needed (addressed via J1V3). Concrete Slab on Ground (if any): no added insulation required. |
| J5-9 (DTS) | Building Services | As required by NCC J1V3 method: Set at the minimum of NCC 2022 DTS requirements (Similar to Case 1- Reference Building) |
| Other requirements | | <ul style="list-style-type: none"> • Building services: minimum DTS performance or better • Thermal comfort level of between a Predicted Mean Vote of -1 to +1 across not less than 95% of the floor area of all occupied zones for not less than 98% of the annual hours of operation of the building. • Minimum Solar PV capacity of 12 kW for glazing option 2 (Energy to be used on site). |

5.4.2 Results

The estimated emission for the Proposed Building with DTS services is 332,540 kg/annum.

5.5 Modelling Case 3 - Proposed Building with Proposed Services

5.5.1 Inputs

Building Fabric: The building was modelled based on the proposed fabric which is the same as the NCC part J deemed to satisfy provisions with the following exceptions:

- J4 – Building Fabric: modelling is based on the proposed glazing and insulation performance specification (provided in the Table 15 and summarised in section 6.1 of the report);

Building Services: Based on the proposed building services. The “proposed services” under the modelling case 3 have been conservatively set at the “DTS services” level. The results of modelling cases 2 and 3 are therefore identical.

Table 15 outlines the performance inputs applied to the simulation model 3 (proposed building with proposed services):

Table 15 Modelling Case 3 - Proposed Building with Proposed Services.

| Items (Where separating conditioned and non-conditioned zones) | | Proposed Building Case (Model 3) |
|---|--|---|
| J4 (Proposed) | Roof / Ceiling | Total Insulation: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. |
| | Walls (Addressed through J1V3 assessment) | External Walls: Minimum total R1.5 thermal insulation. Internal Walls: Minimum total R1.0 thermal insulation. |
| | Glazing (Addressed through J1V3 assessment) | All Glazing Components: Glazing Option 1 (Without Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.0; • Total system SHGC ≤ 0.30. Glazing Option 2 (With 12 kW Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.5; • Total system SHGC ≤ 0.35. |
| | Floors | <ul style="list-style-type: none"> • Suspended Floors (if any): no insulation needed (addressed via J1V3). • Concrete Slab on Ground (if any): no added insulation required. |
| J5-9 (Proposed) | Building Services | The “proposed services” under the modelling case 3 have been conservatively set at the “DTS services” level. The results of modelling cases 2 and 3 are therefore the same. |
| Other requirements | | <ul style="list-style-type: none"> • Building services: minimum DTS performance or better • Thermal comfort level of between a Predicted Mean Vote of -1 to +1 across not less than 95% of the floor area of all occupied zones for not less than 98% of the annual hours of operation of the building. • Minimum Solar PV capacity of 12 kW for glazing option 2 (Energy to be used on site). |

5.5.2 Results

The estimated emission for the Proposed Building with proposed services is 332,540 kg/annum.

Note: The “proposed services” under the modelling case 3 have been conservatively set at the “DTS services” level. The estimated results of modelling cases 2 and 3 are therefore the same (332,540 kg/annum).

6. Summary of the Simulation Results and Conclusion

Table 16 summarises the estimated total annual energy consumption for the simulation cases of the development.

Table 16 Summary of Results.

| | CASE 1 Reference Building [DTS Fabric and DTS Services] | CASE 2 Proposed Building [Proposed Fabric and DTS Services] * | CASE 3 Proposed Building [Proposed Fabric and Proposed Services] * | Compliance Achieved |
|------------------------------------|--|--|---|------------------------|
| Annual Greenhouse Gas Emissions | 334,999 kg/annum | 332,540 kg/annum | 332,540 kg/annum | YES |

* The “proposed services” under the modelling case 3 have been conservatively set at the “DTS services” level. The results of modelling cases 2 and 3 are therefore the same (332,540 kg/annum).

A reference building was modelled having minimum DTS envelope characteristics as well as minimum DTS services. The annual energy consumption of the reference building and services was estimated to be 334,999 kg/annum.

The annual energy consumption of the proposed building with the DTS services (modelling case 2) is calculated at 332,540 kg/annum. The services under the 3rd modelling case have been conservatively set at the “DTS services” level. The results of modelling cases 2 and 3 are therefore the same (332,540 kg/annum).

The Proposed Building, therefore, meets the criteria of J1V3 (a) (i) & (ii), for Verification Method J1V3 as 332,540 kg/annum is less than the 334,999 kg/annum estimated for the Reference Case.

The proposed insulation and glazing system as outlined within this report (see section 7) is therefore compliant with the performance requirement of NCC 2022 Section J.

7. Summary of the Section J Requirements

7.1 Part J 4 – Building Fabric Requirements

7.1.1 Overview

Section J part J4 outlines the minimum requirements of building envelope. The envelope is defined by the NCC as parts of a building's fabric that separate a conditioned space or habitable room from the exterior of the building or a non-conditioned space.

The required thermal insulation requirements are outlined in Table 17:

Table 17 Minimum Insulation & Glazing Requirements.

| Item | Minimum Insulation & Glazing Requirements |
|--------------|---|
| Roof/ceiling | Total Insulation: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. |
| Walls | External Walls: Minimum total R1.5 thermal insulation. Internal Walls: Minimum total R1.0 thermal insulation. |
| Glazing | All Glazing Components: Glazing Option 1 (Without Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.0; • Total system SHGC ≤ 0.30. Glazing Option 2 (With 12 kW Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.5; • Total system SHGC ≤ 0.35. |
| Floors | Suspended Floors (if any): no insulation needed (addressed via J1V3). Concrete Slab on Ground (if any): no added insulation required. |

7.1.2 Part J4D2– Application

The Deemed-to-Satisfy Provisions of this Part apply to building elements forming the envelope of Class 2 to 9 building other than J4D3(5), J4D4, J4D5, J4D6 and J4D7 which do not apply to a Class 2 sole-occupancy unit or a Class 4 part of a building. Part J4 is therefore applicable to the proposed development.

7.1.3 J4D3 Thermal Construction General

- (1) Where required, insulation must comply with AS/NZS 4859.1 and be installed so that it—
 - (a) abuts or overlaps adjoining insulation other than at supporting members such as studs, noggings, joists, furring channels and the like where the insulation must be against the member; and
 - (b) forms a continuous barrier with ceilings, walls, bulkheads, floors or the like that inherently contribute to the thermal barrier; and
 - (c) does not affect the safe or effective operation of a service or fitting.
- (2) Where required, reflective insulation must be installed with—
 - (a) the necessary airspace to achieve the required R-Value between a reflective side of the reflective insulation and a building lining or cladding; and
 - (b) the reflective insulation closely fitted against any penetration, door or window opening; and
 - (c) the reflective insulation adequately supported by framing members; and
 - (d) each adjoining sheet of roll membrane being—
 - (i) overlapped not less than 50 mm; or
 - (ii) taped together.

- (3) Where required, bulk insulation must be installed so that—
- (a) it maintains its position and thickness, other than where it is compressed between the cladding and supporting members, water pipes, electrical cabling or the like; and
 - (b) in a ceiling, where there is no bulk insulation or reflective insulation in the wall beneath, it overlaps the wall by not less than 50 mm.
- (4) Roof, ceiling, wall and floor materials, and associated surfaces are deemed to have the thermal properties listed in Specification 36.
- (5) The required Total R-Value and Total System U-Value, including allowance for thermal bridging, must be:
- (a) calculated in accordance with AS/NZS 4859.2 for a roof or floor; or
 - (b) determined in accordance with Specification 37 for wall-glazing construction; or
 - (c) determined in accordance with Specification 39 or Section 3.5 of CIBSE Guide A for soil or sub-floor spaces.

Note:

The thermal insulation performance requirements outlined in this report nominate the Section J compliance requirements only. The specified performance values, therefore, do not consider requirements for any other disciplines such as Acoustics, Fire or Safety compliance. Where required, the development shall comply with any additional requirements related to other disciplines in addition to the Section J compliance requirements detailed in this report. All works need to comply with the minimum Section J Part J4 requirements, Thermal bridging must be accounted for in accordance with J4D3 (5) and is the responsibility of the builder or the architect to obtain a construction build-up calculation from their insulation supplier.

7.1.4 J4D4 Roof and Ceiling Construction

For roof and ceiling constructions that form part of the building envelope of the conditioned space, NCC Section J Compliance shall be achieved with minimum total R3.7 thermal insulation.

The solar absorptance of the upper surface of a roof must be not more than 0.45.

7.1.5 J4D5 Roof Lights

Based on the architectural drawings no roof lights are proposed for the assessed area of the development, Part J4D5 is therefore not applicable to this area.

Under any other design conditions, the roof light must meet the criteria of Table 18. (Table J4D5 Roof Lights – Thermal Performance of transparent and translucent elements).

Table 18 Roof lights – Total system SHGC.

| Roof light shaft index | Total area of roof lights up to 3.5% of the floor area of the room or space | Total area of roof lights more than 3.5% and up to 5% of the floor area of the room or space |
|------------------------|---|--|
| < 1.0 | ≤ 0.45 | ≤ 0.29 |
| ≥ 1.0 to < 2.5 | ≤ 0.51 | ≤ 0.33 |
| ≥ 2.5 | ≤ 0.76 | ≤ 0.49 |

Notes:

- (1) The total area of a roof light serving the space as a percentage of the floor area of the space must not exceed 5%.
- (2) Roof lights must have—
 - (a) a total area of not more than 5% of the floor area of the room or space served; and
 - (b) transparent and translucent elements, including any imperforate ceiling diffuser, with a combined performance of—

- (i) for Total system SHGC, in accordance with Table J4D5 (Table 18 of this report); and
 - (ii) for Total system U-Value, not more than U3.9.
- (3) The roof light shaft index is determined by measuring the distance from the centre of the shaft at the roof to the centre of the shaft at the ceiling level and dividing it by the average internal dimension of the shaft opening at the ceiling level (or the diameter for a circular shaft) in the same units of measurement.
- (4) The area of a roof light is the area of the roof opening that allows light to enter the building.
- (5) The total area of roof lights is the combined area for all roof lights serving the room or space.
- (6) The performance requirements of the total glazing system (glass + frame) must be demonstrated under NFRC100-2001 conditions and based on AFRC requirements and in compliance with the NCC.

7.1.6 J4D6 Walls and Glazing (addressed through J1V3)

For wall and glazing constructions that form part of the building envelope of the conditioned space, NCC Section J Compliance shall be achieved as Table 19:

Table 19 Minimum Insulation & Glazing Requirements.

| | |
|---------|---|
| Walls | External Walls: Minimum total R1.5 thermal insulation. Internal Walls: Minimum total R1.0 thermal insulation. |
| Glazing | All Glazing Components: Glazing Option 1 (Without Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.0; • Total system SHGC ≤ 0.30. Glazing Option 2 (With 12 kW Solar PV): <ul style="list-style-type: none"> • Total system U-Value ≤ 4.5; • Total system SHGC ≤ 0.35. |

7.1.7 J4D7 Floors (Addressed as part of J1V3)

For floors without in-slab heating or cooling system:

- There are no requirements for floor insulation for the floors which are concrete slab on ground (assuming the wall thickness is 250mm or higher).
- No insulation is needed for any suspended floors separating a conditioned space from a non-conditioned space (addressed via J1V3).

7.2 Part J5 – Building Sealing

Part J5 of the NCC 2022 contains the requirements of the Deemed-to-Satisfy compliance for building sealing. The purpose of this subsection is to ensure that additional heating and cooling loads will not be introduced through building leakage.

Part J5 is applicable to the development.

Clause J5D3 refers to chimneys and flues. The chimney or flue of an open solid-fuel burning appliance must be provided with a damper or flap that can be closed to seal the chimney or flue.

Clause J5D4 refers to roof lights.

Clause J5D5 outlines that a seal to restrict air infiltration must be fitted to each edge of doors, openable windows or the like that separate conditioned spaces from non-conditioned spaces or external areas. This provision is not required for windows complying with Australian Standard AS2047, a fire door or smoke door; or a roller shutter door, roller shutter grille or other security door or device installed only for out-of-hours security.

A seal to restrict air infiltration—

- (a) for the bottom edge of a door, must be a draft protection device; and

- (b) for the other edges of a door or the edges of an openable window or other such opening, may be a foam or rubber compression strip, fibrous seal or the like.

An entrance to a building, if leading to a conditioned space must have an airlock, self-closing door, rapid roller door,

revolving door or the like, other than—

- (a) where the conditioned space has a floor area of not more than 50 m²; or
- (b) where a café, restaurant, open front shop or the like has—
 - (i) a 3 m deep un-conditioned zone between the main entrance, including an open front, and the conditioned space; and
 - (ii) at all other entrances to the café, restaurant, open front shop, or the like, self-closing doors.

A loading dock entrance, if leading to a conditioned space, must be fitted with a rapid roller door or the like.

Clause J5D6 is related to exhaust fans. An exhaust fan must be fitted with a sealing device such as a self-closing damper or the like when serving—

- (a) a conditioned space; or
- (b) a habitable room in climate zones 4, 5, 6, 7 or 8.

Clause J5D7 is related to construction of ceilings, walls, and floors.

- (1) Ceilings, walls, floors, and any opening such as a window frame, door frame, roof light frame or the like must be constructed to minimise air leakage in accordance with (2) when forming part of—

- (a) the envelope; or
- (b) in climate zones 4, 5, 6, 7 or 8.

- (2) Construction required by (1) must be—

- (a) enclosed by internal lining systems that are close fitting at ceiling, wall, and floor junctions; or
- (b) sealed at junctions and penetrations with—
 - (i) close fitting architrave, skirting or cornice; or
 - (ii) expanding foam, rubber compressible strip, caulking or the like.

- (3) The requirements of (1) do not apply to openings, grilles or the like required for smoke hazard management.

Clause J5D8 is related to evaporative coolers. An evaporative cooler must be fitted with a self-closing damper or the like—

- (a) when serving a heated space; or
- (b) in climate zones 4, 5, 6, 7 or 8.

7.3 Part J6 – Air Conditioning and Ventilation Systems

Part J6 of the NCC outlines the performance requirements for air conditioning and ventilation systems to ensure these services operate in an efficient manner.

Furthermore, in compliance with the J1V3 method, the proposed building is required to achieve a thermal comfort level of between a Predicted Mean Vote of -1 to +1 across not less than 95% of the floor area of all occupied zones for not less than 98% of the annual hours of operation of the building.

All services consultants and contractors shall design the air conditioning and ventilation systems to ensure compliance with the PMV requirements noted above, Part J6 of the NCC Section J and all subsections associated therein.

7.4 Part J7 – Artificial Lighting and Power

Part J7 of the NCC outlines the performance requirements for illumination power density and the efficient use of lighting power and controls.

All services consultants and contractors shall design the artificial lighting systems to ensure compliance with Part J7 of the NCC Section J and all subsections associated therein with regard to power.

7.5 Part J8 – Hot Water Supply

Part J8 of the NCC outlines the provisions for the energy efficient use of hot water supply systems.

Clause J8D2 of Part J8 states that a hot water supply system for food preparation or sanitary purposes must be designed and installed in accordance with Section 8 of AS/NZS 3500.4.

All services consultants and contractors shall design the Hot Water supply systems to ensure compliance with Part J8 of the NCC Section J and all subsections associated therein.

7.6 Part J9 – Facilities for Energy Monitoring and on-site distributed energy resources

Part J9 is applicable to this development.

7.6.1 J9D3 Facilities for energy monitoring

Part J9D3 of the NCC outlines the provisions of facilities for energy monitoring. Facilities for energy monitoring shall be provided in accordance with Part J9D3 of the NCC.

- (1) A building or sole-occupancy unit with a floor area of more than 500 m² must have the facility to record the time-of-use consumption of gas and electricity.
- (2) A building with a floor area of more than 2,500 m² must have energy meters configured to enable individual time-of-use energy data recording, in accordance with (3), of—
 - (a) air-conditioning plant including, where appropriate, heating plant, cooling plant and air handling fans; and
 - (b) artificial lighting; and
 - (c) appliance power; and
 - (d) central hot water supply; and
 - (e) internal transport devices including lifts, escalators, and travelators where there is more than one serving the building; and
 - (f) on-site renewable energy equipment; and
 - (g) on-site electric vehicle charging equipment; and
 - (h) on-site battery systems; and
 - (i) other ancillary plant.
- (3) Energy meters required by (2) must be interlinked by a communication system that collates the time-of-use energy data to a single interface monitoring system where it can be stored, analysed, and reviewed.
- (4) The provisions of (2) do not apply to energy meters serving—
 - (a) a Class 2 building where the total floor area of the common areas is less than 500 m²; or
 - (b) individual sole-occupancy units with a floor area of less than 2,500 m².

All services consultants and contractors shall design for access for maintenance and facilities for monitoring to ensure compliance with Part J9 of the NCC Section J and all subsections associated therein.

7.6.2 J9D4 Facilities for electric vehicle charging equipment

Part J9D4 of the NCC outlines the provisions of Facilities for electric vehicle charging equipment. Facilities for electric vehicle charging shall be provided in accordance to Part J9 of the NCC.

- (1) Subject to (2), a carpark associated with a Class 2, 3, 5, 6, 7b, 8 or 9 building must be provided with electrical distribution boards dedicated to electric vehicle charging—
- (a) in accordance with Table J9D4 (Table 20of this report) in each storey of the carpark; and
 - (b) labelled to indicate use for electric vehicle charging equipment.

Table 20. Electric vehicle distribution board requirement for each storey of a carpark.

| Carpark spaces per storey for electric vehicles | Electrical distribution boards for electric vehicle charging per storey |
|---|---|
| 0-9 | 0 |
| 10-24 | 1 |
| 25-48 | 2 |
| 49-72 | 3 |
| 73-96 | 4 |
| 97-120 | 5 |
| 121-144 | 6 |
| 145-168 | 7 |

- (2) Electrical distribution boards dedicated to serving electric vehicle charging in a carpark must—
- (a) be fitted with a charging control system with the ability to manage and schedule charging of electric vehicles in response to total building demand; and
 - (b) when associated with a Class 2 building, have capacity for each circuit to support an electric vehicle charger able to deliver a minimum of 12 kWh from 11:00 pm to 7:00 am daily; and
 - (c) when associated with a Class 5 to 9 building, have capacity for each circuit to support an electric vehicle charger able to deliver a minimum of 12 kWh from 9:00 am to 5:00 pm daily; and
 - (d) when associated with a Class 3 building, have capacity for each circuit to support an electric vehicle charger able to deliver a minimum of 48 kWh from 11:00 pm to 7:00 am daily; and
 - (e) be sized to support the future installation of a 7 kW (32 A) type 2 electric vehicle charger in—
 - (i) 100% of the car parking spaces associated with a Class 2 building; or
 - (ii) 10% of car parking spaces associated with a Class 5 or 6 building; or
 - (iii) 20% of car parking spaces associated with a Class 3, 7b, 8 or 9 building; and
 - (f) contain space of at least 36 mm width of DIN rail per outgoing circuit for individual sub-circuit electricity metering to record electricity use of electric vehicle charging equipment; and
 - (g) be labelled to indicate the use of the space required by (f) is for the future installation of metering equipment.

Limitations

J9D4 does not apply to a stand-alone Class 7a building.

7.6.3 J9D5 Facilities for solar photovoltaic and battery systems

Part J9D5 of the NCC outlines the provisions of Facilities for solar photovoltaic and battery systems. Facilities for solar photovoltaic and battery shall be provided in accordance with Part J9D5 of the NCC.

- (1) The main electrical switchboard of a building must—
 - (a) contain at least two empty three-phase circuit breaker slots and four DIN rail spaces labelled to indicate the use of each space for—
 - (i) a solar photovoltaic system; and
 - (ii) a battery system; and
 - (b) be sized to accommodate the installation of solar photovoltaic panels producing their maximum electrical output on at least 20% of the building roof area.
- (2) At least 20% of the roof area of a building must be left clear for the installation of solar photovoltaic panels, except for buildings—
 - (a) with installed solar photovoltaic panels on—
 - (i) at least 20% of the roof area; or
 - (ii) an equivalent generation capacity elsewhere on-site; or
 - (b) where 100% of the roof area is shaded for more than 70% of daylight hours; or
 - (c) with a roof area of not more than 55 m²; or
 - (d) where more than 50% of the roof area is used as a terrace, carpark, roof garden, roof light or the like.

Limitations

- (1) The requirements of J9D5 (1)(a)(i) and (b) do not apply to a building with solar photovoltaic panels installed on at least 20% of the roof area.
- (2) The requirements of J9D5 (1)(a)(ii) and (b) do not apply to a building with battery systems installed.

All services consultants and contractors shall design their systems to ensure compliance with Part J9 of the NCC Section J and all subsections associated therein with regards to facilities for energy monitoring and on-site distributed energy resources.

8. Disclaimer

This report is prepared using the information described above and inputs from other consultants. Whilst JN has endeavoured to ensure the information used is accurate, no responsibility or liability to any third party is accepted for any loss or damage arising out of the use of this report by any third party. Any third party wishing to act upon any material contained in this report should first contact JN for detailed advice which will take into account that party's particular requirements.

Computer performance assessment provides an estimate of building performance. This estimate is based on a necessarily simplified and idealised version of the building that does not and cannot fully represent all the intricacies of the building once built. As a result, simulation results only represent an interpretation of the potential performance of the building. No guarantee or warranty of building performance in practice can be based on simulation results alone. JN and its employees and agents shall not be liable for any loss arising because of, any person using or relying on the Report and whether caused by reason or error, negligent act, or omission in the report. The draft assessment has been prepared based on the preliminary building services and architectural design with the view to conduct a detailed assessment once the design is further developed.

Performance of the completed building may be significantly affected by the quality of construction; the quality of commissioning, ongoing management of the building, and the way the building is operated, monitored, and maintained. Building fabric inputs require verifiable manufacturer data to confirm thermal properties.

This report is intended as a guide to assist with the application of NCC Section J. It should be read in conjunction with the NCC 2022, specific applications may vary during the design development of the project.

The J1V3 Verification Methodology is for NCC Section J compliance purposes only and compares the proposed hypothetical building design to a DTS reference building with the same geometry using defined occupancy and operational control schedules. The annual energy output calculated in the software is used only to demonstrate whether the proposed building envelope has a higher (fail) or lower (pass) value than the DTS reference building.

The modelling, therefore, does not estimate the actual energy consumption of the building and the outputs must not be used for this purpose.

Glossary

Air-conditioning, for the purposes of Section J of Volume One, means a service that actively cools or heats the air within a space, but does not include a service that directly

- (a) cools or heats cold or hot rooms; or
- (b) maintains specialised conditions for equipment or processes, where this is the main purpose of the service.

Annual energy consumption, this is the amount of energy calculated to be consumed under certain specific conditions in consideration of operating profiles, internal loads, and plant efficiencies. It is used in Verification Method J1V3 that compares the calculated energy consumption with that of a complying reference building. It should not be considered a prediction of the actual energy consumption of an actual building as there could be major differences in the conditions such as the internal loads of the building and the hours of operation. It differs from annual energy load because it is affected by the type of heating or cooling appliance used, for example, heating by a reverse cycle air-conditioner uses less than half the energy that a gas fired heater would use to meet the same annual energy load.

Annual greenhouse gas emissions mean the theoretical amount of greenhouse gas emissions attributable to the energy used annually by a building's services, excluding kitchen exhaust and the like.

Assessment Method means a method that can be used for determining that a Performance Solution or Deemed-to-Satisfy Solution complies with the Performance Requirements.

Boiler means a vessel or an arrangement of vessels and interconnecting parts, wherein steam or other vapour is generated, or water or other liquid is heated at a pressure above that of the atmosphere, by the application of fire, the products of combustion, electrical power, or similar high temperature means, and—

- (a) includes superheaters, reheaters, economisers, boiler piping, supports, mountings, valves, gauges, fittings, controls, the boiler settings and directly associated equipment; but
- (b) excludes a fully flooded or pressurised system where water or other liquid is heated to a temperature lower than the normal atmospheric boiling temperature of the liquid.

Carpark means a building that is used for the parking of motor vehicles but is neither a private garage nor used for the servicing of vehicles, other than washing, cleaning, or polishing.

Climate zone means an area defined in Figure 2 and in Table 2 for specific locations, having energy efficiency provisions based on a range of similar climatic characteristics.

Conditioned space, means a space that is likely (i.e., expected) to be air-conditioned and is not limited to the space where an air-conditioning system is installed. In some cases, chilled and hot water may be reticulated through duct risers as part of the building design to enable conditioning to be provided as part of a later fit out. A conditioned space may include a ceiling or under-floor space that is open to the conditioned space such as a space separated by only a perforated or grille ceiling or floor where the space is a supply air or return air plenum.

Cooling load means the calculated amount of energy removed from the cooled spaces of the building annually by artificial means to maintain the desired temperatures in those spaces.

Deemed-to-Satisfy Provisions means provisions which are deemed to satisfy the Performance Requirements.

Deemed-to-Satisfy Solution means a method of satisfying the Deemed-to-Satisfy Provisions.

Display glazing means glazing used to display retail goods in a shop or showroom directly adjacent to a walkway or footpath, but not including that used in a café or restaurant.

Domestic services mean the basic engineering systems that use energy or control the use of energy; and—

- (a) includes—
 - (i) heating, air-conditioning, mechanical ventilation, and artificial lighting; and
 - (ii) pumps and heaters for swimming pools and spa pools; and
 - (iii) heated water systems; but
- (b) excludes cooking facilities and portable appliances.

Envelope, for the purposes of Section J in Volume One, means the parts of a building's fabric that separate a conditioned space or habitable room from—

- (a) the exterior of the building; or
- (b) a non-conditioned space including—
 - (i) the floor of a rooftop plant room, lift-machine room or the like; and
 - (ii) the floor above a carpark or warehouse; and
 - (iii) the common wall with a carpark, warehouse or the like.

External wall, for the purposes of Volume One, means an outer wall of a building which is not a common wall.

Fabric means the basic building structural elements and components of a building including the roof, ceilings, walls, glazing and floors.

Floor area, for the purposes of Volume One, means—

- (a) in relation to a building — the total area of all storeys; and
- (b) in relation to a storey — the area of all floors of that storey measured over the enclosing walls, and includes—
 - (i) the area of a mezzanine within the storey, measured within the finished surfaces of any external walls; and
 - (ii) the area occupied by any internal wall or partitions, any cupboard, or other built-in furniture, fixture, or fitting; and
 - (iii) if there is no enclosing wall, an area which has a use that—
 - (A) contributes to the fire load; or
 - (B) impacts on the safety, health, or amenity of the occupants in relation to the provisions of the BCA; and
- (c) in relation to a room — the area of the room measured within the finished surfaces of the walls, and includes the area occupied by any cupboard or other built-in furniture, fixture, or fitting; and
- (d) in relation to a fire compartment — the total area of all floors within the fire compartment measured within the finished surfaces of the bounding construction, and if there is no bounding construction, includes an area which has a use which contributes to the fire load; and
- (e) in relation to an atrium — the total area of all floors within the atrium measured within the finished surfaces of the bounding construction and if no bounding construction, within the external walls.

Glazing, for the purposes of Section J in Volume One, means a transparent or translucent element and its supporting frame located in the envelope, and includes a window other than a roof light.

For the purposes of Section J, the glazing provides an aperture by which light and energy can flow into or from the conditioned space.

Heated water means water that has been intentionally heated. It is normally referred to as hot water or warm water

Heating load means the calculated amount of energy delivered to the heated spaces of the building annually by artificial means to maintain the desired temperatures in those spaces.

Hours of operation means the number of hours when the occupancy of the building is greater than 20% of the peak occupancy.

Illuminance means the luminous flux falling onto a unit area of surface.

Illumination power density (W/m^2) means the total of the power that will be consumed by the lights in a space, including any lamps, ballasts, current regulators, and control devices other than those that are plugged into socket outlets for intermittent use such as floor standing lamps, desk lamps or work station lamps, divided by the area of the space.

Internal wall, for the purposes of Volume One, excludes a common wall or a party wall.

Latent heat gain means the heat gained by the vaporising of liquid without change of temperature.

Minimum Energy Performance Standards (MEPS) means the Minimum Energy Performance Standards for equipment and appliances established through the Greenhouse and Energy Minimum Standards Act 2012.

Mezzanine means an intermediate floor within a room.

NABERS Energy for Offices means the National Australia Built Environment Rating Systems for office energy efficiency, which is managed by the New South Wales Government.

Outdoor air means air outside the building.

Performance Requirement means a requirement which states the level of performance which a Performance Solution or Deemed-to-Satisfy Solution must meet.

Performance Solution means a method of complying with the Performance Requirements other than by a Deemed-to-Satisfy Solution.

Predicted Mean Vote (PMV) means the Predicted Mean Vote of the thermal perception of building occupants determined in accordance with ANSI/ASHRAE Standard 55.

R-Value ($m^2.K/W$) means the thermal resistance of a component calculated by dividing its thickness by its thermal conductivity.

Reference building, for the purposes of Volume One, means a hypothetical building that is used to calculate the maximum allowable annual greenhouse gas emissions and determine the Thermal comfort level for the proposed building.

Reflective insulation means a building membrane with a reflective surface such as a reflective foil laminate, reflective barrier, foil batt or the like capable of reducing radiant heat flow.

Renewable energy means energy that is derived from sources that are regenerated, replenished, or for all practical purposes cannot be depleted and the energy sources include, but are not limited to, solar, wind, hydroelectric, wave action and geothermal.

Residential care building means a Class 3, 9a or 9c building which is a place of residence where 10% or more of persons who reside there need physical assistance in conducting their daily activities and to evacuate the building during an emergency (including any aged care building or residential aged care building) but does not include a hospital.

Sensible heat gain means the heat gained which causes a change in temperature

Service, for the purposes of Section J in Volume One, means a mechanical or electrical system that uses energy to provide air-conditioning, mechanical ventilation, heated water supply, artificial lighting, vertical transport, and the like within a building, but which does not include—

- (a) systems used solely for emergency purposes; and
- (b) cooking facilities; and
- (c) portable appliances.

Site means the part of the allotment of land on which a building stands or is to be erected

Solar admittance means the fraction of incident irradiance on a wall-glazing construction that adds heat to a building's space.

Sole-occupancy unit means a room or other part of a building for occupation by one or joint owner, lessee, tenant, or other occupier to the exclusion of any other owner, lessee, tenant, or other occupier and includes—

- (a) a dwelling; or
- (b) a room or suite of rooms in a Class 3 building which includes sleeping facilities; or
- (c) a room or suite of associated rooms in a Class 5, 6, 7, 8 or 9 building; or
- (d) a room or suite of associated rooms in a Class 9c building, which includes sleeping facilities and any area for the exclusive use of a resident.

Thermal comfort level means the level of thermal comfort in a building expressed as a PMV sensation scale.

Total R-Value ($m^2.K/W$), for the purposes of Volume One, means the sum of the R-Values of the individual component layers in a composite element including any building material, insulating material, airspace, thermal bridging, and associated surface resistances.

Total System Solar Heat Gain Coefficient (SHGC), for the purposes of Volume One, means the fraction of incident irradiance on a wall-glazing construction or a roof light that adds heat to a building's space.

Total System U-Value ($W/m^2. K$), for the purposes of Volume One, means the thermal transmittance of the composite element allowing for the effect of any airspaces, thermal bridging, and associated surface resistances.

Ventilation opening means an opening in the external wall, floor or roof of a building designed to allow air movement into or out of the building by natural means including a permanent opening, an openable part of a window, a door or other device which can be held open.

Verification Method means a test, inspection, calculation, or other method that determines whether a Performance Solution complies with the relevant Performance Requirements.

Wall-glazing construction, for the purposes of Section J in Volume One, means the combination of wall and glazing components comprising the envelope of a building, excluding—

- (a) display glazing; and
- (b) opaque non-glazed openings such as doors, vents, penetrations, and shutters.

Ward area means that part of a patient care area for resident patients and may contain areas for accommodation, sleeping, associated living and nursing facilities.

Window includes a roof light, glass panel, glass block or brick, glass louvre, glazed sash, glazed door, or other device which transmits natural light directly from outside a building to the room concerned when in the closed position.



20 February 2025

PERFORMANCE BASED DESIGN BRIEF

For 461 Chapel Rd, Bankstown NSW

PROJECT NAME: 461 Chapel Rd, Bankstown NSW

FROM: Ben Shojaei

1. Introduction

Pursuant to Clause A2G2(4) of the BCA, this Performance Based Design Brief (PBDB) has been prepared by JN for the proposed development at 461 Chapel Rd, Bankstown NSW. This Performance Based Design Brief (PBDB) outlines the BCA DTS variations which occur within proposed development.

This assessment is based upon, and limited to, the information depicted in the documentation provided for assessment and does not make any assumptions regarding design intention or the like.

The content of this report relates only to the non-compliance/s and subject building identified.

2. Regulatory Framework


BCA Clause A2G1

Compliance with the NCC is achieved by complying with—

- the Governing Requirements of the NCC; and
- the Performance Requirements.

Performance Requirements are satisfied by one of the following, as shown in the Figure below:

- A Performance Solution.
- A Deemed-to-Satisfy Solution.
- A combination of the above two options.



BCA Clause A2G2

- (1) A Performance Solution is achieved by demonstrating—
 - (a) compliance with all the relevant Performance Requirements; or
 - (b) the solution is at least equivalent to the Deemed-to-Satisfy Provisions.

- (2) A Performance Solution must be shown to comply with the relevant Performance Requirements through one or a combination of the following Assessment Methods:
 - (a) Evidence of suitability in accordance with Part A5 that shows the use of a material, product, plumbing and drainage product, form of construction or design meets the relevant Performance Requirements.
 - (b) A Verification Method including the following:
 - (i). The Verification Methods provided in the NCC.

- (ii). Other Verification Methods, accepted by the appropriate authority that show compliance with the relevant Performance Requirements.
 - (c) Expert Judgement.
 - (d) Comparison with the Deemed-to-Satisfy Provisions.
- (3) Where a Performance Requirement is satisfied entirely by a Performance Solution, in order to comply with (1) the following method must be used to determine the Performance Requirement or Performance Requirements relevant to the Performance Solution:
 - (a) Identify the relevant Performance Requirements from the Section or Part to which the Performance Solution applies.
 - (b) Identify Performance Requirements from other Sections or Parts that are relevant to any aspects of the Performance Solution proposed or that are affected by the application of the Performance Solution.
- (4) Where a Performance Requirement is proposed to be satisfied by a Performance Solution, the following steps must be undertaken:
 - (a) Prepare a performance-based design brief in consultation with relevant stakeholders.
 - (b) Carry out analysis, as proposed by the performance-based design brief.
 - (c) Evaluate results from (4)(b) against the acceptance criteria in the performance-based design brief.
 - (d) Prepare a final report that includes—
 - (i). all Performance Requirements and/or Deemed-to-Satisfy Provisions identified through A2G2(3) or A2G4(3) as applicable; and
 - (ii). identification of all Assessment Methods used; and
 - (iii). details of steps (4)(a) to (4)(c); and
 - (iv). confirmation that the Performance Requirement has been met; and
 - (v). details of conditions or limitations, if any exist, regarding the Performance Solution.

3. Building Characteristics

This PBDB relates to the development at 461 Chapel Rd, Bankstown NSW. The subject building is required to comply with the BCA and specifically with Part J Energy Efficiency.

4. Regulatory Framework

This assessment is a performance solution comparative energy consumption review to demonstrate that the overall energy consumption of the mechanical system with reduced insulation would still outperform the reference case.

The assessment is based on the following architectural drawings by Plus architecture Sydney Pty. Ltd. as presented in Table 1.

Note:

This PBDB has been prepared strictly based on the set of drawings listed below. Any changes to the design drawings made after the date of these drawings have not been captured. Please note that Section J compliance may not be achieved if the design drawings are updated. Compliance with Section J must be verified based on the revised set of drawings.



Table 1. Architectural Drawing List.

| Drawing Title | Drawing Number | Date of Issue |
|------------------------------|---------------------|---------------|
| Basement Plan | PLA-DA-10B1 | 14/01/2025 |
| Ground to Level22 Floor plan | PLA-DA-1000 to 1011 | 14/01/2025 |
| Roof Plan | PLA-DA-1016 | 14/01/2025 |
| Elevations | PLA-DA-2000 to 2003 | 14/01/2025 |
| Sections | PLA-DA-3000 & 3001 | 14/01/2025 |



Level 10 - Floor Plan



North and South Elevations



West and East Elevations



5. Performance Solution Brief

Summary of Performance Solutions

Table 2 lists the Performance Requirement/s and presents its Performance Solution.

Table 2. Performance solution information.

| No. | DTS Provision | Performance Requirement/s | Performance Solution |
|-----|---------------|---|---|
| 1 | Part J4 | Changes to insulation and glazing performance | J1V3 Simulations in compliance with NCC Volume 1. |

Assessment Methods and Acceptance Criteria

Pursuant to BCA clause A2G2, the Assessment Methods, approach, and acceptance criteria in Table 3 have been utilised to determine whether the Performance Solution complies with the Performance Requirements:

Table 3. Performance Solution.

| |
|--|
| Performance Solution #1 |
| Assessment Method – A2G2(2) |
| + Clause A2G2 (2)(b): (i) the Verification Methods in the BCA |
| Approach: |
| <p>Compliance with J1P1 is verified via the following approach:</p> <p>(1) For a Class 3, 5, 6, 7, 8 or 9 building or common area of a Class 2 building, compliance with J1P1 is verified when—</p> <p>(a) it is determined that the annual greenhouse gas emissions of the proposed building are not more than the annual greenhouse gas emissions of a reference building when—</p> <p>(i) the proposed building is modelled with the proposed services; and</p> <p>(ii) the proposed building is modelled with the same services as the reference building; and</p> <p>(b) in the proposed building, a thermal comfort level of between a Predicted Mean Vote of -1 to +1 is achieved across not less than 95% of the floor area of all occupied zones for not less than 98% of the annual hours of operation of the building; and</p> <p>(c) the building complies with the additional requirements in Specification 33.</p> <p>(2) The annual greenhouse gas emissions of the proposed building may be offset by—</p> <p>(a) renewable energy generated and used on site; and</p> <p>(b) another process such as reclaimed energy, used on site.</p> <p>(3) The calculation method used for (1) and (2) must comply with—</p> <p>(a) ANSI/ASHRAE Standard 140; and</p> <p>(b) Specification 34.</p> |
| Nominated Acceptance Criteria: |
| Verification Method – J1V3 |

6. Required Scope of Supporting Information

A summary of the proposed performance solutions is shown in Table 4.

Table 4. Summary of performance solutions.

| Envelope Items (Where separating conditioned and non-conditioned zones) | | DTS requirements Part J4 | Performance Solution J1V3 |
|--|-------------------|---|---|
| J4 | Roof / Ceiling | Total thermal insulation: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. | Total thermal insulation: R3.7 The solar absorptance of the upper surface of a roof must be not more than 0.45. |
| | Walls & Glazing | <ul style="list-style-type: none"> Total System U-Value of wall-glazing construction \leq U2.0 Total System R-Value of wall components of the wall-glazing construction \geq R1.0 Where the wall is 80% or more of the area of the wall-glazing construction \geq R1.4 Maximum wall-glazing construction solar admittance 0.13 Process: As expected, the "Proposed" glazing and insulation did not meet the NCC part J4 'deemed to satisfy' calculators. Specification of the DTS external glazing and insulation were refined to be as close as possible to 100% to ensure the highest possible energy consumption figure was achieved for the reference building. | External Walls: minimum total R1.5 thermal insulation. Internal Walls: minimum total R1.0 thermal insulation. All Glazing Components: Glazing Option 1 (Without Solar PV): <ul style="list-style-type: none"> Total system U-Value \leq 4.0; Total system SHGC \leq 0.30. Glazing Option 2 (With 12 kW Solar PV): <ul style="list-style-type: none"> Total system U-Value \leq 4.5; Total system SHGC \leq 0.35. |
| | Floors | Minimum total thermal insulation R-Value: R2.0 | Suspended Floors (if any): no insulation needed (addressed via J1V3). Concrete Slab on Ground: no added insulation required. |
| J5-9 | Building Services | Set at the minimum NCC 2022 DTS requirements. | Compliant with the minimum NCC 2022 DTS requirements. |
| Other | Solar Absorptance | Solar absorptance of 0.6 for external walls, in accordance with J1V3. | Compliant with the minimum NCC 2022 DTS requirements. Minimum Solar PV capacity of 12 kW for glazing option 2 (Energy to be used on site). |

7. Evidence of Consultation

All stakeholders are required to acknowledge this Performance Based Design Brief in order for the Performance Solution Report to be prepared.

If any information contained within this Brief is not agreed with, correspondence must be issued to JN to ensure that the Brief can be agreed to by all stakeholders.


8. Summary

It is the opinion of JN that the proposed Performance Solutions satisfy Performance Requirements NCC Part J1P1 of the BCA.

Therefore, JN seeks concurrence from the relevant stakeholders as listed in section 4 above in order to proceed with the preparation of a performance solution report.

Kind Regards,

If any further clarification is required, please do not hesitate to contact the undersigned.

| | |
|------|--|
| From | Ben Shojaei Senior ESD Engineer BSc, MEng (UTS), MEngSc (UNSW) Inst. of Engineers Australia – Professional Engineer NABERS AA, GSAP, CBD AA, CEC AD |
| Sign |  |
| Date | 20/02/2025 |