

Hi Elisha,

Having reviewed the PHA, we have no additional queries regarding MOD 2. The PHA is sufficiently comprehensive for both options for energy storage, being Li-ion batteries or iron-flow batteries, showing that both options can comply with the Department's HIPAP 4 land use safety risk criteria.

Having discussed with FRNSW on Monday, we understand that they have also reviewed the PHA and will provide a submission. As such, may I request reviewing their submission so that suitable hazards-related conditions can be drafted? It should be noted that the conditions will be different compared to the standard Li-ion battery systems, but will be similar to HIPAP 12.

Thanks.

Regards,

Nicholas Hon

Technical Specialist (Hazards)

Industry Assessments

4 Parramatta Square, 12 Darcy Street, Parramatta NSW 2150

T 02 9274 6344