Hi Elisha,

Transgrid reference number:

2022-291

Proposal:Limondale Solar Farm (SSD-8025-Mod-2) - Request forAdvice on Modification Report

Thank you for referring the Limondale Solar Farm- Request for Advice on Modification Report to Transgrid.

Please be advised:

- The customer will need to engage TransGrid via executing a Connection Processes Agreement to finalise the connection to TransGrid's network. The Modification will need to include all connection assets including any new transmission line cut in to the existing substation, a new transmission line/substation and access roads for the new infrastructure assets.
- Transgrid has requested and issued a consent letter from ETMHC dated 23/12/2021 relating to the Limondale BESS facility which will form part of the Limondale Solar Farm as per attached consent letter and Modification report for your reference.

If you have any questions, please do not hesitate to contact our team.

Kind regards,

Lauren Player Enquiry Services Coordinator | Community and Policy

Transgrid | 200 Old Wallgrove Road, Wallgrove, NSW, 2766 W: www.transgrid.com.au

