



# Solar Access Assessment

**142-150 Narrow Neck Road, Katoomba  
Management 7bbh**

C/- Antoniadis Architects Pty Ltd  
Suite 305, Level 3, 19A Boundary St  
Darlinghurst, NSW 2010

Prepared by:

**SLR Consulting Australia**

Tenancy 202 Submarine School, Sub Base  
Platypus, 120 High Street, North Sydney NSW  
2060, Australia

SLR Project No.: 610.033104

12 January 2026

Revision: 2

## Revision Record

Revision	Date	Prepared By	Checked By	Authorised By
01	24 October 2025	Mark Hobday	Neihad Al-Khalidy	Neihad Al-Khalidy
02	12 January 2026	Mark Hobday	Neihad Al-Khalidy	Neihad Al-Khalidy

## Basis of Report

This report has been prepared by SLR Consulting Australia (SLR) with all reasonable skill, care and diligence, and taking account of the timescale and resources allocated to it by agreement with Management 7bbh (the Client). Information reported herein is based on the interpretation of data collected, which has been accepted in good faith as being accurate and valid.

This report is for the exclusive use of the Client. No warranties or guarantees are expressed or should be inferred by any third parties. This report may not be relied upon by other parties without written consent from SLR.

SLR disclaims any responsibility to the Client and others in respect of any matters outside the agreed scope of the work.



## Executive Summary

SLR Consulting Australia Pty Ltd (SLR) has been engaged by Management 7bbh to conduct a detailed solar access assessment of the proposed mixed-use development (comprising Blocks A, B, C, D, E, F, G & H) located at 142-150 Narrow Neck Road, Katoomba.

This report forms part of the HDA for the project site.

This assessment has been based on the DA Drawings, issued November 2025

The State Environmental Planning Policy (SEPP) 65 supported by the Apartment Design Guide - Part 03 and 04 is relevant to the assessment of the daylight access into the residential component of the proposed development. The above regulation states that:

- Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.
- In all other areas, living rooms and private open spaces of at least 70% of the apartments in a building receive a minimum of 3 hours direct sunlight between 9 am and 3 pm at mid-winter.
- A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid-winter.
- Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid-winter).
- The ADG also outlines the following design guidance:
  - To maximise the benefit to residents of direct sunlight within living rooms and private open spaces, a minimum of  $1m^2$  of direct sunlight, measured at 1m above floor level is achieved for at least 15 minutes.

From the model provided SLR has calculated the below summarised ADG assessed direct sunlight to residential apartments for June 21, between the hours of 9.00 am and 3.00 pm.

- 62.4% (136 out of 218) of apartments will achieve 3 hours solar access across the assessment window.
- 3% (7 out of 218) of apartments will receive no solar access across the assessment window.



## Table of Contents

<b>Basis of Report</b> .....	<b>i</b>
<b>Executive Summary</b> .....	<b>ii</b>
<b>1.0 Introduction</b> .....	<b>1</b>
1.1 Development Site .....	1
<b>2.0 Solar Access</b> .....	<b>3</b>
<b>3.0 Solar Access Analysis</b> .....	<b>4</b>
<b>4.0 Results</b> .....	<b>5</b>
4.1 Solar Access to Apartments .....	5
<b>5.0 Conclusions</b> .....	<b>6</b>
<b>6.0 Feedback</b> .....	<b>7</b>

## Figures in Text

Figure 1 Project Site Location .....	1
Figure 2 Master Plan .....	2
Figure 3 3D Model of Proposed Site and Surrounds .....	4
Figure 4 Roof Plans .....	4

## Appendices

- Appendix A Sun Eye View Diagrams**
- Appendix B ADG Compliance Table**



## 1.0 Introduction

SLR Consulting Australia Pty Ltd (SLR) has been engaged by Management 7bbh to conduct a detailed solar access assessment of the proposed mixed-use development (comprising Blocks A, B, C, D, E, F, G & H) located at 142-150 Narrow Neck Road, Katoomba.

This report forms part of the HDA for the project site.

This assessment has been based on the DA Drawings, issued December 2025

### 1.1 Development Site

The subject site is currently heavily vegetated along Narrow Neck Road to the West. There is a mix of single and two storey residential buildings to the North along Glencoe Road and there are new three-bedroom duplexes along the Escarpments to the South. The golf course is located to the east of the developments. The site is located in a residential zone - refer **Figure 1**.

**Figure 1 Project Site Location**



*Image: Courtesy Nearmap, October 2024*



## 1.2 Development Description

The proposed multi-building mixed-use development (refer **Figure 2**) spans 16,839 m<sup>2</sup> and comprises

- 8 residential buildings (4-storeys each)
- 36 Serviced apartments
- A restaurant and communal spaces
- 218 residential units

**Figure 2 Master Plan**



The surroundings of 142–150 Narrow Neck Road, Katoomba feature a mix of natural parks and modest residential buildings. The area along Narrow Neck Road includes around 115 properties, mostly residential homes and holiday retreats.



## 2.0 Solar Access

The State Environmental Planning Policy (SEPP) 65 supported by the Apartment Design Guide - Part 03 and 04 is relevant to the assessment of the daylight access into the residential component of the proposed development. The above regulation states that:

- Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.
- In all other areas, living rooms and private open spaces of at least 70% of the apartments in a building receive a minimum of 3 hours direct sunlight between 9 am and 3 pm at mid-winter.
- A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid-winter.
- Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid winter).
- The ADG also outlines the following design guidance:
  - To maximise the benefit to residents of direct sunlight within living rooms and private open spaces, a minimum of  $1m^2$  of direct sunlight, measured at 1m above floor level is achieved for at least 15 minutes.



### 3.0 Solar Access Analysis

The CAD file, created below, was based on the DWG file provided by Antoniades Architects was utilised to conduct the solar analysis (Refer **Figure 3**):


Surrounds were included in the model to incorporate elements which may impact the solar access assessment.

**Figure 3 3D Model of Proposed Site and Surrounds**



The roof plan, including the proposed skylights designed to enhance solar access to the living areas and private open spaces.

**Figure 4 Roof Plans**



## 4.0 Results

SLR imported the AutoCAD 3D model into Sketchup and sun eye view diagrams were generated for each 15-minute interval between 9.00 am and 3.00 pm on the Winter Solstice (21 June). These can be seen in attached **Appendix A**.

### 4.1 Solar Access to Apartments

Results of solar access to living rooms and private open spaces of apartments for the proposed development at 142-150, Narrow Neck Road, Katoomba on June 21 (winter solstice) between the hours of 9.00 am and 3.00 pm inclusive are summarised in the list below, detailed results can be found in **Appendix B**.

From the model provided SLR has calculated the below summarised ADG assessed direct sunlight to residential apartments for June 21, between the hours of 9.00 am and 3.00 pm.

- 62.4% (136 out of 218) of apartments will achieve 3 hours solar access across the assessment window.
- 3% (7 out of 218) of apartments will receive no solar access across the assessment window.

**Table 3 Solar Access Results (June 21, between the hours of 9.00 am and 3.00 pm)**

Building	Number of Apartments	Number of Apartments with 3 hours direct sunlight between 9 am and 3 pm	Number of Apartments with no direct sunlight between 9 am and 3 pm	Percentage of Apartments with 3 hours direct sunlight between 9 am and 3 pm
A	32	23	0	71.9%
B	32	21	0	65.6%
C	32	22	0	68.8%
D	32	23	0	71.9%
E	32	23	0	71.9%
F	24	9	6	37.5%
G	27	13	1	48.1%
H	7	2	0	28.6%
<b>Total</b>	<b>218</b>	<b>136</b>	<b>7</b>	-
<b>Percentage</b>	-	<b>62.4%</b>	<b>3.0%</b>	-



## 5.0 Conclusions

SLR Consulting Australia Pty Ltd (SLR) has been engaged by Management 7bbh to conduct a detailed solar access assessment of the proposed mixed-use development (comprising Blocks A, B, C, D, E, F, G & H) located at 142-150 Narrow Neck Road, Katoomba.

This report forms part of the HDA for the project site.

This assessment has been based on the DA Drawings, issued November 2025

The State Environmental Planning Policy (SEPP) 65 supported by the Apartment Design Guide - Part 03 and 04 is relevant to the assessment of the daylight access into the residential component of the proposed development. The above regulation states that:

- Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.
- In all other areas, living rooms and private open spaces of at least 70% of the apartments in a building receive a minimum of 3 hours direct sunlight between 9 am and 3 pm at mid-winter.
- A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid-winter.
- Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid-winter).
- The ADG also outlines the following design guidance:
  - To maximise the benefit to residents of direct sunlight within living rooms and private open spaces, a minimum of  $1m^2$  of direct sunlight, measured at 1m above floor level is achieved for at least 15 minutes.

From the model provided SLR has calculated the below summarised ADG assessed direct sunlight to residential apartments for June 21, between the hours of 9.00 am and 3.00 pm.

- 62.4% (136 out of 218) of apartments will achieve 3 hours solar access across the assessment window.
- 3% (7 out of 218) of apartments will receive no solar access across the assessment window.




## 6.0 Feedback


At SLR, we are committed to delivering professional quality service to our clients. We are constantly looking for ways to improve the quality of our deliverables and our service to our clients. Client feedback is a valuable tool in helping us prioritise services and resources according to our client needs.

To achieve this, your feedback on the team's performance, deliverables and service are valuable and SLR welcome all feedback via <https://www.slrconsulting.com/en/feedback>. We recognise the value of your time and we will make a \$10 donation to our Charity Partner - Lifeline, for every completed form.





**Appendix A Sun Eye View  
Diagrams**



1 3D View  
Sun Eye\_09.00



2 3D View  
Sun Eye\_10.00

NOT FOR CONSTRUCTION

NOTES:  
 • (C) Antoniaades Architects Pty Ltd all rights reserved. This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Antoniaades Architects. Any license to use this document, whether expressed or implied is restricted to the terms of the agreement or implied agreement between Antoniaades Architects Pty Ltd and the instructing party.  
 • All dimensions in millimeters unless otherwise shown.  
 • Use figured dimensions only.  
 • Do not scale from drawings.  
 • Check all dimensions on site prior to construction.  
 • To be read in conjunction with all other documents.  
 • Report any discrepancies to Antoniaades Architects Pty Ltd.  
 • All boundary dimensions and bearings to be verified by licensed surveyor prior to proceeding with work.

REV	DESCRIPTION	BY	DATE
A	Issue for Submission		31.10.2025
B	Issue for Submission		18.12.2025

**ANTONIAADES  
ARCHITECTS**

www.antoniaades.com.au  
 ACN 129 731 559  
 Nominated Architect: Andreas Antoniaades  
 NSW Registration 7954

PROJECT PHASE  
**DEVELOPMENT  
 APPLICATION**

STATUS  
**FOR SUBMISSION**


PROJECT NO.  
**24012**  
 PROJECT  
 -  
 ADDRESS  
 142-150 Narrow Neck Road,  
 Katoomba  
 CLIENT  
 VDM Prime Pty Ltd

DRAWING SERIES  
**DA6 Design Analysis**  
 DRAWING TITLE  
**Sun's Eye View - 9am - 10am, 21st June**


DRAWING NO.  
**DA6.05**  
 SCALE  
 NTS

REVISION  
**B**  
 DRAWN BY  
**SX**  
 CHECKED BY  
**AA**

@A1



1 3D View  
Sun Eye\_09.00



2 3D View  
Sun Eye\_10.00

NOT FOR CONSTRUCTION

NOTES:  
 • (C) Antoniaades Architects Pty Ltd all rights reserved. This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Antoniaades Architects. Any license to use this document, whether expressed or implied is restricted to the terms of the agreement or implied agreement between Antoniaades Architects Pty Ltd and the instructing party.  
 • All dimensions in millimeters unless otherwise shown.  
 • Use figured dimensions only.  
 • Do not scale from drawings.  
 • Check all dimensions on site prior to construction.  
 • To be read in conjunction with all other documents.  
 • Report any discrepancies to Antoniaades Architects Pty Ltd.  
 • All boundary dimensions and bearings to be verified by licensed surveyor prior to proceeding with work.

REV	DESCRIPTION	BY	DATE
A	Issue for Submission		31.10.2025
B	Issue for Submission		18.12.2025

**ANTONIAADES  
ARCHITECTS**

www.antoniaades.com.au  
 ACN 129 731 559

• • •

Nominated Architect: Andreas Antoniaades  
 NSW Registration 7954

PROJECT PHASE  
**DEVELOPMENT  
 APPLICATION**

STATUS  
**FOR SUBMISSION**


PROJECT NO.  
**24012**  
 PROJECT  
 -  
 ADDRESS  
 142-150 Narrow Neck Road,  
 Katoomba  
 CLIENT  
 VDM Prime Pty Ltd

DRAWING SERIES  
**DA6 Design Analysis**  
 DRAWING TITLE  
**Sun's Eye View - 9am - 10am, 21st June**


DRAWING NO.  
**DA6.05**  
 SCALE  
 NTS

REVISION  
**B**  
 DRAWN BY  
**SX**  
 CHECKED BY  
**AA**

@A1



1 3D View  
Sun Eye\_11.00



2 3D View  
Sun Eye\_12.00

NOT FOR CONSTRUCTION

NOTES:  
 • (C) Antoniaades Architects Pty Ltd all rights reserved. This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Antoniaades Architects. Any license to use this document, whether expressed or implied is restricted to the terms of the agreement or implied agreement between Antoniaades Architects Pty Ltd and the instructing party.  
 • All dimensions in millimeters unless otherwise shown.  
 • Use figured dimensions only.  
 • Do not scale from drawings.  
 • Check all dimensions on site prior to construction.  
 • To be read in conjunction with all other documents.  
 • Report any discrepancies to Antoniaades Architects Pty Ltd.  
 • All boundary dimensions and bearings to be verified by licensed surveyor prior to proceeding with work.

REV	DESCRIPTION	BY	DATE
A	Issue for Submission		31.10.2025
B	Issue for Submission		18.12.2025

**ANTONIADES ARCHITECTS**

www.antoniaades.com.au  
 ACN 129 731 559

• • •

Nominated Architect: Andreas Antoniaades  
 NSW Registration 7954

PROJECT PHASE  
**DEVELOPMENT APPLICATION**

STATUS  
**FOR SUBMISSION**



PROJECT NO.  
**24012**  
 PROJECT  
 -  
 ADDRESS  
 142-150 Narrow Neck Road,  
 Katoomba  
 CLIENT  
 VDM Prime Pty Ltd

DRAWING SERIES  
**DA6 Design Analysis**  
 DRAWING TITLE  
**Sun's Eye View - 11am - 12pm, 21st June**

DRAWING NO.  
**DA6.06**  
 SCALE  
 NTS

REVISION  
**B**  
 DRAWN BY  
**SX**  
 CHECKED BY  
**AA**

@A1



1 3D View  
Sun Eye\_13.00

2 3D View  
Sun Eye\_14.00

NOT FOR CONSTRUCTION

NOTES:  
 • (C) Antoniaades Architects Pty Ltd all rights reserved. This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Antoniaades Architects. Any license to use this document, whether expressed or implied is restricted to the terms of the agreement or implied agreement between Antoniaades Architects Pty Ltd and the instructing party.  
 • All dimensions in millimeters unless otherwise shown.  
 • Use figured dimensions only.  
 • Do not scale from drawings.  
 • Check all dimensions on site prior to construction.  
 • To be read in conjunction with all other documents.  
 • Report any discrepancies to Antoniaades Architects Pty Ltd.  
 • All boundary dimensions and bearings to be verified by licensed surveyor prior to proceeding with work.

REV	DESCRIPTION	BY	DATE
A	Issue for Submission		31.10.2025
B	Issue for Submission		18.12.2025

**ANTONIADES  
ARCHITECTS**

www.antoniaades.com.au  
ACN 129 731 559

Nominated Architect: Andreas Antoniaades  
NSW Registration 7954

PROJECT PHASE  
**DEVELOPMENT  
APPLICATION**

STATUS  
**FOR SUBMISSION**

PROJECT NO.  
**24012**

PROJECT

-

ADDRESS  
142-150 Narrow Neck Road,  
Katoomba  
CLIENT  
VDM Prime Pty Ltd

DRAWING SERIES  
**DA6 Design Analysis**


DRAWING TITLE  
**Sun's Eye View - 1pm - 2pm, 21st June**

DRAWING NO.  
**DA6.07**

SCALE  
NTS

REVISION  
**B**  
DRAWN BY  
**SX**  
CHECKED BY  
**AA**

@A1



1 **3D View**  
Sun Eye, 15.00

NOT FOR CONSTRUCTION

NOTES:

- (C) Antoniaades Architects Pty Ltd all rights reserved. This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Antoniaades Architects. Any license to use this document, whether expressed or implied is restricted to the terms of the agreement or implied agreement between Antoniaades Architects Pty Ltd and the instructing party.
- All dimensions in millimeters unless otherwise shown.
- Use figured dimensions only.
- Do not scale from drawings.
- Check all dimensions on site prior to construction.
- To be read in conjunction with all other documents.
- Report any discrepancies to Antoniaades Architects Pty Ltd.
- All boundary dimensions and bearings to be verified by licensed surveyor prior to proceeding with work.

REV	DESCRIPTION	BY	DATE
A	Issue for Submission		31.10.2025
B	Issue for Submission		18.12.2025

**ANTONIADES  
ARCHITECTS**

www.antoniaades.com.au  
ACN 129 731 559

Nominated Architect: Andreas Antoniaades  
NSW Registration 7954

PROJECT PHASE  
**DEVELOPMENT  
APPLICATION**

STATUS  
**FOR SUBMISSION**

PROJECT NO.  
**24012**

PROJECT

-

ADDRESS  
142-150 Narrow Neck Road,  
Katoomba  
CLIENT  
VDM Prime Pty Ltd

DRAWING SERIES

**DA6 Design Analysis**

DRAWING TITLE

**Sun's Eye View - 3pm, 21st June**

DRAWING NO.

**DA6.08**

SCALE  
NTS

REVISION

**B**


DRAWN BY

**SX**

CHECKED BY

**AA**

@A1



**Appendix B    ADG Compliance  
Table**







**Solar Access Tally at 15 minute intervals**

**EXISTING / PROPOSED**

Subject site: **142-150 Narrow Neck Road, Katoomba**

Adjacent site:

Infill orange cells using drop down menu options only:  
 Y = in sunlight  
 N = not in sunlight  
 H = min. 15 mins sunlight to habitable room only

Infill red cells manually

No. of Apt	Building	Floor Level (Living)	Unique Apt ID	Room Name	9:00	9:15	9:30	9:45	10:00	10:15	10:30	10:45	11:00	11:15	11:30	11:45	12:00	12:15	12:30	12:45	1:00	1:15	1:30	1:45	2:00	2:15	2:30	2:45	2:00	Total Hours	≥ 2 hours sun to LIVING & P.O.S.	≥ 3 hours sun to LIVING & P.O.S.	Confirmed NDS = 'YES' (<=15mins)	NDS to LIVING & P.O.S.
1	D	L01	DG01	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO	
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
2	D	L01	DG02	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
3	D	L01	DG03	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
4	D	L01	DG04	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
5	D	L01	DG05	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
6	D	L01	DG06	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
7	D	L01	DG07	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
8	D	L01	DG08	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
1	D	L02	DG01	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO	
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
2	D	L02	DG02	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
3	D	L02	DG03	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
4	D	L02	DG04	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
5	D	L02	DG05	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
6	D	L02	DG06	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
7	D	L02	DG07	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
8	D	L02	DG08	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
1	D	L03	D101	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO	
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
2	D	L03	D102	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
3	D	L03	D103	LIVING	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
				P.O.S.	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0			NO
4	D	L03	D104	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
5	D	L03	D105	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
6	D	L03	D106	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
7	D	L03	D107	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
8	D	L03	D108	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
1	D	L04	D201	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
2	D	L04	D202	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
3	D	L04	D203	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
4	D	L04	D204	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
5	D	L04	D205	LIVING	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	6	Y	Y		NO	
				P.O.S.																														







Solar Access Tally at 15 minute intervals	
EXISTING / PROPOSED	
Subject site:	142-150 Narrow Neck Road, Katoomba
Adjacent site:	
Infill orange cells using drop down menu options only: Y = in sunlight N = not in sunlight H = min. 15 mins sunlight to habitable room only	

Infill red cells manually


No. of Apt	Building	Floor Level (Living)	Unique Apt ID	Room Name	9:00	9:15	9:30	9:45	10:00	10:15	10:30	10:45	11:00	11:15	11:30	11:45	12:00	12:15	12:30	12:45	1:00	1:15	1:30	1:45	2:00	2:15	2:30	2:45	3:00	Total Hours	≥ 2 hours sun to LIVING & P.O.S	≥ 3 hours sun to LIVING & P.O.S	Confirm) NDS = 'YES' (< 15mins)	NDS to LIVING & P.O.S
1	H	L02	HLO2.01	LIVING	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	0.5				NO	
				P.O.S	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	N	0	2				NO	
2	H	L02	HLO2.02	LIVING	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	6	Y	Y		NO
				P.O.S	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	6				NO
3	H	L02	HLO2.03	LIVING	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.75				NO
				P.O.S	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	4.25				NO
4	H	L02	HLO2.04	LIVING	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.75				NO
				P.O.S	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	4.25				NO
5	H	L02	HLO2.05	LIVING	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	1.25				NO
				P.O.S	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	4.25				NO
6	H	L02	HLO2.06	LIVING	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.75				NO
				P.O.S	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	4.25				NO
7	H	L03	HLO3.01	LIVING	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	6	Y	Y		NO
				P.O.S	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	0.25	Y	6				NO

<b>Total No. of Apts</b>	<b>7</b>
--------------------------	----------

If the number of apartments is greater or less than 50, add/remove rows below 1 or above 50  
If rows are added or removed, check that the total number of apartments shown here is correct

≥ 2 hours sunlight	2	28.6%
≥ 3 hours sunlight	2	28.6%

No Direct Sun	0	0.0%
---------------	---	------



Making Sustainability Happen