

Nationwide House Energy Rating Scheme® Class 2 Summary

NatHERS® Certificate No. #HR-95MH4Y-01

Generated on 15 May 2026 using Hero 4.1

Property

Address Pacific Highway, Chatswood, NSW, 2076
Lot/DP 1/-/DP547585
NatHERS climate zone 56 - Mascot AMO



Accredited assessor

Name Xiaoran Sun
Business name SLR Consulting
Email xiaoran_sun@foxmail.com
Phone +61 424275678
Accreditation No. 101556
Assessor Accrediting Organisation ABSA

Verification

To verify this certificate, scan the QR code or visit <http://www.hero-software.com.au/pdf/HR-95MH4Y-01>.
When using either link, ensure you are visiting <http://www.hero-software.com.au>



National Construction Code (NCC) requirements

The NCC allows the use of NatHERS accredited software to comply with the energy efficiency requirements for houses (Class 1 buildings) and apartments (Class 2 sole-occupancy units and Class 4 parts of buildings). The applicable requirements for houses are detailed in Specification 42 of NCC Volume Two. For apartments the requirements are detailed in clauses J3D3 and J3D15 of NCC Volume One.

NCC 2022 includes enhanced thermal performance requirements for houses and apartments. It also includes a new whole-of-home annual energy use budget which applies to the major equipment in the home.


The NCC, and associated ABCB Standards and support material, can be accessed at www.abcb.gov.au.

Note, variations and additions to the NCC energy efficiency requirements may apply in some states and territories.

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m².yr)	Cooling load (load limit) (MJ/m².yr)	Total load (MJ/m².yr)	Star Rating	Whole of Home Rating
HR-LW38OB-01	3306	5.8 (34)	12.5 (21)	18.3	8.3	n/a
HR-ZJAIPU-01	3402	30.0 (34)	6.1 (21)	36.0	6.2	n/a
HR-J39ILD-01	4606	6.6 (34)	12.0 (21)	18.5	8.2	n/a

Thermal performance Star rating



NCC heating and cooling maximum loads MJ/m².yr

Limits taken from ABCB Standard 2022

	Heating	Cooling
Average load	18.3	9.8
Maximum load	32.7	18.8
Average limit	28.1	20.0
Maximum limit	34.4	21.4

Whole of Home performance rating

No Whole of Home performance rating generated for this certificate or not completed for all dwellings.

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-96972E-01	4702	29.9 (34)	6.0 (21)	35.9	6.3	n/a
HR-XPFCUE-01	1001	25.9 (34)	7.4 (21)	33.3	6.6	n/a
HR-SF6T8B-01	1002	14.8 (34)	13.7 (21)	28.5	7.2	n/a
HR-C0VIF2-01	1003	22.4 (34)	8.2 (21)	30.6	6.9	n/a
HR-W72LVX-01	1201	22.3 (34)	9.9 (21)	32.2	6.7	n/a
HR-UTKIS2-01	1202	29.2 (34)	7.0 (21)	36.2	6.2	n/a
HR-SYNKJZ-01	1203	22.5 (34)	14.4 (21)	36.9	6.1	n/a
HR-DH8GHP-01	1204	24.1 (34)	10.8 (21)	34.9	6.4	n/a
HR-0QTP5X-01	1205	14.6 (34)	12.5 (21)	27.2	7.3	n/a
HR-79T6N4-01	1206	13.6 (34)	9.0 (21)	22.6	7.8	n/a
HR-X6ZRP1-01	1207	21.1 (34)	12.0 (21)	33.1	6.6	n/a
HR-VF4Z9C-01	1208	19.6 (34)	13.1 (21)	32.7	6.7	n/a
HR-V4RYLI-01	1209	20.2 (34)	8.2 (21)	28.4	7.2	n/a
HR-GWM8NZ-01	1210	32.2 (34)	3.3 (21)	35.4	6.3	n/a
HR-4XJTW-01	1301	23.0 (34)	7.4 (21)	30.4	6.9	n/a
HR-9B42SS-01	1302	29.8 (34)	6.6 (21)	36.4	6.2	n/a
HR-EO1SZ6-01	1303	15.6 (34)	18.4 (21)	34.0	6.4	n/a
HR-QTULGR-01	1304	21.7 (34)	6.5 (21)	28.2	7.2	n/a
HR-76RN3I-01	1305	12.6 (34)	15.3 (21)	27.9	7.2	n/a
HR-4BOJTU-01	1306	10.9 (34)	8.0 (21)	18.9	8.2	n/a
HR-HPQI3J-01	1307	24.1 (34)	11.8 (21)	35.9	6.3	n/a
HR-DHGCAS-01	1308	17.7 (34)	7.2 (21)	24.9	7.5	n/a
HR-5J1Q6A-01	1309	16.4 (34)	9.5 (21)	25.9	7.4	n/a
HR-JQ8TY4-01	1310	32.3 (34)	3.9 (21)	36.3	6.2	n/a
HR-6QSK9V-01	1401	22.3 (34)	7.3 (21)	29.6	7.0	n/a
HR-12NGSM-01	1402	29.6 (34)	6.8 (21)	36.3	6.2	n/a
HR-ORXJSP-01	1403	15.4 (34)	18.5 (21)	33.9	6.5	n/a
HR-K8OXZL-01	1404	21.8 (34)	6.4 (21)	28.2	7.2	n/a
HR-55TCN6-01	1405	12.7 (34)	15.4 (21)	28.1	7.2	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-I1DTF2-01	1406	11.1 (34)	7.9 (21)	18.9	8.2	n/a
HR-P9ZP0R-01	1407	24.2 (34)	11.6 (21)	35.8	6.3	n/a
HR-DZKYEW-01	1408	17.8 (34)	6.8 (21)	24.6	7.6	n/a
HR-S9VY8K-01	1409	16.7 (34)	8.4 (21)	25.1	7.4	n/a
HR-Z4JRLP-01	1410	32.4 (34)	4.0 (21)	36.4	6.2	n/a
HR-NFZ6QX-01	1501	21.4 (34)	7.3 (21)	28.7	7.1	n/a
HR-NU1UL4-01	1502	29.1 (34)	6.7 (21)	35.8	6.3	n/a
HR-NW36AD-01	1503	15.3 (34)	18.8 (21)	34.1	6.4	n/a
HR-8XNAKT-01	1504	22.0 (34)	6.3 (21)	28.3	7.2	n/a
HR-B5TUL1-01	1505	12.9 (34)	15.3 (21)	28.2	7.2	n/a
HR-V0KL3V-01	1506	11.2 (34)	7.7 (21)	18.9	8.2	n/a
HR-4H98MO-01	1507	24.4 (34)	11.6 (21)	36.0	6.3	n/a
HR-13DWLP-01	1508	17.9 (34)	7.0 (21)	25.0	7.5	n/a
HR-ZSA3CE-01	1509	16.8 (34)	8.6 (21)	25.4	7.4	n/a
HR-VD8XCV-01	1510	32.2 (34)	4.0 (21)	36.2	6.2	n/a
HR-PJO2E4-01	1601	20.6 (34)	7.3 (21)	27.9	7.2	n/a
HR-R08SZT-01	1602	29.3 (34)	7.0 (21)	36.3	6.2	n/a
HR-D5LP3F-01	1603	15.3 (34)	18.2 (21)	33.5	6.6	n/a
HR-LWXP UU-01	1604	22.2 (34)	6.3 (21)	28.5	7.1	n/a
HR-81MXF5-01	1605	13.0 (34)	15.4 (21)	28.4	7.2	n/a
HR-UV0JRV-01	1606	11.4 (34)	7.7 (21)	19.1	8.2	n/a
HR-WBBZ0Y-01	1607	24.7 (34)	11.4 (21)	36.1	6.2	n/a
HR-YBRZDI-01	1608	18.1 (34)	7.1 (21)	25.2	7.4	n/a
HR-BLGWES-01	1609	16.8 (34)	8.9 (21)	25.7	7.4	n/a
HR-9Z63MX-01	1610	31.9 (34)	4.3 (21)	36.2	6.2	n/a
HR-NAZIF0-01	1701	20.6 (34)	7.3 (21)	27.9	7.2	n/a
HR-Q5LN26-01	1702	29.5 (34)	7.0 (21)	36.5	6.2	n/a
HR-6FRBFG-01	1703	15.4 (34)	17.9 (21)	33.4	6.6	n/a
HR-HR0K0Q-01	1704	22.4 (34)	6.3 (21)	28.7	7.1	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-0T8ZEE-01	1705	13.2 (34)	15.2 (21)	28.4	7.2	n/a
HR-KK9XFD-01	1706	11.5 (34)	7.8 (21)	19.3	8.2	n/a
HR-9E5L0I-01	1707	24.9 (34)	11.6 (21)	36.5	6.2	n/a
HR-Q0XKY0-01	1708	18.3 (34)	6.9 (21)	25.1	7.4	n/a
HR-ENUS2D-01	1709	16.8 (34)	9.1 (21)	25.9	7.4	n/a
HR-AOYTP8-01	1710	29.7 (34)	4.5 (21)	34.1	6.4	n/a
HR-0RSLSP-01	1801	20.5 (34)	7.3 (21)	27.9	7.2	n/a
HR-1B8FQR-01	1802	29.6 (34)	6.9 (21)	36.5	6.2	n/a
HR-4J39VG-01	1803	15.5 (34)	18.0 (21)	33.5	6.6	n/a
HR-L2HY5F-01	1804	22.5 (34)	6.2 (21)	28.8	7.1	n/a
HR-5ELRTO-01	1805	13.4 (34)	15.2 (21)	28.6	7.1	n/a
HR-9HNI2J-01	1806	11.6 (34)	7.8 (21)	19.4	8.2	n/a
HR-0FUDLY-01	1807	21.3 (34)	9.5 (21)	30.8	6.9	n/a
HR-ZZVASG-01	1808	18.4 (34)	7.1 (21)	25.5	7.4	n/a
HR-MIA3S1-01	1809	16.5 (34)	9.3 (21)	25.8	7.4	n/a
HR-28FNPB-01	1810	25.2 (34)	10.6 (21)	35.8	6.3	n/a
HR-AG0D3U-01	1901	20.9 (34)	7.3 (21)	28.1	7.2	n/a
HR-RFULDX-01	1902	30.6 (34)	6.1 (21)	36.7	6.2	n/a
HR-YXIVAA-01	1903	15.7 (34)	18.1 (21)	33.8	6.5	n/a
HR-DWVO9B-01	1904	22.7 (34)	6.2 (21)	28.9	7.1	n/a
HR-ZCNQHI-01	1905	13.5 (34)	15.1 (21)	28.6	7.1	n/a
HR-9YV51I-01	1906	11.7 (34)	7.7 (21)	19.5	8.2	n/a
HR-RLP06G-01	1907	25.3 (34)	11.5 (21)	36.8	6.2	n/a
HR-12O3G1-01	1908	18.6 (34)	6.8 (21)	25.3	7.4	n/a
HR-WHU283-01	1909	15.4 (34)	9.4 (21)	24.8	7.5	n/a
HR-Z6CI23-01	1910	14.6 (34)	10.1 (21)	24.7	7.5	n/a
HR-8L5LPG-01	2001	21.0 (34)	7.1 (21)	28.1	7.2	n/a
HR-418R69-01	2002	15.8 (34)	18.0 (21)	33.8	6.5	n/a
HR-20NRBH-01	2003	10.5 (34)	5.4 (21)	15.9	8.5	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-V71XB0-01	2004	26.1 (34)	11.5 (21)	37.6	6.1	n/a
HR-SK2WBH-01	2005	4.5 (34)	7.6 (21)	12.1	8.9	n/a
HR-XRVSB0-01	2006	21.7 (34)	9.6 (21)	31.3	6.8	n/a
HR-3TWGTW-01	2007	9.7 (34)	6.1 (21)	15.8	8.5	n/a
HR-DBVEWH-01	2008	15.5 (34)	9.3 (21)	24.8	7.5	n/a
HR-T4VMQG-01	201	23.4 (34)	10.4 (21)	33.8	6.5	n/a
HR-T3TICZ-01	202	15.6 (34)	16.0 (21)	31.6	6.8	n/a
HR-R5F1OH-01	203	11.4 (34)	10.2 (21)	21.5	7.9	n/a
HR-0HWVGD-01	2101	20.5 (34)	7.4 (21)	27.9	7.2	n/a
HR-WZLA1K-01	2102	30.5 (34)	6.8 (21)	37.3	6.1	n/a
HR-BBJBYA-01	2103	15.9 (34)	18.0 (21)	33.9	6.5	n/a
HR-FZCRDX-01	2104	23.0 (34)	6.3 (21)	29.3	7.1	n/a
HR-OMTQS5-01	2105	13.8 (34)	15.1 (21)	28.8	7.1	n/a
HR-HAZKBF-01	2106	12.0 (34)	7.8 (21)	19.7	8.1	n/a
HR-ZHZY7C-01	2107	25.5 (34)	11.3 (21)	36.8	6.2	n/a
HR-OYLE6D-01	2108	18.7 (34)	6.6 (21)	25.4	7.4	n/a
HR-YY51FX-01	2109	15.5 (34)	9.2 (21)	24.7	7.5	n/a
HR-ULHH8J-01	2110	14.8 (34)	10.9 (21)	25.7	7.4	n/a
HR-8Y5L76-01	2201	19.1 (34)	10.5 (21)	29.5	7.0	n/a
HR-DRCQ9R-01	2202	29.7 (34)	7.0 (21)	36.7	6.2	n/a
HR-JGNO9D-01	2203	15.4 (34)	17.3 (21)	32.7	6.7	n/a
HR-SKT1Z2-01	2204	21.5 (34)	10.8 (21)	32.3	6.7	n/a
HR-Q9F2BP-01	2205	13.1 (34)	12.4 (21)	25.5	7.4	n/a
HR-NU8HP1-01	2206	12.1 (34)	7.8 (21)	19.9	8.1	n/a
HR-MC1WTI-01	2207	20.4 (34)	12.0 (21)	32.3	6.7	n/a
HR-KPJUCT-01	2208	16.9 (34)	13.0 (21)	29.9	7.0	n/a
HR-88LK50-01	2209	12.8 (34)	8.6 (21)	21.4	7.9	n/a
HR-2YIIAJ-01	2210	14.5 (34)	9.6 (21)	24.1	7.6	n/a
HR-NEPYSG-01	2301	21.2 (34)	7.5 (21)	28.7	7.1	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-SI4E01-01	2302	30.6 (34)	6.7 (21)	37.4	6.1	n/a
HR-FFCV6N-01	2303	16.8 (34)	18.1 (21)	34.8	6.4	n/a
HR-J1ZNO8-01	2304	23.8 (34)	6.3 (21)	30.1	6.9	n/a
HR-DG105I-01	2305	14.5 (34)	14.8 (21)	29.3	7.1	n/a
HR-P4QPT9-01	2306	12.4 (34)	7.8 (21)	20.2	8.1	n/a
HR-T6XEOB-01	2307	26.6 (34)	8.1 (21)	34.6	6.4	n/a
HR-NERQD3-01	2308	19.4 (34)	7.1 (21)	26.6	7.3	n/a
HR-K6IHFH-01	2309	15.6 (34)	9.4 (21)	25.0	7.4	n/a
HR-LM2MYJ-01	2310	13.8 (34)	11.4 (21)	25.2	7.4	n/a
HR-8Y499Q-01	2401	21.2 (34)	7.5 (21)	28.7	7.1	n/a
HR-J0DAWY-01	2402	31.0 (34)	6.6 (21)	37.7	6.0	n/a
HR-Z4TWD3-01	2403	16.7 (34)	17.9 (21)	34.6	6.4	n/a
HR-5PUQ2P-01	2404	23.7 (34)	6.2 (21)	29.9	7.0	n/a
HR-RZWGDU-01	2405	14.3 (34)	14.6 (21)	29.0	7.1	n/a
HR-CUKFSC-01	2406	12.4 (34)	7.5 (21)	19.9	8.1	n/a
HR-RQJJ2M-01	2407	26.4 (34)	8.3 (21)	34.7	6.4	n/a
HR-7V4LOX-01	2408	19.3 (34)	7.0 (21)	26.3	7.4	n/a
HR-O8E3P6-01	2409	15.5 (34)	9.3 (21)	24.8	7.5	n/a
HR-82NI7Y-01	2410	13.6 (34)	10.8 (21)	24.4	7.6	n/a
HR-QT4RZ9-01	2501	21.3 (34)	7.5 (21)	28.8	7.1	n/a
HR-JDQCL9-01	2502	31.1 (34)	6.6 (21)	37.7	6.0	n/a
HR-ELN2IK-01	2503	16.8 (34)	17.9 (21)	34.7	6.4	n/a
HR-739P XK-01	2504	23.9 (34)	6.2 (21)	30.1	6.9	n/a
HR-D0Y8MY-01	2505	14.5 (34)	14.6 (21)	29.1	7.1	n/a
HR-BFCX5H-01	2506	12.5 (34)	7.6 (21)	20.1	8.1	n/a
HR-FK52X7-01	2507	26.6 (34)	8.3 (21)	34.9	6.4	n/a
HR-HCFVT6-01	2508	19.5 (34)	7.0 (21)	26.4	7.4	n/a
HR-AS5M0S-01	2509	15.6 (34)	9.3 (21)	24.9	7.5	n/a
HR-Y8RYNF-01	2510	13.8 (34)	10.9 (21)	24.7	7.5	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-PGJ532-01	2601	21.0 (34)	7.5 (21)	28.5	7.2	n/a
HR-5FBXTB-01	2602	31.3 (34)	6.6 (21)	37.9	6.0	n/a
HR-K25OHW-01	2603	16.8 (34)	17.9 (21)	34.7	6.4	n/a
HR-KGOWHY-01	2604	23.9 (34)	6.2 (21)	30.1	6.9	n/a
HR-I9FA53-01	2605	14.5 (34)	14.6 (21)	29.1	7.1	n/a
HR-3PKIYY-01	2606	12.5 (34)	7.6 (21)	20.1	8.1	n/a
HR-HXC7O3-01	2607	26.6 (34)	8.3 (21)	34.9	6.4	n/a
HR-9GMF4F-01	2608	19.5 (34)	7.0 (21)	26.5	7.4	n/a
HR-5IZOS0-01	2609	15.6 (34)	9.3 (21)	24.8	7.5	n/a
HR-T6AZ4N-01	2610	13.8 (34)	11.0 (21)	24.7	7.5	n/a
HR-VFZE8F-01	2701	21.6 (34)	7.4 (21)	29.0	7.1	n/a
HR-5SSIGL-01	2702	19.5 (34)	7.5 (21)	27.0	7.3	n/a
HR-APMKNH-01	2703	17.0 (34)	17.8 (21)	34.8	6.4	n/a
HR-8DESAS-01	2704	24.1 (34)	6.1 (21)	30.2	6.9	n/a
HR-GCKBKZ-01	2705	14.6 (34)	14.6 (21)	29.2	7.1	n/a
HR-7QJWL2-01	2706	12.7 (34)	7.6 (21)	20.2	8.1	n/a
HR-921MTA-01	2707	26.8 (34)	8.1 (21)	34.9	6.4	n/a
HR-8T4O6C-01	2708	19.6 (34)	7.0 (21)	26.7	7.3	n/a
HR-2LMDN6-01	2709	15.7 (34)	9.3 (21)	25.0	7.5	n/a
HR-LVH1PR-01	2710	13.8 (34)	10.9 (21)	24.7	7.5	n/a
HR-830VY8-01	2801	21.7 (34)	7.3 (21)	29.0	7.1	n/a
HR-LN320G-01	2802	19.7 (34)	7.6 (21)	27.3	7.3	n/a
HR-SU85CH-01	2803	17.1 (34)	17.8 (21)	34.8	6.4	n/a
HR-E3B9Y2-01	2804	24.3 (34)	6.1 (21)	30.4	6.9	n/a
HR-G6IUVL-01	2805	14.8 (34)	14.7 (21)	29.5	7.1	n/a
HR-WHEW3B-01	2806	12.8 (34)	7.3 (21)	20.2	8.1	n/a
HR-JNVWT5-01	2807	27.0 (34)	8.1 (21)	35.2	6.4	n/a
HR-RHSNRP-01	2808	19.8 (34)	6.9 (21)	26.7	7.3	n/a
HR-ACS4WM-01	2809	15.8 (34)	9.3 (21)	25.0	7.4	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-9GUPLE-01	2810	14.0 (34)	10.8 (21)	24.8	7.5	n/a
HR-6LPZLC-01	2901	21.7 (34)	7.6 (21)	29.2	7.1	n/a
HR-RAQ1CP-01	2902	20.1 (34)	8.8 (21)	29.0	7.1	n/a
HR-4W07EN-01	2903	17.1 (34)	17.8 (21)	34.9	6.4	n/a
HR-NZCDWO-01	2904	24.3 (34)	6.1 (21)	30.4	6.9	n/a
HR-T6LY1V-01	2905	14.8 (34)	14.7 (21)	29.4	7.1	n/a
HR-TIZKSV-01	2906	12.8 (34)	7.5 (21)	20.3	8.1	n/a
HR-TXCQZR-01	2907	27.0 (34)	8.1 (21)	35.2	6.4	n/a
HR-9IERSJ-01	2908	19.8 (34)	7.0 (21)	26.9	7.3	n/a
HR-7NYDQE-01	2909	15.8 (34)	9.3 (21)	25.0	7.4	n/a
HR-MK6OHH-01	2910	14.0 (34)	10.4 (21)	24.4	7.6	n/a
HR-3PJ7AL-01	3001	20.3 (34)	7.6 (21)	27.8	7.2	n/a
HR-1Y1SK0-01	3002	17.1 (34)	17.8 (21)	34.8	6.4	n/a
HR-79AZWT-01	3003	17.2 (34)	17.7 (21)	34.9	6.4	n/a
HR-48YHM1-01	3004	13.2 (34)	5.5 (21)	18.7	8.2	n/a
HR-6OMEF7-01	3005	14.8 (34)	14.7 (21)	29.5	7.1	n/a
HR-QN27SP-01	3006	5.0 (34)	7.9 (21)	12.9	8.9	n/a
HR-3NIAO2-01	3007	14.1 (34)	8.4 (21)	22.5	7.8	n/a
HR-NNDMYE-01	3008	19.8 (34)	6.9 (21)	26.7	7.3	n/a
HR-WBQ7SD-01	3009	15.9 (34)	9.3 (21)	25.1	7.4	n/a
HR-WBUK4S-01	301	21.5 (34)	11.3 (21)	32.8	6.6	n/a
HR-QZ54LZ-01	3010	14.1 (34)	10.6 (21)	24.7	7.5	n/a
HR-3NB95F-01	302	31.9 (34)	5.3 (21)	37.2	6.1	n/a
HR-S7T0TL-01	303	24.7 (34)	6.7 (21)	31.4	6.8	n/a
HR-1APTXP-01	304	23.8 (34)	10.1 (21)	33.9	6.5	n/a
HR-34HVAJ-01	3101	19.8 (34)	9.6 (21)	29.4	7.1	n/a
HR-NZ80R4-01	3102	25.9 (34)	7.3 (21)	33.2	6.6	n/a
HR-3SNM9B-01	3103	18.3 (34)	17.0 (21)	35.4	6.3	n/a
HR-WKW6R0-01	3104	22.8 (34)	10.2 (21)	33.1	6.6	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-QEQSUQ-01	3105	14.2 (34)	12.3 (21)	26.4	7.4	n/a
HR-1HD3N7-01	3106	13.1 (34)	7.6 (21)	20.7	8.0	n/a
HR-MU7F13-01	3107	21.8 (34)	7.3 (21)	29.1	7.1	n/a
HR-UFRHZS-01	3108	17.8 (34)	12.8 (21)	30.6	6.9	n/a
HR-9L5WZD-01	3109	13.2 (34)	8.6 (21)	21.7	7.9	n/a
HR-UGSU6L-01	3110	14.0 (34)	9.6 (21)	23.6	7.7	n/a
HR-WZN64Q-01	3201	20.6 (33)	10.2 (20)	30.9	6.9	n/a
HR-BKTQ0Q-01	3202	20.2 (33)	8.4 (20)	28.6	7.1	n/a
HR-YT1G1Q-01	3203	17.3 (33)	18.0 (20)	35.2	6.3	n/a
HR-BEA6KC-01	3204	24.6 (33)	11.8 (20)	36.3	6.2	n/a
HR-WPKOCS-01	3205	15.2 (33)	14.3 (20)	29.5	7.0	n/a
HR-MWVIVQ-01	3206	13.3 (33)	7.9 (20)	21.2	7.9	n/a
HR-YKLOQG-01	3207	26.7 (33)	10.2 (20)	36.8	6.1	n/a
HR-H8PO1J-01	3208	19.5 (33)	14.1 (20)	33.6	6.5	n/a
HR-NSTUD8-01	3209	16.6 (33)	9.4 (20)	26.0	7.4	n/a
HR-KXJXB4-01	3210	16.1 (33)	10.8 (20)	26.9	7.3	n/a
HR-DE4MT1-01	3301	20.5 (34)	5.2 (21)	25.7	7.4	n/a
HR-36Y1KV-01	3302	31.5 (34)	6.0 (21)	37.5	6.1	n/a
HR-9BBKH7-01	3303	16.7 (34)	16.6 (21)	33.3	6.6	n/a
HR-FTJTPD-01	3304	12.4 (34)	9.0 (21)	21.5	7.9	n/a
HR-5MYT1O-01	3305	16.2 (34)	10.9 (21)	27.2	7.3	n/a
HR-12BLEE-01	3307	10.3 (34)	10.4 (21)	20.7	8.0	n/a
HR-O2PWWN-01	3308	7.2 (34)	8.9 (21)	16.1	8.4	n/a
HR-P606U7-01	3401	20.6 (34)	5.3 (21)	25.9	7.4	n/a
HR-RDU82W-01	3403	17.0 (34)	16.9 (21)	33.9	6.5	n/a
HR-1H1QC8-01	3404	12.7 (34)	8.5 (21)	21.2	7.9	n/a
HR-GGT6YO-01	3405	16.9 (34)	10.2 (21)	27.1	7.3	n/a
HR-UNGLTD-01	3406	5.6 (34)	13.4 (21)	19.0	8.2	n/a
HR-VG5UY0-01	3407	10.3 (34)	10.0 (21)	20.3	8.1	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-R5NNF6-01	3408	7.3 (34)	8.8 (21)	16.1	8.4	n/a
HR-UA22KU-01	3501	20.8 (34)	5.3 (21)	26.1	7.4	n/a
HR-8X31R2-01	3502	29.5 (34)	6.0 (21)	35.6	6.3	n/a
HR-IYO4CO-01	3503	17.1 (34)	17.2 (21)	34.2	6.4	n/a
HR-AWR29Y-01	3504	12.9 (34)	8.4 (21)	21.3	7.9	n/a
HR-YHGIIG-01	3505	17.1 (34)	10.2 (21)	27.2	7.3	n/a
HR-VTOLMC-01	3506	5.7 (34)	13.0 (21)	18.6	8.2	n/a
HR-0I77IJ-01	3507	10.4 (34)	9.8 (21)	20.2	8.1	n/a
HR-BGAJFS-01	3508	7.4 (34)	8.8 (21)	16.2	8.4	n/a
HR-D9T4TI-01	3601	20.8 (34)	5.2 (21)	26.0	7.4	n/a
HR-WEKEPU-01	3602	29.3 (34)	6.1 (21)	35.4	6.3	n/a
HR-DNC4P8-01	3603	17.1 (34)	17.2 (21)	34.3	6.4	n/a
HR-JARLJW-01	3604	12.9 (34)	8.3 (21)	21.2	7.9	n/a
HR-L15X5M-01	3605	17.1 (34)	10.2 (21)	27.2	7.3	n/a
HR-EOIDKN-01	3606	5.7 (34)	12.9 (21)	18.6	8.2	n/a
HR-XID9VF-01	3607	10.4 (34)	10.0 (21)	20.4	8.1	n/a
HR-54I49O-01	3608	7.4 (34)	8.8 (21)	16.2	8.4	n/a
HR-8N9MHX-01	3701	20.9 (34)	5.3 (21)	26.2	7.4	n/a
HR-80GNHT-01	3702	29.7 (34)	6.0 (21)	35.7	6.3	n/a
HR-8PKFU4-01	3703	17.2 (34)	17.2 (21)	34.4	6.4	n/a
HR-INNC29-01	3704	13.0 (34)	8.3 (21)	21.3	7.9	n/a
HR-PF7MYL-01	3705	17.2 (34)	10.1 (21)	27.3	7.3	n/a
HR-6CJBOM-01	3706	5.8 (34)	13.2 (21)	19.0	8.2	n/a
HR-U4CMHE-01	3707	10.5 (34)	10.0 (21)	20.5	8.1	n/a
HR-FEX4KC-01	3708	7.5 (34)	8.8 (21)	16.3	8.4	n/a
HR-UHGLFX-01	3801	20.9 (34)	5.2 (21)	26.1	7.4	n/a
HR-SC0YL9-01	3802	29.6 (34)	6.0 (21)	35.7	6.3	n/a
HR-LQZUTW-01	3803	17.2 (34)	16.9 (21)	34.1	6.4	n/a
HR-TG5XDF-01	3804	13.0 (34)	8.3 (21)	21.3	7.9	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-AP007B-01	3805	17.2 (34)	10.1 (21)	27.3	7.3	n/a
HR-S059UU-01	3806	5.8 (34)	12.9 (21)	18.7	8.2	n/a
HR-0CQ0K9-01	3807	10.4 (34)	10.3 (21)	20.7	8.0	n/a
HR-VX5K8E-01	3808	7.5 (34)	8.8 (21)	16.4	8.4	n/a
HR-RBIM0C-01	3901	21.0 (34)	5.3 (21)	26.3	7.4	n/a
HR-6ZKKHN-01	3902	29.6 (34)	6.4 (21)	36.0	6.3	n/a
HR-0YH4F3-01	3903	17.3 (34)	17.0 (21)	34.3	6.4	n/a
HR-XRH725-01	3904	13.1 (34)	8.2 (21)	21.3	7.9	n/a
HR-EA6S9H-01	3905	17.4 (34)	10.1 (21)	27.4	7.3	n/a
HR-HEINZB-01	3906	5.9 (34)	12.9 (21)	18.8	8.2	n/a
HR-GN9C8E-01	3907	10.5 (34)	10.3 (21)	20.8	8.0	n/a
HR-1EFIKB-01	3908	7.7 (34)	8.9 (21)	16.6	8.4	n/a
HR-NE33RD-01	4001	21.0 (34)	5.3 (21)	26.4	7.4	n/a
HR-NYZRUR-01	4002	17.3 (34)	16.9 (21)	34.2	6.4	n/a
HR-72N3U5-01	4003	13.1 (34)	8.1 (21)	21.3	7.9	n/a
HR-0YK978-01	4004	17.4 (34)	10.1 (21)	27.4	7.3	n/a
HR-TIH6ZI-01	4005	5.9 (34)	12.8 (21)	18.7	8.2	n/a
HR-UTLV10-01	4006	10.6 (34)	9.5 (21)	20.2	8.1	n/a
HR-71MWKQ-01	401	23.1 (34)	7.0 (21)	30.0	6.9	n/a
HR-TMLLQT-01	402	24.6 (34)	12.4 (21)	37.0	6.1	n/a
HR-9RZSGJ-01	403	18.6 (34)	9.4 (21)	28.0	7.2	n/a
HR-T277JJ-01	404	22.8 (34)	10.6 (21)	33.5	6.6	n/a
HR-KF2W8Y-01	405	13.2 (34)	9.8 (21)	23.0	7.8	n/a
HR-AGKVVZ-01	406	13.3 (34)	14.0 (21)	27.3	7.3	n/a
HR-N0SF3K-01	407	20.1 (34)	5.4 (21)	25.6	7.4	n/a
HR-57REY8-01	408	12.5 (34)	6.2 (21)	18.7	8.2	n/a
HR-9KDR66-01	409	19.2 (34)	5.1 (21)	24.2	7.6	n/a
HR-OD1RQV-01	410	23.5 (34)	7.4 (21)	30.9	6.9	n/a
HR-CNRAMQ-01	4101	21.2 (34)	5.3 (21)	26.5	7.4	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-1EK6VR-01	4102	29.6 (34)	6.1 (21)	35.7	6.3	n/a
HR-F0S4JC-01	4103	17.5 (34)	17.1 (21)	34.6	6.4	n/a
HR-BHUUAT-01	4104	13.2 (34)	8.1 (21)	21.3	7.9	n/a
HR-GCC081-01	4105	17.6 (34)	10.0 (21)	27.6	7.2	n/a
HR-UM7R2K-01	4106	6.0 (34)	12.9 (21)	18.8	8.2	n/a
HR-YEAU4B-01	4107	10.7 (34)	10.4 (21)	21.1	7.9	n/a
HR-PLQ105-01	4108	7.7 (34)	8.9 (21)	16.6	8.4	n/a
HR-LU9I84-01	411	20.1 (34)	14.4 (21)	34.5	6.4	n/a
HR-RLFG1G-01	4201	21.2 (34)	5.3 (21)	26.5	7.4	n/a
HR-O5LN4D-01	4202	29.8 (34)	6.0 (21)	35.8	6.3	n/a
HR-L2DKXI-01	4203	23.3 (34)	10.5 (21)	33.8	6.5	n/a
HR-L42C0C-01	4204	16.1 (34)	9.1 (21)	25.2	7.4	n/a
HR-JRP79O-01	4205	18.9 (34)	10.5 (21)	29.4	7.1	n/a
HR-3A33QS-01	4206	11.6 (34)	15.5 (21)	27.2	7.3	n/a
HR-MPS5TO-01	4207	21.9 (34)	12.8 (21)	34.7	6.4	n/a
HR-ONRZSU-01	4208	7.7 (34)	9.0 (21)	16.8	8.4	n/a
HR-WHL8T2-01	4301	21.3 (34)	5.3 (21)	26.6	7.3	n/a
HR-LQE3MG-01	4302	29.5 (34)	6.0 (21)	35.5	6.3	n/a
HR-TJKMAY-01	4303	26.2 (34)	10.7 (21)	36.9	6.1	n/a
HR-T8K7X0-01	4304	22.4 (34)	9.8 (21)	32.2	6.7	n/a
HR-H0TNY4-01	4305	8.0 (34)	9.2 (21)	17.2	8.4	n/a
HR-Y81VP2-01	4401	21.3 (34)	5.3 (21)	26.6	7.3	n/a
HR-F7FG5I-01	4402	29.7 (34)	6.0 (21)	35.7	6.3	n/a
HR-U0XS2M-01	4403	23.8 (34)	6.7 (21)	30.5	6.9	n/a
HR-K8EBU2-01	4404	16.4 (34)	6.4 (21)	22.8	7.8	n/a
HR-73TVDH-01	4405	16.3 (34)	11.9 (21)	28.2	7.2	n/a
HR-A5Y2SF-01	4406	8.0 (34)	8.1 (21)	16.1	8.4	n/a
HR-PKDWKG-01	4501	21.5 (34)	5.4 (21)	26.9	7.3	n/a
HR-ZAG8BR-01	4502	30.1 (34)	6.0 (21)	36.1	6.2	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-7QGCJ7-01	4503	21.6 (34)	16.2 (21)	37.8	6.0	n/a
HR-8P2TVJ-01	4504	15.9 (34)	7.9 (21)	23.8	7.7	n/a
HR-CFICZX-01	4505	21.3 (34)	9.6 (21)	30.8	6.9	n/a
HR-T7TEOT-01	4506	6.8 (34)	12.7 (21)	19.5	8.2	n/a
HR-1DWWEH-01	4507	11.4 (34)	10.1 (21)	21.6	7.9	n/a
HR-TWZVU1-01	4508	8.1 (34)	9.2 (21)	17.3	8.4	n/a
HR-M3PHK0-01	4601	21.8 (34)	5.5 (21)	27.3	7.3	n/a
HR-ETJDPI-01	4602	30.3 (34)	6.2 (21)	36.4	6.2	n/a
HR-1XINIO-01	4603	17.9 (34)	16.5 (21)	34.4	6.4	n/a
HR-24UA9T-01	4604	13.8 (34)	9.1 (21)	22.8	7.8	n/a
HR-MBXWF7-01	4605	18.0 (34)	10.6 (21)	28.6	7.1	n/a
HR-IPN29L-01	4607	11.2 (34)	10.4 (21)	21.6	7.9	n/a
HR-C5W03N-01	4608	8.4 (34)	9.0 (21)	17.4	8.4	n/a
HR-GHY7QU-01	4701	21.6 (34)	5.3 (21)	26.9	7.3	n/a
HR-EU7NDU-01	4703	17.8 (34)	16.7 (21)	34.5	6.4	n/a
HR-H1IADU-01	4704	13.6 (34)	8.0 (21)	21.7	7.9	n/a
HR-KBJVTI-01	4705	18.1 (34)	10.0 (21)	28.1	7.2	n/a
HR-YBSNDE-01	4706	6.2 (34)	12.7 (21)	18.9	8.2	n/a
HR-JM1N35-01	4707	10.8 (34)	10.3 (21)	21.1	7.9	n/a
HR-364J0X-01	4708	15.3 (34)	14.1 (21)	29.4	7.1	n/a
HR-RHHG68-01	4801	21.6 (34)	5.4 (21)	26.9	7.3	n/a
HR-UA9M4R-01	4802	30.1 (34)	6.0 (21)	36.1	6.2	n/a
HR-GTUOT9-01	4803	17.8 (34)	16.7 (21)	34.5	6.4	n/a
HR-QZM81L-01	4804	13.6 (34)	8.0 (21)	21.7	7.9	n/a
HR-VVKHCP-01	4805	18.1 (34)	9.9 (21)	28.0	7.2	n/a
HR-RWRWNX-01	4806	6.2 (34)	12.7 (21)	18.9	8.2	n/a
HR-CP0C8Z-01	4807	10.8 (34)	10.6 (21)	21.4	7.9	n/a
HR-W478C0-01	4901	21.7 (34)	5.4 (21)	27.1	7.3	n/a
HR-WSJHSJ-01	4902	29.9 (34)	6.0 (21)	35.9	6.3	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-2LDMVZ-01	4903	18.0 (34)	16.5 (21)	34.4	6.4	n/a
HR-XTSK6Z-01	4904	13.8 (34)	8.0 (21)	21.8	7.9	n/a
HR-RAOXWU-01	4905	18.3 (34)	9.9 (21)	28.2	7.2	n/a
HR-GNZI39-01	4906	6.3 (34)	12.6 (21)	18.9	8.2	n/a
HR-D9K7H2-01	4907	10.9 (34)	10.1 (21)	21.0	7.9	n/a
HR-3O0ULE-01	4908	16.2 (34)	7.9 (21)	24.2	7.6	n/a
HR-6U516U-01	5001	21.7 (34)	5.3 (21)	27.0	7.3	n/a
HR-KZXUMI-01	5002	30.1 (34)	6.0 (21)	36.2	6.2	n/a
HR-UUAI12-01	5003	18.0 (34)	16.5 (21)	34.5	6.4	n/a
HR-34YTHR-01	5004	13.8 (34)	8.0 (21)	21.8	7.9	n/a
HR-TJYM5T-01	5005	18.3 (34)	9.9 (21)	28.1	7.2	n/a
HR-42FNKF-01	5006	6.3 (34)	12.6 (21)	19.0	8.2	n/a
HR-TJBZW3-01	5007	10.9 (34)	10.2 (21)	21.1	7.9	n/a
HR-3G0VW1-01	5008	8.2 (34)	8.8 (21)	17.0	8.4	n/a
HR-NIDBM0-01	501	23.1 (34)	7.1 (21)	30.2	6.9	n/a
HR-NLP6Q3-01	502	23.2 (34)	9.7 (21)	32.9	6.6	n/a
HR-FSQUH9-01	503	19.0 (34)	9.2 (21)	28.2	7.2	n/a
HR-R92TH8-01	504	23.4 (34)	10.5 (21)	33.9	6.5	n/a
HR-P6K6K6-01	505	12.0 (34)	9.9 (21)	21.9	7.9	n/a
HR-XV09BU-01	506	10.4 (34)	14.5 (21)	24.9	7.5	n/a
HR-CNO5OX-01	507	32.0 (34)	4.6 (21)	36.5	6.2	n/a
HR-0CK4OV-01	508	8.4 (34)	6.5 (21)	14.8	8.6	n/a
HR-LHWUMR-01	509	30.1 (34)	6.6 (21)	36.8	6.2	n/a
HR-CUFPAF-01	510	20.3 (34)	7.5 (21)	27.8	7.2	n/a
HR-WYJP36-01	5101	21.8 (34)	5.3 (21)	27.2	7.3	n/a
HR-Q9KK6R-01	5102	30.4 (34)	6.0 (21)	36.4	6.2	n/a
HR-HJLOV9-01	5103	18.1 (34)	16.5 (21)	34.6	6.4	n/a
HR-V4SVAW-01	5104	13.9 (34)	8.0 (21)	21.9	7.9	n/a
HR-Y4YS0Z-01	5105	18.4 (34)	9.9 (21)	28.3	7.2	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-DD9PAC-01	5106	6.4 (34)	13.0 (21)	19.4	8.2	n/a
HR-ANN5G2-01	5107	11.0 (34)	10.0 (21)	21.1	7.9	n/a
HR-ZC348F-01	5108	8.4 (34)	8.8 (21)	17.2	8.4	n/a
HR-VEECFZ-01	511	19.5 (34)	14.0 (21)	33.4	6.6	n/a
HR-UIEQT0-01	5201	22.2 (34)	8.3 (21)	30.5	6.9	n/a
HR-9O2FB0-01	5202	30.4 (34)	6.0 (21)	36.4	6.2	n/a
HR-KVJHT6-01	5203	18.7 (34)	17.5 (21)	36.2	6.2	n/a
HR-H6UBST-01	5204	18.3 (34)	12.7 (21)	31.0	6.9	n/a
HR-MA9LHO-01	5205	19.8 (34)	15.0 (21)	34.9	6.4	n/a
HR-8WXT5K-01	5206	8.6 (34)	15.6 (21)	24.2	7.6	n/a
HR-U6CATI-01	5207	18.6 (34)	13.5 (21)	32.1	6.7	n/a
HR-JIAH4B-01	5208	15.6 (34)	13.9 (21)	29.4	7.1	n/a
HR-CX6Y1U-01	5301	22.3 (34)	5.5 (21)	27.8	7.2	n/a
HR-NY8W89-01	5302	30.4 (34)	6.0 (21)	36.4	6.2	n/a
HR-188AB1-01	5303	18.2 (34)	16.4 (21)	34.7	6.4	n/a
HR-JUF4RL-01	5304	14.6 (34)	8.2 (21)	22.8	7.8	n/a
HR-AOASP2-01	5305	19.3 (34)	9.6 (21)	28.8	7.1	n/a
HR-MC6Q0R-01	5306	6.9 (34)	12.0 (21)	18.9	8.2	n/a
HR-3D8UJU-01	5307	11.7 (34)	10.3 (21)	21.9	7.9	n/a
HR-J26VUJ-01	5401	22.3 (34)	8.2 (21)	30.6	6.9	n/a
HR-YG9W0F-01	5402	30.5 (34)	6.0 (21)	36.5	6.2	n/a
HR-EHO69I-01	5403	18.9 (34)	17.4 (21)	36.3	6.2	n/a
HR-69WR1T-01	5404	18.4 (34)	12.6 (21)	31.0	6.9	n/a
HR-TAQHTB-01	5405	20.0 (34)	14.9 (21)	34.9	6.4	n/a
HR-ZP4WOL-01	5406	8.7 (34)	15.9 (21)	24.5	7.6	n/a
HR-YP4AJ6-01	5407	18.6 (34)	12.8 (21)	31.4	6.8	n/a
HR-I16GGW-01	5408	18.6 (34)	12.4 (21)	31.0	6.9	n/a
HR-5GYAA5-01	5501	22.3 (34)	5.5 (21)	27.8	7.2	n/a
HR-CN4CTN-01	5502	30.3 (34)	6.0 (21)	36.2	6.2	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-MMN6TE-01	5503	18.1 (34)	16.3 (21)	34.4	6.4	n/a
HR-LRPC39-01	5504	14.4 (34)	8.0 (21)	22.5	7.8	n/a
HR-J5GNXC-01	5505	19.1 (34)	9.5 (21)	28.7	7.1	n/a
HR-NBJPG7-01	5506	6.8 (34)	12.3 (21)	19.1	8.2	n/a
HR-GBERJK-01	5507	11.6 (34)	10.6 (21)	22.3	7.8	n/a
HR-R54PNV-01	5508	8.8 (34)	8.9 (21)	17.7	8.3	n/a
HR-D95X7R-01	5601	22.1 (34)	5.4 (21)	27.5	7.3	n/a
HR-H4LYYT-01	5602	30.2 (34)	6.0 (21)	36.2	6.2	n/a
HR-29U741-01	5603	18.1 (34)	16.1 (21)	34.3	6.4	n/a
HR-W195W7-01	5604	13.9 (34)	8.6 (21)	22.5	7.8	n/a
HR-PBCQAF-01	5605	18.2 (34)	11.0 (21)	29.2	7.1	n/a
HR-FTW051-01	5606	6.5 (34)	11.2 (21)	17.7	8.3	n/a
HR-Y381LQ-01	5607	11.2 (34)	10.2 (21)	21.4	7.9	n/a
HR-WE1G76-01	5608	8.5 (34)	8.8 (21)	17.3	8.4	n/a
HR-BFYVNU-01	5701	22.1 (34)	5.4 (21)	27.5	7.3	n/a
HR-ZH206B-01	5702	30.0 (34)	5.9 (21)	35.9	6.3	n/a
HR-RTVKZP-01	5703	18.1 (34)	16.1 (21)	34.2	6.4	n/a
HR-RNZ384-01	5704	13.9 (34)	8.6 (21)	22.5	7.8	n/a
HR-NLM83Z-01	5705	18.2 (34)	11.0 (21)	29.2	7.1	n/a
HR-UU8080-01	5706	6.5 (34)	11.2 (21)	17.7	8.3	n/a
HR-7MBQQF-01	5707	11.3 (34)	10.1 (21)	21.4	7.9	n/a
HR-UHAFTU-01	5708	15.7 (34)	13.5 (21)	29.2	7.1	n/a
HR-01IOBT-01	5801	22.2 (34)	5.4 (21)	27.6	7.2	n/a
HR-5JVQT2-01	5802	30.7 (34)	5.9 (21)	36.6	6.2	n/a
HR-2YYXHU-01	5803	18.2 (34)	15.9 (21)	34.1	6.4	n/a
HR-2B43CF-01	5804	14.0 (34)	8.6 (21)	22.7	7.8	n/a
HR-7OQAV3-01	5805	18.4 (34)	11.0 (21)	29.4	7.1	n/a
HR-P9GEMJ-01	5806	6.6 (34)	11.6 (21)	18.1	8.3	n/a
HR-JDAO7B-01	5807	11.2 (34)	10.2 (21)	21.4	7.9	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-GD3NDB-01	5901	27.7 (34)	8.1 (21)	35.8	6.3	n/a
HR-L89XKG-01	5902	25.6 (34)	6.8 (21)	32.4	6.7	n/a
HR-RGCMU6-01	5903	27.1 (34)	10.8 (21)	37.8	6.0	n/a
HR-36KI6P-01	5904	23.1 (34)	12.8 (21)	35.9	6.3	n/a
HR-XBOZ2H-01	5905	15.9 (34)	12.6 (21)	28.5	7.1	n/a
HR-FD6Q9D-01	5906	14.5 (34)	16.6 (21)	31.1	6.9	n/a
HR-JSU4QC-01	5907	22.5 (34)	11.8 (21)	34.3	6.4	n/a
HR-UHB59G-01	5908	21.9 (34)	11.2 (21)	33.1	6.6	n/a
HR-X9BYXD-01	601	26.2 (34)	7.6 (21)	33.8	6.5	n/a
HR-NHV025-01	602	23.6 (34)	9.6 (21)	33.3	6.6	n/a
HR-6M9QL8-01	603	19.3 (34)	9.2 (21)	28.5	7.1	n/a
HR-50B1XF-01	604	24.0 (34)	10.3 (21)	34.4	6.4	n/a
HR-JE116G-01	605	12.4 (34)	9.7 (21)	22.1	7.9	n/a
HR-3SIN1H-01	606	10.8 (34)	14.3 (21)	25.1	7.4	n/a
HR-7IKFMM-01	607	32.7 (34)	5.0 (21)	37.7	6.0	n/a
HR-AV9L7Q-01	608	8.9 (34)	6.4 (21)	15.3	8.6	n/a
HR-FKO5KI-01	609	31.0 (34)	4.5 (21)	35.5	6.3	n/a
HR-H96N73-01	610	20.7 (34)	8.0 (21)	28.7	7.1	n/a
HR-PD9B3E-01	611	20.3 (34)	14.1 (21)	34.4	6.4	n/a
HR-13EW5J-01	701	24.2 (34)	7.2 (21)	31.4	6.8	n/a
HR-TT9FFV-01	702	24.3 (34)	9.4 (21)	33.8	6.5	n/a
HR-2KS4LZ-01	703	19.8 (34)	9.2 (21)	29.1	7.1	n/a
HR-DKKQ0B-01	704	24.8 (34)	11.5 (21)	36.3	6.2	n/a
HR-L9YTKD-01	705	13.2 (34)	9.5 (21)	22.7	7.8	n/a
HR-3XQ1EI-01	706	11.3 (34)	14.1 (21)	25.3	7.4	n/a
HR-64E9W9-01	707	18.7 (34)	6.8 (21)	25.5	7.4	n/a
HR-P5BK6T-01	708	9.3 (34)	6.4 (21)	15.8	8.5	n/a
HR-76WMRG-01	709	31.8 (34)	4.8 (21)	36.6	6.2	n/a
HR-FTBBKX-01	710	21.2 (34)	8.1 (21)	29.3	7.1	n/a

Summary of all dwellings

Certificate number and link	Unit Number	Heating load (load limit) (MJ/m ² .yr)	Cooling load (load limit) (MJ/m ² .yr)	Total load (MJ/m ² .yr)	Star Rating	Whole of Home Rating
HR-J2PN1H-01	711	20.9 (34)	15.3 (21)	36.2	6.2	n/a
HR-3BMSVW-01	801	24.1 (34)	7.2 (21)	31.3	6.8	n/a
HR-6V655G-01	802	24.5 (34)	9.4 (21)	33.9	6.5	n/a
HR-UGS8SR-01	803	20.1 (34)	9.2 (21)	29.3	7.1	n/a
HR-WR6M0I-01	804	24.8 (34)	10.1 (21)	34.9	6.4	n/a
HR-WWHJVV-01	805	13.2 (34)	9.6 (21)	22.8	7.8	n/a
HR-7BWOCF-01	806	11.5 (34)	14.1 (21)	25.6	7.4	n/a
HR-K7SWX4-01	807	19.4 (34)	6.1 (21)	25.5	7.4	n/a
HR-3UXTE0-01	808	9.6 (34)	6.4 (21)	16.0	8.4	n/a
HR-JJ6J7L-01	809	32.1 (34)	4.6 (21)	36.8	6.2	n/a
HR-J7E8K6-01	810	21.7 (34)	7.6 (21)	29.3	7.1	n/a
HR-OHEZJ1-01	811	9.8 (34)	9.0 (21)	18.8	8.2	n/a
HR-029N6A-01	901	22.7 (34)	7.6 (21)	30.3	6.9	n/a
HR-VLA30C-01	902	25.7 (34)	9.2 (21)	34.9	6.4	n/a
HR-7G2JAJ-01	903	20.8 (34)	7.9 (21)	28.7	7.1	n/a
HR-X152ZS-01	904	23.2 (34)	12.9 (21)	36.1	6.2	n/a
HR-LDDDBR-01	905	20.9 (34)	10.2 (21)	31.0	6.9	n/a
HR-YVBPSW-01	906	15.8 (34)	15.0 (21)	30.8	6.9	n/a
HR-BILT1V-01	907	22.0 (34)	7.3 (21)	29.3	7.1	n/a
HR-92VFQ8-01	908	12.6 (34)	6.5 (21)	19.1	8.2	n/a
HR-4NH09W-01	909	21.3 (34)	6.2 (21)	27.5	7.2	n/a
HR-7GK502-01	910	26.8 (34)	8.7 (21)	35.5	6.3	n/a
HR-BUDQ2N-01	911	16.6 (34)	14.2 (21)	30.8	6.9	n/a
Averages	490x (Total)	18.3	9.8	28.1	7.2	n/a
Maximum Loads and Minimum Ratings		32.7	18.8	37.9	6.0	n/a

Explanatory notes

About the ratings

The thermal performance star rating in this Certificate is the average rating of all NCC Class 2 dwellings in an apartment block. The Whole of Home performance rating in this Certificate is the lowest rating for the apartment block. Individual unit ratings are listed in the 'Summary of all dwellings' section of this Certificate.

NatHERS ratings use computer modelling to evaluate a home's energy efficiency and performance. They use localised climate data and standard assumptions on how people use their home to predict the energy loads and societal cost. The thermal performance star rating uses the home's building specifications, layout, orientation and fabric (i.e. walls, windows, floors, roofs and ceilings) to predict the heating and cooling energy loads. The Whole of Home performance rating uses information about the home's appliances and onsite energy production and storage to estimate the home's societal cost.

For more details about an individual dwelling's assessment, refer to the individual dwelling's NatHERS Certificate (accessible via link).

Accredited Assessors

For high quality NatHERS Certificates, always use an accredited or licenced assessor registered with an Assessor Accrediting Organisation (AAO). AAOs have strict quality assurance processes, and professional development requirements ensuring consistently high standards for assessments.

Non-accredited assessors (Raters) have no ongoing training requirements and are not quality assured.

Licensed assessors in the Australian Capital Territory (ACT) can produce assessments for regulatory purposes only, using endorsed software, as listed on the ACT licensing register.

Any queries about this report should be directed to the assessor. If the assessor is unable to address questions or concerns, contact the AAO specified on the front of this certificate.

Disclaimer

The NatHERS Certificate format is developed by the NatHERS Administrator. However, the content in certificates is entered by the assessor. It is the assessor's responsibility to use NatHERS accredited software correctly and follow the NatHERS Technical Note to produce a NatHERS Certificate.

The predicted annual energy use, cost and greenhouse gas emissions in this NatHERS Certificate are an estimate based on an assessment of the dwelling's design by the assessor. It is not a prediction of actual energy use, cost or emissions. The information and ratings may be used to compare how other dwellings are likely to perform when used in a similar way.

Information presented in this report relies on a range of standard assumptions (both embedded in NatHERS accredited software and made by the assessor who prepared this report), including assumptions about occupancy, behaviour, appliance performance, indoor air temperature and local climate.

Not all assumptions made by the assessor while using the NatHERS accredited software tool are presented in this report and further details or data files may be available from the assessor.