

20-22 Atchison Street, St Leonards

Appendix B - ADG Compliance Table

24/10/2025
Rev C

ADG Ref.	Item Description	Notes	Compliance
PART 2	DEVELOPING THE CONTROLS		
2A	PRIMARY CONTROLS		
	Primary development controls are the key planning tool used to manage the scale of development so that it relates to the context and desired future character of an area and manages impacts on surrounding development.		✓
2A-1	Retention of trees	4 trees to be removed due to their likely failure during demolition or construction. Surrounding un-impacted street trees are to be retained. Additional trees are proposed to be introduced to the site to replace those removed.	YES
2A-2	Minimum setbacks	Setbacks compliant with those set out in the Transport Oriented Development (TOD) controls and the Design Guide.	YES
2A-3	Deep soil zones and basements levels	Due to constraints of a high-density area and majority non-residential use at ground floor, deep soil zones are not achieved as nominated in the ADG. The design compensates by providing a green link on the boundary to Mitchell Street, and extensive landscaped areas to communal open space on the podium, please refer to landscape drawings and report for further detail	NO
2A-4	Building separation and depth	North, east and south facades comply with building separation. The western façade does not meet the required 24m building separation, in part due to an existing non-compliant neighbour setback. This is addressed through planning that allows for the non-compliant wall to be solid with no windows, meaning privacy and solar access is not impacted.	YES
2A-5	Building performance and orientation	Building is orientated towards north.	YES
2A-6	Three-dimensional building envelope	Variation in setbacks between podium and tower as well as notches for balconies and corridor windows.	YES

2B	BUILDING ENVELOPES		
	A building envelope is a three dimensional volume that defines the outermost part of a site that the building can occupy.		✓
2B-1	Building envelope	Proposed building sits within setbacks and height controls.	YES
2C	BUILDING HEIGHT		
	Building height helps shape the desired future character of a place relative to its setting and topography. It defines the proportion and scale of streets and public spaces and has a relationship to the physical and visual amenity of both the public and private realms.		✓
2C-1	Maximum building height 139m	Proposed building complies with the podium height and maximum building height outlined in the TOD controls.	YES
2D	FLOOR SPACE RATIO		
	Floor space ratio (FSR) is the relationship of the total gross floor area (GFA) of a building relative to the total site area it is built on.		✓
2D-1	Maximum FSR 13.8:1 Residential 10.8:1 Non-Residential 3:1	The proposed FSR is below the maximum at 13.38:1. The project includes support for a variation to the residential and non-residential FSR values	YES
2E	BUILDING DEPTH		
	Building depth is an important tool for determining the development capacity of a site. It is the overall cross section dimension of a building envelope. Building depth dimensions typically include articulation such as projecting balconies, gallery access, eaves, overhangs, sun hoods, blades and other architectural features.		✓
2E-1	Building depth ensures the bulk of the development relates to the scale of the desired future context.	Proposed building sits within setbacks controls, building form is slim due to size of site.	YES
2E-2	Building depth supports apartment layouts that meet the objectives, design criteria and design guidance within the ADG		YES
2F	BUILDING SEPARATION		
	Building separation is the distance measured between building envelopes or buildings. Separation between buildings contributes to the urban form of an area and the amenity within apartments and open space areas.		✓

2F-1	Ensure that new development is scaled to support the desired future character with appropriate massing and spaces between buildings	North, east and south facades comply with building separation. The western façade does not meet the required 24m building separation, in part due to an existing non-compliant neighbour setback.	YES
2F-2	Assist in providing residential amenity including visual and acoustic privacy, natural ventilation, sunlight and daylight access and outlook	The western façade is proposed to be solid with no windows, meaning privacy and solar access is not impacted.	YES
2F-3	Provide suitable areas for communal open spaces, deep soil zones and landscaping	Setback to Mitchell St allows for public landscaping, communal open space is provided for residents at L4.	YES
2G	STREET SETBACKS		
	Street setbacks establish the alignment of buildings along the street frontage, spatially defining the width of the street. Combined with building height and road reservation, street setbacks define the proportion and scale of the street and contribute to the character of the public domain.		✓
2G-1	Establish the desired spatial proportions of the street and define the street edge		YES
2G-2	Provide space that can contribute to the landscape character of the street where desired	Setback to Mitchell St allows for public landscaping, communal open space is provided for residents at L4.	YES
2G-3	Create a threshold by providing a clear transition between the public and private realms	Existing level change along Atchison St provides a clear delineation between the public realm and the semi private and private entrances to the development.	YES
2G-4	Assist in achieving visual privacy to apartments from the street	No apartments to Ground Floor level	YES
2G-5	Create good quality entries to lobbies, foyers or individual dwellings	Residential and non-residential lobbies set back from Atchison Street	YES
2G-6	Promote passive surveillance and outlook to the street		YES
2H	SIDE AND REAR SETBACKS		
	Side and rear setbacks govern the distance of a building from the side and rear site boundaries and are related to the height of the building. They are important tools for achieving amenity for new development and buildings on adjacent sites.		
2H-1	Side and rear setbacks	Site is a stand-alone site fronted by roads on three sides and a pedestrian link on the fourth.	N/A

PART 3	SITING THE DEVELOPMENT		
3A	SITE ANALYSIS		
3A-1	Objective: Site Analysis illustrates that design decisions have been based on opportunities & constraints of the site conditions & their relationship to the surrounding context.		✓
	Design Guidance		
	Each element in the Site Analysis Checklist is addressed.		✓
3B	ORIENTATION		
3B-1	Objective: Building types & layouts respond to the streetscape & site while optimising solar access within the development		✓
	Design Guidance		
	Buildings along the street frontage define the street by facing it & incorporating direct access from the street		YES
	Where the street frontage is to the east or west, rear buildings are orientated to the north	Tower setback is constrained to minimum setbacks	N/A
	Where the street frontage is to the north or south, over-shadowing to the south is minimised & buildings behind the street frontage are orientated to the east & west	Tower setback is constrained to minimum setbacks	N/A
3B-2	Objective: Overshadowing of neighbouring properties is minimised during mid winter.		✓
	Design Guidance		
	Living areas, private open space & communal open space receive solar access in accordance with section 3D Communal & Public Open Space and section 4A Solar & Daylight Access		YES
	Solar access to living rooms, balconies & private open spaces of neighbours are considered		YES
	Where an adjoining property does not currently receive the required hours of solar access, the proposed building ensures solar access to neighbouring properties is not reduced by more than 20%		N/A
	If the proposal will reduce the solar access of neighbours, building separation is increased beyond minimums contained in 3F Visual Privacy		N/A
	Overshadowing is minimised to the south or downhill by increased upper level setbacks		YES
	Buildings are orientated at 90 deg to the boundary with neighbouring properties to minimise overshadowing & privacy impacts, particularly where minimum setbacks are used & where buildings are higher than the adjoining development		YES

	A minimum of 4 hours of solar access is retained to solar collectors on neighbouring buildings	Does not overshadow any solar collectors	YES
3C	PUBLIC DOMAIN INTERFACE		
3C-1	Objective: Transition between private & public domain is achieved without compromising safety & security.		✓
	Design Guidance		
	Terraces, balconies and courtyard apartments have direct street entry, where appropriate	No units located on ground level	N/A
	Changes in level between private terraces, front gardens & dwelling entries above the street level provide surveillance & improve visual privacy for ground level dwellings	No units located on ground level	N/A
	Upper level balconies & windows overlook the public domain		YES
	Front fences & walls along street frontages use visually permeable materials & treatments. Height of solid fences or walls is limited to 1m	No walls along street frontage	N/A
	Length of solid walls is limited along street frontages	Open public domain with retail/commercial offering	YES
	Opportunities for casual interaction between residents & the public domain is provided for. Design solutions may include seating at building entries, near letter boxes & in private courtyards adjacent to streets	Public green space seating provided along Mitchell Street. Seating provided adjacent to building entrances at retail providers.	YES
	In developments with multiple buildings and/or entries, pedestrian entries & spaces associated with individual buildings/entries are differentiated to improve legibility for residents, using the following design solutions: • Architectural detailing • Changes in materials • Plant Species • Colours • Opportunities for people to be concealed are minimised	Residential entry is clearly defined from the commercial entries through the use of differing awning covers, and an architectural language that connects the residential entry to the residential tower above.	YES
3C-2	Objective: Amenity of the public domain is retained & enhanced.		✓
	Design Guidance		
	Planting is used to soften the edges of any raised terraces to the street, for example above sub-basement car parking.	Planting integrated within podium terrace to overhang parapet	YES
	Mail boxes are located in lobbies, perpendicular to the street alignment or integrated into front fences where individual street entries are provided	Located within residential lobbies	YES

	The visual prominence of underground car park vents is minimised & located at a low level where possible		YES
	Substations, pump rooms, garbage storage areas & other service requirements are located in basement car parks or out of view	Garbage are services located at Lower Ground and Basement levels. Services seamlessly integrated within exterior detailing of podium at Lower Ground to Atchison Lane.	YES
	Ramping for accessibility is minimised by building entry location & setting ground floor levels in relation to footpath levels	Entries level to corner of Atchison Street and Mitchell Street which provides DDA access, both streets fall steeply away from this corner.	YES
	Durable, graffiti resistant & easily cleanable materials are used		YES
	Where development adjoins public parks, open space or bushland, the design positively addresses this interface & uses the following design solutions: - Street access, pedestrian paths & building entries are clearly defined - Paths, low fences & planting are clearly delineate between communal/private open space & the adjoining public open space - Minimal use of blank walls, fences & ground level parking	Located next to residential and commercial precinct	N/A
	On sloping sites protrusion of car parking above ground level is minimised by using split levels to step underground car parking	Parking is located below street levels at Basement 1.	YES
	COMMUNAL & PUBLIC OPEN SPACE		
3D-1	Objective: An adequate area of communal open space is provided to enhance residential amenity & to provide opportunities for landscaping.	Refer to the design guidance comments	✓
	Design Criteria		
1	Communal open space has a minimum area equal to 25% of the site	25% = 343.5m ² required, 640m ² proposed.	YES
2	Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid winter)	88% of Principal Open Space receives 2+ hours solar.	YES
	Design Guidance		
	Communal open space is consolidated into a well designed, easily identified & usable area	Located on Level 4	YES
	Communal open space have a minimum dimension of 3m. Larger developments should consider greater dimensions		YES
	Communal open space is co-located with deep soil areas	Due to constraints dense urban area, communal open space needs to be located on top of podium. Landscape design approach is to mound soil and	NO

		implement deep planters to support substantial plantings.	
	Direct, equitable access are provided to communal open space areas from common circulation areas, entries & lobbies	Located centrally to tower through shared lobby	YES
	Where communal open space cannot be provided at ground level, it is provided on a podium or roof	Provided on top of podium at Level 4	YES
	Where developments are unable to achieve the design criteria, such as on small lots, sites within business zones, or in a dense urban area, they need to: • Provide communal spaces elsewhere such as a landscaped roof top terrace or a common room • Provide larger balconies or increased private open space for apartments • Demonstrate good proximity to public open space & facilities and/or provide contributions to public open space		N/A
3D-2	Objective: Communal open space is designed to allow for a range of activities, respond to site conditions & be attractive and inviting		✓
	Design Guidance		
	Facilities are provided within communal open spaces & common spaces for a range of age groups (see 4F Common Circulation & Spaces), incorporating the following: • Seating for individuals or groups • Barbeque areas • Play equipment or play areas • Swimming pools, gyms, tennis courts or common rooms	Various areas have been incorporated including passive play, dining booths, flexible function areas, and common rooms adjacent. Refer to landscape documentation for further information.	YES
	Location of facilities responds to microclimate & site conditions with access to sun in winter, shade in summer & shelter from strong winds & down drafts	Shelter from winds with increased glass balustrade height coordinated with wind engineer.	YES
	Visual impacts of services are minimised, including location of ventilation duct outlets from basement car parks, electrical substations & detention tanks		YES
3D-3	Objective: Communal open space is designed to maximise safety.		✓
	Design Guidance		
	Communal open space & public domain should be readily visible from habitable rooms & private open space areas while maintaining visual privacy. Design solutions include: • Bay windows • Corner windows • Balconies	Communal open space is on the podium footprint. Balconies above will have views to lower green edges and public domain along with a majority of apartments having green / water views to the north and east.	YES
	Communal open space is well lit		YES

	Communal open space/facilities that are provided for children & young people are safe and contained		YES										
3D-4	Objective: Public open space, where provided, responds to the existing pattern & uses of the neighbourhood		✓										
	Design Guidance												
	Public open space is well connected with public streets along at least one edge	Public open space located along Mitchell Street.	YES										
	POS is connected with nearby parks & other landscape elements	Public open space creates a green link that acts as a continuation of the Mitchell Street Plaza.	YES										
	POS is linked through view lines, pedestrian desire paths, termination points & the wider street grid		YES										
	Solar access is provided year round along with protection from strong winds	Additional tree planting proposed to mitigate wind impact to public open space along Mitchell Street. Ground Floor setback at Atchison Street entries provides protection.	YES										
	Opportunities for a range of recreational activities is provided for people of all ages	Size of public open space is limited and used to provide greenery and incidental seating, recreational activities not provided.	NO										
	Positive street address & active street frontages are provided adjacent to POS		YES										
	Boundaries are clearly defined between POS & private areas	Architectural expression and awning design above clear demark residential lobby and entry against retail and other GF uses.	YES										
3E	DEEP SOIL ZONES												
3E-1	Objective: Deep soil zones are suitable for healthy plant& tree growth, improve residential amenity and promote management of water and air quality.		X										
	Design Criteria												
1	Deep soil zones are to meet the following minimum requirements: <table><tr><th>Site Area (sqm)</th><th>Minimum Dim. (m)</th><th>Deep Soil Zone (% of site area)</th></tr><tr><td>Less than 650</td><td>-</td><td rowspan="3">7</td></tr><tr><td>650-1500</td><td>3</td></tr><tr><td>Greater than 1500</td><td>6</td></tr></table>	Site Area (sqm)	Minimum Dim. (m)	Deep Soil Zone (% of site area)	Less than 650	-	7	650-1500	3	Greater than 1500	6	Due to constrains of a high-density area and majority non-residential use at ground floor, deep soil zones are not achieved as nominated in the ADG. The design compensates by providing a green link on the boundary to Mitchell Street, and extensive landscaped areas to communal open space on the podium, please refer to landscape drawings and report for further detail.	NO
Site Area (sqm)	Minimum Dim. (m)	Deep Soil Zone (% of site area)											
Less than 650	-	7											
650-1500	3												
Greater than 1500	6												

	Greater than 1500 with significant existing tree cover	6				
	Design Guidance					
	On some sites it may be possible to provide larger deep soil zones, depending on the site area & context: 10% of the site as deep soil on sites with an area of 650sqm -1,500sqm 15% of the site as deep soil on sites greater than 1,500sqm				Not applicable due to constraints of site.	N/A
	Deep soil zones are located to retain existing significant trees & to allow for the development of healthy root systems, providing anchorage & stability for mature trees. Design solutions may include: - Basement & sub-basement car park design that is consolidated beneath building footprints - Use of increased front & side setbacks - Adequate clearance around trees to ensure long term health - Co-location with other deep soil areas on adjacent sites to create larger contiguous areas of deep soil				Basement car park to ensure active building footprint. Due to highly urban context, planting is located above ground.	N/A
	Achieving the design criteria may not be possible on some sites including where: - location & building typology have limited or no space for deep soil at ground level (e.g. central business district, constrained sites, high density areas, or in centres) - there is 100% site coverage or non-residential uses at ground floor level Where a proposal does not achieve deep soil requirements, acceptable stormwater management is achieved & alternative forms of planting provided				100% site coverage and non-residential uses at ground floor level. Located within highly dense context.	YES
3F	VISUAL PRIVACY					
3F-1	Objective: Adequate building separation distances are shared equitably between neighbouring sites, to achieve reasonable levels of external & internal visual privacy.					✓
	Design Criteria					
1	Separation between windows & balconies is provided to ensure visual privacy is achieved. Minimum required separation distances from buildings to the side & rear boundaries are as follows:				No clear windows located on the western tower façade, this façade is setback 6m from boundary and does not meet the ADG separation requirements. 9m separation between living room window and boundary through balconies above L14, neighbouring building has wall screened so visual privacy won't be impacted.	NO
	Building Height (m)	Habitable Rooms & Balconies (m)	Non-Habitable Rooms (m)			
	Up to 12 (4 storeys)	6	3			

	Up to 25 (5-8 storeys)	9	4.5			
	Over 25 (9+ storeys)	12	6			
Note: Separation distances between buildings on the same site should combine required building separations depending on the type of room. Gallery access circulation should be treated as habitable space when measuring privacy separation distances between neighbouring properties.						
	Design Guidance					
	Generally as the height increases, one step in the built form is desirable due to building separations. Any additional steps do not cause a 'ziggurat' appearance				Consistent tower setbacks ensure no steps in built form.	YES
	For residential buildings next to commercial buildings, separation distances are measured as follows: - Retail, office spaces & commercial balconies use the habitable room distances - Service & plant areas use the non-habitable room distances					N/A
	New developments are located & oriented to maximise visual privacy between buildings on site & for neighbouring buildings. Design solutions include: - site layout & building are orientated to minimise privacy impacts (see 3B Orientation) - on sloping sites, apartments on different levels have appropriate visual separation distances (see pg 63 figure 3F.4)					YES
	Apartment buildings have an increased separation distance of 3m (in addition to 3F-1 Design Criteria) when adjacent to a different zone that permits lower density residential development, to provide for a transition in scale & increased landscaping (pg 63 figure 3F.5)					N/A
	Direct lines of sight are avoided for windows & balconies across corners					YES
	No separation is required between blank walls					N/A
3F-2	Objective: Site & building design elements increase privacy without compromising access to light & air and balance outlook & views from habitable rooms & private open space.					✓
	Design Guidance					
	Communal open space, common areas & access paths are separated from private open space & windows to apartments, particularly habitable room windows. Design solutions include: - setbacks - solid or partially solid balustrades on balconies at lower levels - fencing and/or trees and vegetation to separate spaces					YES

	- screening devices - bay windows or pop out windows to provide privacy in one direction & outlook in another - raising apartments or private open space above the public domain or communal open space - planter boxes incorporated into walls & balustrades to increase visual separation - pergolas or shading devices to limit overlooking of lower apartments or private open space - on constrained sites where it can be demonstrated that building layout opportunities are limited, fixed louvres or screen panels on windows and/or balconies		
	Bedrooms, living spaces & other habitable rooms are separated from gallery access & other open circulation space by the apartment's service areas	Apartments in tower accessed by internal shared lobby with maximum of 7 units off one lobby. Where possible, units are accessed through private lobby adjacent to service zone before entering main living space.	YES
	Balconies & private terraces are located in front of living rooms to increase internal privacy		YES
	Windows are offset from the windows of adjacent buildings		YES
	Recessed balconies and/or vertical fins are used between adjacent balconies		YES
3G	PEDESTRIAN ACCESS & ENTRIES		
3G-1	Objective: Building entries & pedestrian access connects to and addresses the public domain.		✓
	Design Guidance		
	Multiple entries (including communal building entries & individual ground floor entries) activate the street edge	Retail spaces provided on south west corner activates street edges to Atchison Street and Mitchell Street activated by proposed green link.	YES
	Entry locations relate to the street & subdivision pattern, and the existing pedestrian network		YES
	Building entries are clearly identifiable. Communal entries are clearly distinguishable from private entries	Architecture integrates seamless wayfinding strategy to residential lobbies to highlight private vs public entries to the podium.	YES
	Where street frontage is limited, a primary street address should be provided with clear sight lines and pathways to secondary building entries		YES
3G-2	Objective: Access, entries & pathways are accessible & easy to identify.		✓
	Design Guidance		
	Building access areas including lift lobbies, stairwells & hallways are clearly visible from the public domain & communal spaces		YES

	The design of ground floors & underground car parks minimise level changes along pathways & entries		YES
	Steps & ramps are integrated into the overall building & landscape design		YES
	For large developments 'way finding' maps are provided to assist visitors & residents		N/A
	For large developments electronic access & audio/video intercom are provided to manage access		YES
3G-3	Objective: Large sites provide pedestrian links for access to streets & connection to destinations.		N/A
	Design Guidance		
	Pedestrian links through sites facilitate direct connections to open space, main streets, centres & public transport		N/A
	Pedestrian links are direct, have clear sight lines, are overlooked by habitable rooms or private open spaces of dwellings, are well lit & contain active uses, where appropriate		N/A
3H	VEHICLE ACCESS		
3H-1	Objective: Vehicle access points are designed & located to achieve safety, minimise conflicts between pedestrians & vehicles and create high quality streetscapes.		✓
	Design Guidance		
	Design solutions include: - materials & colour palette minimise visibility from street - security doors/gates minimise voids in the facade - where doors are not provided, visible interiors reflect façade design, and building services, pipes & ducts are concealed	Entries recessed from podium face to minimise visibility. Façade design prioritises visibility of activated ground plane mixed-use interior spaces.	YES
	Car park entries are located behind the building line	Lower Ground vehicle entry set back from façade.	YES
	Vehicle entries are located at the lowest point of the site, minimising ramp lengths, excavation & impacts on the building form and layout	Located at lowest point of site on Atchison Lane.	YES
	Car park entry & access are located on secondary streets or lanes where available	Loading and basement entry integrated and located on Atchison Lane, leaving Atchison Street façade highly active. Location aligns with existing vehicle entry to site to ensure no adverse impacts on current traffic strategy	YES
	Vehicle standing areas that increase driveway width & encroach into setbacks are avoided		YES
	Access point is located to avoid headlight glare to habitable rooms		YES

	Adequate separation distances are provided between vehicle entries & street intersections		YES
	The width & number of vehicle access points are limited to the minimum	Single vehicle access point off Atchison Lane.	YES
	Visual impact of long driveways is minimised through changing alignments & screen planting	No long driveways in project.	N/A
	The need for large vehicles to enter or turn around within the site is avoided	Loading dock for 2 x MRV vehicles provides, turning space allowed to allow vehicles to enter and exit the site in a forward motion as per council requirements.	NO
	Garbage collection, loading & servicing areas are screened	Located behind main building facade	YES
	Clear sight lines are provided at pedestrian & vehicle crossings		YES
	Traffic calming devices, such as changes in paving material or textures, are used where appropriate		N/A
	Pedestrian & vehicle access are separated & distinguishable. Design solutions include: • Changes in surface materials • Level changes • Landscaping for separation		YES
3J	BICYCLE & CAR PARKING		
3J-1	Objective: Car parking is provided based on proximity to public transport in metropolitan Sydney & centres in regional areas.		✓
	Design Criteria		
1	For development in the following locations: • on sites that are within 800m of a railway station or light rail stop in the Sydney Metropolitan Area; or • on land zoned, and sites within 400m of land zoned, B3 Commercial Core, B4 Mixed Use or equivalent in a nominated regional centre the minimum car parking requirement for residents & visitors is set out in the Guide to Traffic Generating Developments, or the car parking requirement prescribed by the relevant council, whichever is less. The car parking needs for a development must be provided off street.	Parking provisions are below the Housing SEPP residential rates which takes precedence over the DCP. Council have previously stated due to the sites location they will accept less than maximum parking numbers.	NO
	Design Guidance		
	Where a car share scheme operates locally, car share parking spaces are provided within the development.		N/A
	Where less car parking is provided in a development, council do not provide on street resident parking permits		N/A

3J-2	Objective: Parking & facilities are provided for other modes of transport.		✓
	Design Guidance		
	Conveniently located & sufficient numbers of parking spaces are provided for motorbikes & scooters		YES
	Secure undercover bicycle parking is provided & easily accessible from both public domain & common areas	Over supply of bicycle parking provided to mitigate the below maximum car parking provided.	YES
	Conveniently located charging stations are provided for electric vehicles, where desirable	Provisions for future EV charging points included.	N/A
3J-3	Objective: Car park design & access is safe and secure		✓
	Design Guidance		
	Supporting facilities within car parks, including garbage, plant & switch rooms, storage areas & car wash bays can be accessed without crossing car parking spaces	Car wash bay not provided.	YES
	Direct, clearly visible & well lit access is provided into common circulation areas		YES
	Clearly defined & visible lobby or waiting area is provided to lifts & stairs		YES
	For larger car parks, safe pedestrian access is clearly defined & circulation areas have good lighting, colour, line marking and/or bollards		YES
3J-4	Objective: Visual & environmental impacts of underground car parking are minimised.		YES
	Design Guidance		
	Excavation minimised through efficient car park layouts & ramp design		YES
	Car parking layout is well organised, using a logical, efficient structural grid & double loaded aisles	Due to size of site double aisles are not achievable.	N/A
	Protrusion of car parks do not exceed 1m above ground level. Solution include stepping car park levels or using split levels on sloping sites		YES
	Natural ventilation is provided to basement & sub-basement car parking		YES
	Ventilation grills or screening devices for car parking openings are integrated into the facade & landscape design		YES
3J-5	Objective: Visual & environmental impacts of on-grade car parking are minimised.		✓
	Design Guidance		
	On-grade car parking is avoided		YES
	Where on-grade car parking is unavoidable, the following design solutions are used: Parking is located on the side or rear of the lot away from the primary street frontage		N/A

	- Cars are screened from view of streets, buildings, communal & private open space areas - Safe & direct access to building entry points is provided - Parking is incorporated into the landscape design, by extending planting & materials into the car park space - Stormwater run-off is managed appropriately from car parking surfaces - Bio-swales, rain gardens or on site detention tanks are provided, where appropriate - Light coloured paving materials or permeable paving systems are used. Shade trees are planted between every 4-5 parking spaces to reduce increased surface temperatures to large areas of paving		
3J-6	Objective: Visual & environmental impacts of above ground enclosed car parking are minimised.		✓
	Design Guidance		
	Exposed parking is not located along primary street frontages		N/A
	Screening, landscaping & other design elements including public art are used to integrate the above ground car parking with the facade. Design solutions include: - Car parking that is concealed behind facade, with windows integrated into the overall facade design (limited to developments where larger floor plate podium is suitable at lower levels) - Car parking that is 'wrapped' with other uses, such as retail, commercial or two storey Small Office/Home Office (SOHO) units along the street frontage		N/A
	Positive street address & active frontages are provided at ground level		N/A

ADG Ref.	Item Description	Notes	Compliance
PART 4	DESIGNING THE BUILDING		
4A	SOLAR & DAYLIGHT ACCESS		
4A-1	Objective: To optimise number of apartments receiving sunlight to habitable rooms, primary windows & private open space.		✓
	Design Criteria		
1	Living rooms & private open spaces of at least 70% of apartments in a building receive a minimum of 2 hrs direct sunlight between 9am - 3pm at mid winter in Sydney Metropolitan Area and in Newcastle and Wollongong local government areas		YES
2	In all other areas, living rooms & private open spaces of at least 70% of apartments in a building receive a minimum of 3 hrs direct sunlight between 9 am - 3 pm at mid winter		N/A
3	A maximum of 15% of apartments in a building receive no direct sunlight between 9 am - 3 pm at mid winter	3% of apartments receive no solar during mid-winter.	YES
	Design Guidance		
	The design maximises north aspect. The number of single aspect south facing apartments is minimised		YES
	Single aspect, single storey apartments have a northerly or easterly aspect		YES
	Living areas are located to the north and service areas to the south & west of apartments		YES

ADG Ref.	Item Description	Notes	Compliance
	To optimise direct sunlight to habitable rooms & balconies a number of the following design features are used: • Dual aspect apartments • Shallow apartment layouts • Two storey & mezzanine level apartments • Bay windows		YES
	To maximise the benefit to residents of direct sunlight within living rooms & private open spaces, a minimum of 1sqm of direct sunlight, measured at 1m above floor level, is achieved for at least 15 minutes		YES
	Achieving the design criteria may not be possible where: • greater residential amenity can be achieved along a busy road or rail line by orientating the living rooms away from the noise source • on south facing sloping sites • significant views are oriented away from the desired aspect for direct sunlight Design drawings need to demonstrate how site constraints & orientation preclude meeting Design Criteria & how the development meets the objective.		YES
4A-2	Objective: Daylight access is maximised where sunlight is limited.		✓
	Design Guidance		
	Courtyards, skylights & high level windows (with sills of 1,500mm or greater) are used only as a secondary light source in habitable rooms		YES
	Where courtyards are used: • Use is restricted to kitchens, bathrooms & service areas • Building services are concealed with appropriate detailing & materials to visible walls • Courtyards are fully open to the sky • Access is provided to the light well from communal area for cleaning & maintenance • Acoustic privacy, fire safety & minimum privacy separation distances (see 3F Visual Privacy) are achieved		N/A
	Opportunities for reflected light into apartments are optimised through: • Reflective exterior surfaces on buildings opposite south facing windows • Positioning windows to face other buildings or surfaces (on neighbouring sites or within site) that will reflect light • Integrating light shelves into the design • Light coloured internal finishes		YES

ADG Ref.	Item Description	Notes	Compliance
4A-3	Objective: Design incorporates shading & glare control, particularly for warmer months.		✓
	Design Guidance		
	A number of the following design features are used: - Balconies or sun shading that extend far enough to shade summer sun, but allow winter sun to penetrate living areas - Shading devices such as eaves, awnings, balconies, pergolas, external louvres & planting - Horizontal shading to north facing windows - Vertical shading to east & particularly west facing windows - Operable shading to allow adjustment & choice - High performance glass that minimises external glare off windows, with consideration given to reduce tint glass or glass with a reflectance level below 20% (reflective films are avoided)	Shading achieved through stacked balconies. Shading devices such as eaves, awnings, and vertical fins have been incorporated into the façade design.	YES
4B	NATURAL VENTILATION		
4B-1	Objective: All habitable rooms are naturally ventilated		✓
	Design Guidance		
	The building's orientation maximises capture & use of prevailing breezes for natural ventilation in habitable rooms		YES
	Depths of habitable rooms support natural ventilation		YES
	The area of unobstructed window openings should be equal to at least 5% of the floor area served		YES
	Light wells are not the primary air source for habitable rooms	No light wells are used	YES
	Doors & openable windows maximise natural ventilation opportunities by using the following design solutions: - Adjustable windows with large effective openable areas - Variety of window types that provide safety & flexibility such as awnings & louvres - Windows that occupants can reconfigure to funnel breezes into apartment, such as vertical louvres, casement windows & externally opening doors		YES
4B-2	Objective: The layout & design of single aspect apartments maximises natural ventilation.		✓
	Design Guidance		

ADG Ref.	Item Description	Notes	Compliance
	Apartment depths limited to maximise ventilation & airflow		YES
	Natural ventilation to single aspect apartments is achieved with the following design solutions: • Primary windows are augmented with plenums and light wells (generally not suitable for cross ventilation) • Stack effect ventilation, solar chimneys or similar used to naturally ventilate internal building areas or rooms such as bathrooms & laundries • Courtyards or building indentations have a width to depth ratio of 2:1 or 3:1 to ensure effective air circulation & avoid trapped smells	Single aspect apartments, have been provided with a mechanical ventilation system that complies with “NCC 2022 F6D7 Ventilation of Rooms” to support their natural ventilation.	YES
4B-3	Objective: Number of apartments with natural cross vent is maximised to create comfortable indoor environments for residents.		✓
	Design Criteria		
1	At least 60% of apartments are naturally cross ventilated in the first nine storeys of the building. Apartments at ten storeys or greater are deemed to be cross ventilated only if any enclosure of the balconies at these levels allows adequate natural ventilation and cannot be fully enclosed		YES
2	Overall depth of a cross-over or cross-through apartment does not exceed 18m, measured glass line to glass line	No cross-through apartments.	N/A
	Design Guidance		
	The building includes dual aspect apartments, cross through apartments & corner apartments, and limited apartment depths	No cross-through apartments.	YES
	In cross-through apartments, external window & door opening sizes/ areas on one side of an apartment (inlet side) are approximately equal to the external window & door opening sizes/areas on the other side of the apartment (outlet side)		N/A
	Apartments are designed to minimise the number of corners, doors & rooms that might obstruct airflow		YES
	Apartment depths, combined with appropriate ceiling heights, maximise cross ventilation & airflow		YES
4C	CEILING HEIGHTS		
4C-1	Objective: Ceiling height achieves sufficient natural ventilation & daylight access.		✓
	Design Criteria		

ADG Ref.	Item Description	Notes	Compliance	
1	Measured from finished floor level to finished ceiling level, minimum ceiling heights are:		YES	
	Minimum Ceiling Height for apt and mixed-used buildings (m)			
	Habitable rooms			2.7
	Non-habitable rooms			2.4
	For 2 storey apts			2.7 for main living area floor 2.4 for second floor, where its area does not exceed 50% of the apt area
	Attic spaces			1.8 at edge of room with 30deg minimum ceiling slope
	If located in mixed-use areas			3.3 for ground and first floor to promote future flexibility of use
These minimums do not preclude higher ceilings if desired				
	Design Guidance			
	Ceiling height accommodates use of ceiling fans for cooling & heat distribution		YES	
4C-2	Objective: Ceiling height increases the sense of space in apartments & provides for well proportioned rooms.		✓	
	Design Guidance			
	A number of the following design solutions are used: - Hierarchy of rooms in apartment is defined using changes in ceiling heights & alternatives such as raked or curved ceilings, or double height spaces - Well proportioned rooms are provided, for example, smaller rooms feel larger & more spacious with higher ceilings - Ceiling heights are maximised in habitable rooms by ensuring that bulkheads do not intrude. The stacking of service rooms from floor to floor & coordination of bulkhead location above non-habitable areas, such as robes or storage, can assist		YES	
4C-3	Objective: Ceiling heights contribute to the flexibility of building use over the life of the building		✓	
	Design Guidance			
	Ceiling heights of lower-level apartments should be greater than the minimum required by Design Criteria allowing flexibility & conversion to non-residential uses	Floor to floor, and therefore ceiling heights, are determined by the TOD Design Guide.	N/A	

ADG Ref.	Item Description	Notes	Compliance										
4D	APARTMENT SIZE & LAYOUT												
4D-1	Objective: The layout of rooms within apartment is functional, well organised & provides a high standard of amenity.		✓										
	Design Criteria												
1	Apartments have the following minimum internal areas:		YES										
	<table><tr><th>Apartment Type</th><th>Minimum Internal Area (sqm)</th></tr><tr><td>Studio</td><td>35</td></tr><tr><td>1 Bedroom</td><td>50</td></tr><tr><td>2 Bedroom</td><td>70</td></tr><tr><td>3 Bedroom</td><td>90</td></tr></table>			Apartment Type	Minimum Internal Area (sqm)	Studio	35	1 Bedroom	50	2 Bedroom	70	3 Bedroom	90
	Apartment Type			Minimum Internal Area (sqm)									
	Studio			35									
	1 Bedroom			50									
	2 Bedroom			70									
	3 Bedroom			90									
The minimum internal areas include only one bathroom. Additional bathrooms increase the minimum internal area by 5sqm each.													
A fourth bedroom & further additional bedrooms increase the minimum internal area by 12sqm each													
2	Every habitable room has a window in an external wall with a total minimum glass area of not less than 10% of the floor area of the room. Daylight & air is not borrowed from other rooms	With the exception of internal study zones and dedicated media rooms.	YES										
	Design Guidance												
	Kitchens is not located as part of the main circulation space in larger apartments (such as hallway or entry space)		YES										
	A window is visible from any point in a habitable room		YES										
	Where minimum areas or room dimensions are not met, apartments demonstrate that they are well designed and demonstrate the usability & functionality of the space with realistically scaled furniture layouts & circulation areas.		N/A										
4D-2	Objective: Environmental performance of the apartment is maximised		✓										
	Design Criteria												
1	Habitable room depths are limited to a maximum of 2.5 x the ceiling height	All living rooms and dining rooms comply.	YES										
2	In open plan layouts (living, dining & kitchen are combined) maximum habitable room depth is 8m from a window		YES										

ADG Ref.	Item Description	Notes	Compliance
	Design Guidance		
	Greater than minimum ceiling heights allow for proportional increases in room depth up to the permitted max depths		N/A
	All living areas & bedrooms are located on the external face of building	With the exception of internal study zones and dedicated media rooms.	YES
	Where possible: - bathrooms & laundries have external openable window - main living spaces are oriented toward the primary outlook & aspect and away from noise sources	When located on the façade bathrooms have windows.	YES
4D-3	Objective:		✓
	Design Criteria		
1	Master bedrooms have a minimum area of 10sqm & other bedrooms 9sqm (excluding wardrobe space)		YES
2	Bedrooms have a minimum dimension of 3m (excluding wardrobe space)		YES
3	Living rooms or combined living/dining rooms have a minimum width of: 3.6m for studio & 1 bedroom apartments 4m for 2 & 3 bedroom apartments		YES
4	The width of cross-over or cross-through apartments are at least 4m internally to avoid deep narrow apartment layouts		N/A
	Design Guidance		
	Access to bedrooms, bathrooms & laundries is separated from living areas minimising direct openings between living & service areas		YES
	All bedrooms allow a minimum length of 1.5m for robes		YES
	Main bedroom of apartment or studio apartment is provided with a wardrobe of minimum 1.8m L x 0.6m D x 2.1m H		YES

ADG Ref.	Item Description	Notes	Compliance															
	Apartment layouts allow flexibility over time, design solutions include: • Dimensions that facilitate a variety of furniture arrangements & removal • Spaces for a range of activities & privacy levels between different spaces within the apartment • Dual master apartments • Dual key apartments (Note: dual key apartments which are separate but on the same title are regarded as two sole occupancy units for the purposes of the BCA & for calculating mix of apartments) • Room sizes & proportions or open plans (rectangular spaces 2:3 are more easily furnished than square spaces 1:1) • Efficient planning of circulation by stairs, corridors & through rooms to maximise the amount of usable floor space in rooms		YES															
4E	PRIVATE OPEN SPACE & BALCONIES																	
4E-1	Objective: Apartments provide appropriately sized private open space & balconies to enhance residential amenity.		✓															
	Design Criteria																	
1	All apartments are required to have primary balconies as follows: <table><thead><tr><th>Apartment Type</th><th>Minimum Area (sqm)</th><th>Minimum Depth (m)</th></tr></thead><tbody><tr><td>Studio</td><td>4</td><td>-</td></tr><tr><td>1 Bedroom</td><td>8</td><td>2</td></tr><tr><td>2 Bedroom</td><td>10</td><td>2</td></tr><tr><td>3 Bedroom</td><td>12</td><td>2.4</td></tr></tbody></table> The minimum balcony depth to be counted as contributing to the balcony area is 1m	Apartment Type	Minimum Area (sqm)	Minimum Depth (m)	Studio	4	-	1 Bedroom	8	2	2 Bedroom	10	2	3 Bedroom	12	2.4		YES
Apartment Type	Minimum Area (sqm)	Minimum Depth (m)																
Studio	4	-																
1 Bedroom	8	2																
2 Bedroom	10	2																
3 Bedroom	12	2.4																
2	For apartments at ground level or on podium or similar, a private open space is provided instead of a balcony. It must have minimum area of 15sqm & minimum depth of 3m		N/A															
	Design Guidance																	
	Increased communal open space are provided where the number or size of balconies are reduced	All balconies achieve minimum requirements	N/A															
	Storage areas on balconies is additional to the minimum balcony size	No storage located on balconies	N/A															

ADG Ref.	Item Description	Notes	Compliance
	Balcony use may be limited in some proposals where: - consistently high wind speeds at 10 storeys & above - close proximity to road, rail or other noise sources - exposure to significant levels of aircraft noise - heritage & adaptive reuse of existing buildings In these situations, - juliet balconies, - operable walls, - enclosed wintergardens - bay windows are appropriate. Other amenity benefits for occupants are provide in the apartments or in the development or both. Natural ventilation is also demonstrated	Built proposal reviewed by wind and acoustic consultants, balcony design is compliant with recommendations.	N/A
4E-2	Objective: Primary private open space & balconies are appropriately located to enhance liveability for residents		✓
	Design Guidance		
	Primary open space & balconies are located adjacent to the living room, dining room or kitchen to extend the living space		YES
	POS & balconies predominantly face north, east or west		YES
	POS & balconies are orientated with the longer side facing outwards or be open to the sky to optimise daylight access into adjacent rooms		YES
4E-3	Objective: Private open space & balcony design is integrated into & contributes to the overall architectural form & detail of the building		✓
	Design Guidance		
	Solid, partially solid or transparent fences & balustrades are selected to respond to the location. They are designed to allow views & passive surveillance of the street while maintaining visual privacy & allowing for a range of uses on the balcony. Solid & partially solid balustrades are preferred	Partially solid balustrades are integrated with landscaped planters.	YES
	Full width full height glass balustrades alone are generally not desirable		N/A
	Projecting balconies are integrated into the building design. The design of soffits are considered		N/A

ADG Ref.	Item Description	Notes	Compliance
	Operable screens, shutters, hoods & pergolas are used to control sunlight & wind	Balconies are stacked to offer shading and protection to the balcony below. Fixed open louvres are provided above 1400H solid balustrades to help mitigate impacts on wind.	N/A
	Balustrades are set back from the building or balcony edge where overlooking or where safety is an issue		YES
	Downpipes & balcony drainage are integrated with the overall façade & building design		YES
	Air-conditioning units are located on roofs, in basements, or fully integrated into the building design	Located on rooftop plant which is fully integrated into façade design	YES
	Where clothes drying, storage or air conditioning units are located on balconies, they are screened & integrated in the building design		N/A
	Ceilings of apartments below terraces are insulated to avoid heat loss		YES
	Water & gas outlets are provided for primary balconies & private open space		NO
4E-4	Objective: Private open space & balcony design maximises safety		✓
	Design Guidance		
	Changes in ground levels or landscaping are minimised		YES
	Balcony design & detailing avoids opportunities for climbing & falling	Increased balustrade heights to alleviate climbing and falling issues	YES
4F	COMMON CIRCULATION & SPACES		
4F-1	Objective: Common circulation spaces achieve good amenity & properly service the number of apartments		✓
	Design Criteria		
1	The maximum number of apartments off a circulation core on a single level is eight	Maximum number is 7 apartments off a single core.	YES
2	For buildings of 10 storeys & over, the maximum number of apartments sharing a single lift is 40		N/A
	Design Guidance		
	Greater than minimum requirements for corridor widths and/or ceiling heights allow comfortable movement & access particularly in entry lobbies, outside lifts & at apartment entry doors		YES

ADG Ref.	Item Description	Notes	Compliance
	Daylight & natural ventilation are provided to all common circulation spaces that are above ground		YES
	Windows are provided in common circulation spaces & are adjacent to the stair or lift core or at the ends of corridors		YES
	Longer corridors greater than 12m in length from the lift core are articulated. Design solutions include: - Series of foyer areas with windows & spaces for seating - Wider areas at apartment entry doors & varied ceiling heights	Proposed design is articulated with windows and recesses along the corridor.	YES
	Common circulation spaces maximise opportunities for dual aspect apartments, including multiple core apartment buildings & cross over apartments		N/A
	Achieving Design Criteria for the number of apartments off a circulation core may not be possible. Where development is unable to achieve this, a high level of amenity for common lobbies, corridors & apartments is demonstrated, including: - Sunlight & natural cross ventilation in apartments - Access to ample daylight & natural ventilation in common circulation spaces - Common areas for seating & gathering - Generous corridors with greater than minimum ceiling heights - Other innovative design solutions that provide high levels of amenity		N/A
	Where Design Criteria 1 is not achieved, no more than 12 apartments should be provided off a circulation core on a single level		N/A
	Primary living room or bedroom windows do not open directly onto common circulation spaces, open or enclosed. Visual & acoustic privacy from common circulation spaces to any other rooms are carefully controlled		YES
4F-2	Objective: Common circulation spaces promote safety & provide for social interaction between residents		✓
	Design Guidance		
	Direct & legible access are provided between vertical circulation points & apartment entries by minimising corridor or gallery length to give short, straight, clear sight lines		YES
	Tight corners & spaces are avoided		YES
	Circulation spaces are well lit at night		YES
	Legible signage are provided for apartment numbers, common areas & general wayfinding		YES

ADG Ref.	Item Description	Notes	Compliance
	Incidental spaces, eg space for seating in a corridor, at a stair landing, or near a window are provided		YES
	In larger developments, community rooms for activities such as owners corporation meetings or resident use, are provided & are co-located with communal open space	Communal indoor space provided on Level 4 adjacent to communal open space.	YES
	Where external galleries are provided, they are more open than closed above the balustrade along their length		N/A
4G	STORAGE		
4G-1	Objective: Adequate, well designed storage is provided in each apartment		✓
	Design Criteria		
1	In addition to storage in kitchens, bathrooms and bedrooms, the following storage is provided:		YES
	Apartment Type	Storage Size Volume (cubic m)	
	Studio	4	
	1 Bedroom	6	
	2 Bedroom	8	
	3+ Bedroom	10	
	At least 50% of the required storage is to be located within the apartment		
	Design Guidance		
	Storage is accessible from either circulation or living areas		YES
	Storage provided on balconies (in addition to the minimum balcony size) is integrated into the balcony design, weather proofed & screened from view from the street		N/A
	Left over space such as under stairs is used for storage		N/A
4G-2	Objective: Additional storage is conveniently located, accessible & nominated for individual apartments		✓
	Design Guidance		
	Storage not located in apartments is secure and clearly allocated to specific apartments	Individual storage cages located within carpark	YES
	Storage is provided for larger & less frequently accessed items		YES

ADG Ref.	Item Description	Notes	Compliance
	Storage space in internal or basement car parks is provided at the rear or side of car spaces or in cages, such that allocated car parking remains accessible		YES
	If communal storage rooms are provided they are accessible from common circulation areas of the building		N/A
	Storage not located in apartment is integrated into the overall building design & not visible from public domain	Located within basement carpark levels and podium residential levels in separated room.	YES
4H	ACOUSTIC PRIVACY		
4H-1	Objective: Noise transfer is minimised through the siting of buildings & building layout		✓
	Design Guidance		
	Adequate building separation is provided within the development & from neighbouring buildings/adjacent uses (see 2F Building Separation & 3F Visual Privacy)	Excluding the western façade as previously noted.	YES
	Window & door openings are orientated away from noise sources	Where possible, living spaces are orientated towards the north which is away from noise sources along Pacific Highway. Acoustic strategy has been implemented from acoustic engineer.	YES
	Noisy areas within buildings including building entries & corridors are located next to or above each other while quieter areas are located next to or above quieter areas		YES
	Storage, circulation areas & non-habitable rooms are located to buffer noise from external sources		YES
	The number of party walls (shared with other apartments) are limited & are appropriately insulated		YES
	Noise sources such as garage doors, driveways, service areas, plant rooms, building services, mechanical equipment, active communal open spaces & circulation areas should be located at least 3m away from bedrooms		YES
4H-2	Objective: Noise impacts are mitigated within apartments through layout & acoustic treatments		✓
	Design Guidance		

ADG Ref.	Item Description	Notes	Compliance
	Internal apartment layout separates noisy spaces from quiet spaces, using a number of the following design solutions: • Rooms with similar noise requirements are grouped together • Doors separate different use zones • Wardrobes in bedrooms are co-located to act as sound buffers	Rooms with similar noise requirements are typically grouped together. Party walls between apartments will be discontinuous construction and meet requirements nominated by acoustic engineer.	YES
	Where physical separation cannot be achieved, noise conflicts are resolved using the following design solutions: • Double or acoustic glazing • Acoustic seals • Use of materials with low noise penetration properties • Continuous walls to ground level courtyards where they do not conflict with streetscape or other amenity requirements	Physical separation through discontinuous wall construction of party walls.	YES
4J	NOISE & POLLUTION		
4J-1	Objective: In noisy or hostile environments impacts of external noise & pollution are minimised through careful siting & layout		✓
	Design Guidance		
	To minimise impacts the following design solutions are used: • Physical separation between buildings & the noise or pollution source • Residential uses are located perpendicular to the noise source & where possible buffered by other uses • Non-residential buildings are sited to be parallel with the noise source to provide a continuous building that shields residential uses & communal open spaces • Non-residential uses are located at lower levels vertically separating residential component from noise or pollution source. Setbacks to the underside of residential floor levels are increased, relative to traffic volumes & other noise sources • Buildings respond to both solar access & noise. Where solar access is away from noise source, non-habitable rooms will provide a buffer • Where solar access is in the same direction as the noise source, dual aspect apartments with shallow building depths are preferred • Landscape design reduces the perception of noise & acts as a filter for air pollution generated by traffic & industry	Mixed use podium for 4 levels with landscaped communal open space above. Residential tower starting from Level 6 creates separation from surrounding streets noise pollution. Acoustic mitigation measures such as increased balustrade heights have been coordinated with acoustic consultant.	YES

ADG Ref.	Item Description	Notes	Compliance
	Where developments are unable to achieve Design Criteria, alternatives are considered in the following areas: • Solar & daylight access • Private open space & balconies • Natural cross ventilation		N/A
4J-2	Objective: Appropriate noise shielding or attenuation techniques for building design, construction & choice of materials are used to mitigate noise transmission		✓
	Design Guidance		
	Design solutions to mitigate noise include: • Limiting the number & size of openings facing noise sources • Providing seals to prevent noise transfer through gaps • Using double or acoustic glazing, acoustic louvres or enclosed balconies (wintergardens) • Using materials with mass and/or sound insulation or absorption properties eg solid balcony balustrades, external screens & soffits		YES
4K	APARTMENT MIX		
4K-1	Objective: A range of apartment types & sizes is provided to cater for different household types now & into the future		✓
	Design Guidance		
	A variety of apartment types is provided	1 bed – 3 bed apartments are provided	YES
	The apartment mix is appropriate, taking into consideration: • Distance to public transport, employment & education centres • Current market demands & projected future demographic trends • Demand for social & affordable housing • Different cultural & socioeconomic groups	Monetary contribution for affordable housing.	YES
	Flexible apartment configurations are provided to support diverse household types & stages of life including single person households, families, multi-generational families & group households		YES
4K-2	Objective: The apartment mix is distributed to suitable locations within the building		✓
	Design Guidance		

ADG Ref.	Item Description	Notes	Compliance
	Different apartment types are located to achieve successful façade composition & to optimise solar access		YES
	Larger apartment types are located on ground or roof level where there is potential for more open space, and on corners where more building frontage is available	Larger apartments located on higher levels of the apartment with corner aspects and increased POS, as well as larger balconies for penthouses	YES
4L	GROUND FLOOR APARTMENTS		
4L-1	Objective: Street frontage activity is maximised where ground floor apartments are located	No ground floor apartments	N/A
	Design Guidance		
	Direct street access is provided to ground floor apartments		N/A
	Activity is achieved through front gardens, terraces & the façade of the building. Design solutions include: - Both street, foyer & other common internal circulation entrances to ground floor apartments - Private open space is next to the street - Doors & windows face the street		N/A
	Retail or home office spaces are located along street frontages		N/A
	Ground floor apartment layouts support SOHO use & provide opportunities for future conversion into commercial or retail areas. In these cases higher floor to ceiling heights & easy conversion to ground floor amenities are provided.		N/A
4L-2	Objective: Design of ground floor apartments delivers amenity & safety for residents		N/A
	Design Guidance		
	Privacy & safety are provided without obstructing casual surveillance. Design solutions include: - Elevating private gardens & terraces above the street level by 1-1.5m - Landscaping & private courtyards - Window sill heights minimise sight lines into apartments - Integrating balustrades, safety bars or screens with exterior design		N/A
	Solar access is maximised through: - High ceilings & tall windows - Trees & shrubs allow solar access in winter & shade in summer		N/A

ADG Ref.	Item Description	Notes	Compliance
4M	FACADES		
4M-1	Objective: Building facades provide visual interest along the street while respecting the character of the local area		✓
	Design Guidance		
	Design solutions for front building facades include: • Composition of varied building elements • Defined base, middle & top of buildings • Revealing & concealing certain elements	Defined podium response and tower response highlighting the building address and main entrances, and defining the podium, tower and crown.	YES
	Building services are integrated within the overall facade	Rooftop plant concealed within articulated architectural façade, Lower Ground services integrated into façade.	YES
	Building facades are well resolved with appropriate scale & proportion to streetscape & with consideration of human scale. Solutions include: • Well composed horizontal & vertical elements • Variation in floor heights to enhance the human scale • Elements that are proportional & arranged in patterns • Public artwork or treatments to exterior blank walls • Grouping of floors or elements such as balconies & windows on taller buildings		YES
	Building facades relate to key datum lines of adjacent buildings through upper level setbacks, parapets, cornices, awnings or colonnade heights	Four storey podium street wall proposed in compliance with TOD controls. Tower setback from podium.	YES
	Shadow is created on the facade throughout the day with building articulation, balconies & deeper window reveals	Balconies and vertical shading devices creates changing shadows.	YES
4M-2	Objective: Building functions are expressed by the facade		✓
	Design Guidance		
	Building entries are clearly defined	Recess in façade creates a break in the podium and highlights lobby locations.	YES
	Important corners are given visual prominence through change in articulation, materials or colour, roof expression or changes in height		YES
	Apartment layout is expressed externally through facade features such as party walls & floor slabs		YES

ADG Ref.	Item Description	Notes	Compliance
4N	ROOF DESIGN		
4N-1	Objective: Roof treatments are integrated into the building design & positively respond to the street		✓
	Design Guidance		
	Roof design relates to the street. Design solutions include: • Special roof features & strong corners • Use of skillion or very low pitch hipped roofs • Breaking down the massing of the roof by using smaller elements to avoid bulk • Using materials or pitched form complementary to adjacent buildings	Flat roof concealed within façade detail.	YES
	Roof treatments are integrated with the building design. Design solutions include: • Roof design is in proportion to the overall building size, scale & form • Roof materials compliment the building • Service elements are integrated		YES
4N-2	Objective: Opportunities to use roof space for residential accommodation & open space are maximised		✓
	Design Guidance		
	Habitable roof space are provided with good levels of amenity. Design solutions include: • Penthouse apartments • Dormer or clerestory windows • Openable skylights	Able to comply.	YES
	Open space is provided on roof tops subject to acceptable visual & acoustic privacy, comfort levels, safety & security considerations		NO
4N-3	Objective: Roof design incorporates sustainability features		✓
	Design Guidance		
	Roof design maximises solar access to apartments during winter & provides shade during summer. Design solutions include: • Roof lifts to the north • Eaves & overhangs shade walls & windows from summer sun	Shading devices integrated with façade design and stacked balconies provide shade from hot east and west summer sun.	YES
	Skylights & ventilation systems are integrated into the roof design	No skylights proposed.	YES
4O	LANDSCAPE DESIGN		

ADG Ref.	Item Description	Notes	Compliance
4O-1	Objective: Landscape design is viable & sustainable		✓
	Design Guidance		
	Landscape design is environmentally sustainable & can enhance environmental performance by incorporating: • Diverse & appropriate planting • Bio-filtration gardens • Appropriately planted shading trees • Areas for residents to plant vegetables & herbs • Composting • Green roofs or walls	(Refer to documentation prepared by Tract as a part of submission)	YES
	Ongoing maintenance plans are prepared	(Refer to documentation prepared by Tract as a part of submission)	YES
	Microclimate is enhanced by: • Appropriately scaled trees near the eastern & western elevations for shade • Balance of evergreen & deciduous trees to provide shading in summer & sunlight access in winter • Shade structures such as pergolas for balconies & courtyards	(Refer to documentation prepared by Tract as a part of submission)	YES
	Tree & shrub selection considers size at maturity & the potential for roots to compete.	(Refer to documentation prepared by Tract as a part of submission)	YES
4O-2	Objective: Landscape design contributes to streetscape & amenity	(Refer to documentation prepared by Tract as a part of submission)	✓
	Design Guidance		
	Landscape design responds to the existing site conditions including: • Changes of levels • Views • Significant landscape features including trees & rock outcrops	(Refer to documentation prepared by Tract as a part of submission)	YES
	Significant landscape features are protected by: • Tree protection zones • Appropriate signage & fencing during construction	(Refer to documentation prepared by Tract as a part of submission)	N/A
	Plants selected are endemic to region & reflect local ecology.	(Refer to documentation prepared by Tract as a part of submission)	YES

ADG Ref.	Item Description	Notes	Compliance								
4P	PLANTING ON STRUCTURES										
4P-1	Objective: Appropriate soil profiles are provided	(Refer to documentation prepared by Tract as a part of submission)	✓								
	Design Guidance										
	Structures are reinforced for additional saturated soil weight	(Refer to documentation prepared by Tract and Meinhardt as a part of submission)	YES								
	Soil volume is appropriate for plant growth, including: - Modifying depths & widths according to planting mix & irrigation frequency - Free draining & long soil life span - Tree anchorage	(Refer to documentation prepared by Tract as a part of submission)	YES								
	Minimum soil standards for plant sizes should be provided in accordance with <table><tr><th>Site Area (sqm)</th><th>Recommended Tree Planting</th></tr><tr><td>Up to 850</td><td>1 medium tree per 50sqm of deep soil zone</td></tr><tr><td>850 – 1,500</td><td>1 large tree or 2 medium trees per 90sqm of deep soil zone</td></tr><tr><td>Greater than 1,500</td><td>1 large tree or 2 medium trees per 80sqm of deep soil zone</td></tr></table>	Site Area (sqm)	Recommended Tree Planting	Up to 850	1 medium tree per 50sqm of deep soil zone	850 – 1,500	1 large tree or 2 medium trees per 90sqm of deep soil zone	Greater than 1,500	1 large tree or 2 medium trees per 80sqm of deep soil zone	(Refer to documentation prepared by Tract as a part of submission)	YES
Site Area (sqm)	Recommended Tree Planting										
Up to 850	1 medium tree per 50sqm of deep soil zone										
850 – 1,500	1 large tree or 2 medium trees per 90sqm of deep soil zone										
Greater than 1,500	1 large tree or 2 medium trees per 80sqm of deep soil zone										
4P-2	Objective: Plant growth is optimised with appropriate selection & maintenance	(Refer to documentation prepared by Tract as a part of submission)	✓								
	Design Guidance										

ADG Ref.	Item Description	Notes	Compliance
	Plants are suited to site conditions, considerations include: • Drought & wind tolerance • Seasonal changes in solar access • Modified substrate depths for a diverse range of plants • Plant longevity	(Refer to documentation prepared by Tract as a part of submission)	YES
	A landscape maintenance plan is prepared	(Refer to documentation prepared by Tract as a part of submission)	YES
	Irrigation & drainage systems respond to: • Changing site conditions • Soil profile & planting regime • Whether rainwater, stormwater or recycled grey water is used	(Refer to documentation prepared by Tract as a part of submission)	YES
4P-3	Objective: Planting on structures contributes to the quality & amenity of communal & public open spaces	(Refer to documentation prepared by Tract as a part of submission)	✓
	Design Guidance		
	Building design incorporates opportunities for planting on structures. Design solutions include: • Green walls with specialised lighting for indoor green walls • Wall design that incorporates planting • Green roofs, particularly where roofs are visible from the public domain • Planter boxes Note: structures designed to accommodate green walls should be integrated into the building facade & consider the ability of the facade to change over time	(Refer to documentation prepared by Tract as a part of submission)	YES
4Q	UNIVERSAL DESIGN		
4Q-1	Objective: Universal design features are included in apartment design to promote flexible housing for all community members		✓
	Design Guidance		
	Developments achieve a benchmark of 20% of the total apartments incorporating the Liveable Housing Guideline's silver level universal design features	37/181 (20%) of units are silver level.	YES
4Q-2	Objective: A variety of apartments with adaptable designs are provided		
	Design Guidance		
	Adaptable housing should be provided in accordance with the relevant council policy	37/181 (20%) of units are adaptable.	YES

ADG Ref.	Item Description	Notes	Compliance
	Design solutions for adaptable apartments include: • Convenient access to communal & public areas • High level of solar access • Minimal structural change & residential amenity loss when adapted • Larger car parking spaces for accessibility • Parking titled separately from apartments or shared car parking arrangements		YES
4Q-3	Objective: Apartment layouts are flexible & accommodate a range of lifestyle needs		✓
	Design Guidance		
	Flexible design solutions include: • Rooms with multiple functions • Dual master bedroom apartments with separate bathrooms • Larger apartments with various living space options • Open plan 'loft' style apartments		YES
4R	ADAPTIVE REUSE		
4R-1	Objective: New additions to existing buildings are contemporary, complementary & enhance area's identity & sense of place		N/A
	Design Guidance		
	Design solutions include: New elements align with the existing building Additions complement the existing character, siting, scale, proportion, pattern, form & detailing Contemporary & complementary materials, finishes, textures & colours		N/A
	Additions to heritage items are clearly identifiable from the original building		N/A
	New additions allow for interpretation & future evolution of the building		N/A
4R-2	Objective: Adapted buildings provide residential amenity but does not precluding future adaptive reuse		N/A
	Design Guidance		
	Design features are incorporated sensitively to make up for any physical limitations, to ensure residential amenity. Design solutions include: • Generously sized voids in deeper buildings • Alternative apartment types when orientation is poor • Additions to expand the existing building envelope		N/A

ADG Ref.	Item Description	Notes	Compliance
	Where developments are unable to achieve Design Criteria, alternatives are considered in the following areas: • Where there are existing higher ceilings, depths of habitable rooms can increase subject to demonstrating access to natural ventilation, cross ventilation (when applicable) and solar & daylight access (see 4A & 4B) • Alternatives to providing deep soil where less than the minimum requirement is currently available on the site • Building & visual separation subject to demonstrating alternative design approaches to achieving privacy • Common circulation • Car parking • Alternative approaches to private open space & balconies		N/A
4S	MIXED USE		
4S-1	Objective: Mixed use developments are provided in appropriate locations & provide active street frontages that encourage pedestrian movement.		✓
	Design Guidance		
	Mixed use developments are concentrated around public transport & centres		YES
	Mixed use developments positively contribute to the public domain. Design solutions include: • Development addresses the street • Active frontages provided • Diverse activities & uses • Avoiding blank walls at the ground level • Live/work apartments on the ground floor level, rather than commercial	Active Ground Floor frontage provided, with retail offerings that address street corners.	YES
4S-2	Objective: Residential levels of the building are integrated within the development. Safety & amenity is maximised		✓
	Design Guidance		
	Residential circulation areas are clearly defined. Solutions include: • Residential entries separated from commercial entries & directly accessible from the street • Commercial service areas separated from residential components • Residential car parking & communal facilities separated or secured • Security at entries & safe pedestrian routes are provided • Concealment opportunities are avoided	Residential entry clearly defined through architecture and awning approach and separate from commercial entries.	YES

ADG Ref.	Item Description	Notes	Compliance
	Landscaped communal open space are provided at podium or roof	Provided at top of podium level.	YES
4T	AWNING & SIGNAGE		
4T-1	Objective: Awnings are well located and complement & integrate with the building design.		✓
	Design Guidance		
	Awnings are located along streets with high pedestrian activity & active frontages	Built form creates a podium over main building entrances, the eastern and south public space/ entries are protected with the use of tree planting rather than awnings.	YES
	A number of the following design solutions are used: - Continuous awnings are maintained & provided in areas with an existing pattern - Height, depth, material & form complements existing street character - Protection from sun & rain is provided - Awnings are wrapped around secondary frontages of corner sites - Awnings are retractable in areas without an established pattern	Awning in the form of building overhang and dedicated glazed awning provided along Atchison Street.	YES
	Awnings are located over building entries for building address & public domain amenity		YES
	Awnings relate to residential windows, balconies, street tree planting, power poles & street infrastructure		YES
	Gutters & down pipes are integrated and concealed		YES
	Lighting under awnings is provided for pedestrian safety		YES
4T-2	Objective: Signage responds to context & desired streetscape character.		✓
	Design Guidance		
	Signage is integrated into building design & respond to scale, proportion & detailing of the development		YES
	Legible & discrete way finding is provided for larger developments		YES
	Signage is limited to being on & below awnings, and single façade sign on primary street frontages		YES
4U	ENERGY EFFICIENCY		
4U-1	Objective: Development incorporates passive environmental design.		✓
	Design Guidance		

ADG Ref.	Item Description	Notes	Compliance
	Adequate natural light is provided to habitable rooms (see 4A Solar & Daylight Access)		YES
	Well located, screened outdoor areas are provided for clothes drying		YES
4U-2	Objective: Passive solar design is incorporated to optimize heat storage in winter & reduce heat transfer in summer.		✓
	Design Guidance		
	A number of the following design solutions are used: • Use of smart glass or other on north & west elevations • Thermal mass maximised in floors & walls of north facing rooms • Polished concrete floors, tiles or timber rather than carpet • Insulated roofs, walls & floors. Seals on window & door openings • Overhangs & shading devices such as awnings, blinds & screens	Refer to Basix report for further information.	YES
	Provision of consolidated heating & cooling infrastructure is located in a centralised location (eg basement)	Provided on rooftop plant.	YES
4U-3	Objective: Adequate natural ventilation to minimise the need for mechanical ventilation.		✓
	Design Guidance		
	A number of the following design solutions are used: • Rooms with similar usage are grouped together • Natural cross ventilation for apartments is optimised • Natural ventilation is provided to all habitable rooms & as many non-habitable rooms, common areas & circulation spaces as possible	Natural ventilation is provided to all habitable rooms.	YES
4V	WATER MANAGEMENT & CONSERVATION		
4V-1	Objective: Potable water use is minimised		✓
	Design Guidance		
	Water efficient fittings, appliances & wastewater reuse are incorporated		YES
	Apartments are individually metered		YES
	Rainwater is collected, stored & reused on site	10kL rain water tank provided.	YES
	Drought tolerant, low water use plants are used within landscaped areas	(Refer to documentation prepared by Tract as a part of submission)	YES
4V-2	Objective: Urban stormwater is treated on site before being discharged to receiving waters.		YES

ADG Ref.	Item Description	Notes	Compliance
	Design Guidance		
	Water sensitive urban design systems are designed by a suitably qualified professional	(Refer to documentation prepared by Meinhardt as a part of submission)	YES
	A number of the following design solutions are used: • Runoff is collected from roofs & balconies in water tanks and plumbed into toilets, laundry & irrigation • Porous & open paving materials is maximised • On site stormwater & infiltration, including bio-retention systems such as rain gardens or street tree pits	(Refer to documentation prepared by Meinhardt as a part of submission)	YES
4V-3	Objective: Flood management systems are integrated into site.		
	Design Guidance		
	Detention tanks are located under paved areas, driveways or in basement car parks	(Refer to documentation prepared by Meinhardt as a part of submission)	YES
	On large sites, parks or open space to provide temporary on site detention basins		N/A
4W	WASTE MANAGEMENT		
4W-1	Objective: Waste storage facilities are designed to minimise impacts on streetscape, building entry & amenity of residents.		✓
	Design Guidance		
	Adequately sized storage areas for rubbish bins are located discreetly away from the front of the development or in basement car park		YES
	Waste & recycling storage areas are well ventilated		YES
	Circulation design allows bins to be easily manoeuvred between storage & collection points		YES
	Temporary storage area provided for large bulk items such as mattresses		YES
	Waste management plan is prepared	(Refer to documentation prepared by Salt ³ as a part of submission)	YES
4W-2	Objective: Domestic waste is minimised by providing safe & convenient source separation & recycling.		✓
	Design Guidance		

ADG Ref.	Item Description	Notes	Compliance
	All dwellings have a waste & recycling cupboard or temporary storage area of sufficient size to hold two days worth of waste & recycling		YES
	Communal waste & recycling rooms are in convenient & accessible locations related to each vertical core		YES
	For mixed use developments, residential waste & recycling storage areas & access is separate & secure from other uses		YES
	Alternative waste disposal methods such as composting is provided	(Refer to documentation prepared by Salt ³ as a part of submission)	YES
4X	BUILDING MAINTENANCE		
4X-1	Objective: Building design detail provides protection from weathering.		✓
	Design Guidance		
	A number of the following design solutions are used: • Roof overhangs to protect walls • Hoods over windows & doors to protect openings • Detailing horizontal edges with drip lines to avoid staining surfaces • Methods to eliminate or reduce planter box leaching • Appropriate design & material selection for hostile locations		YES
4X-2	Objective: Systems & access enable ease of maintenance		
	Design Guidance		
	Window design enables cleaning from the inside of the building	Building maintenance systems are incorporated & integrated into the design of the building form, roof & facade	NO
	Building maintenance systems are incorporated & integrated into the design of the building form, roof & facade		YES
	Design does not require external scaffolding for maintenance access		YES
	Manually operated systems such as blinds, sunshades & curtains are used in preference to mechanical systems		YES
	Centralised maintenance, services & storage are provided for communal open space areas within the building		YES

ADG Ref.	Item Description	Notes	Compliance
4X-3	Objective: Material selection reduces ongoing maintenance costs.		✓
	Design Guidance		
	A number of the following design solutions are used: • Sensors to control artificial lighting in common circulation & spaces • Natural materials that weather well & improve with time, such as face brickwork • Easily cleaned surfaces that are graffiti resistant • Robust & durable materials & finishes in locations which receive heavy wear & tear such as common circulation areas & lift interiors		YES

Further to the above ADG Compliance Table we confirm that we have directed the design of the development at 20-22 Atchison Street, St Leonards. The design has been prepared in accordance with the design quality principles and requirements set out in Chapter 4 of the Housing SEPP - Design Quality of Residential Flat Development and the objectives of the Apartment Design Guide.

Ramin Jahromi is registered as an architect in accordance with the NSW Architects Act 2003. Registration Number is ARB 10,000.



Ramin Jahromi