

Company Name:	CI Property
To:	Department of Planning and Environment
From:	Ethos Urban
Date:	10 January 2018
Re:	Design Guidelines Compliance
Project Name:	Nulon Motor Oils Warehouse
Project No:	17650

Compliance with Design Guidelines

Table 1 – Proposed development compliance with the Concept Approval Design Guidelines

Control	Compliance
2.1 Setbacks	
Objectives: - To encourage buildings that respond to the relative position of the site. - To provide an open streetscape with substantial areas for landscaping. To ensure the provision of appropriate buffers to Bringelly Road, Stuart Road and internal roads that softens the visual impact of the development whilst allowing visibility to appropriate development.	
Controls:	
a) Buildings are to be setback by: 20m from Bringelly Road; 15m from Stuart Road; and 10m from the internal road (former Bringelly Road).	Compliant.
b) At least a third of the above building setbacks are to be landscaped. The non-landscaping component of the setback may be used for access driveways and off-street parking areas within the front setback if it can be demonstrated that the location of the car parking area: - promotes the function and operation of the development; - enhances the overall design of the development by implementing design elements including landscaping, that: - will screen the parking area; - is complementary to the development; and - does not detract from the streetscape values of the locality.	The location of the parking is generally compliant, as the staff parking is located adjacent to the entry of the building, promoting the function and operation of the development. The combination of the internal street trees (within the Concept Approval), and landscaping elements included within the proposed detailed Landscape Plan, will appropriately screen the proposed car parking, as well as enhance the consistency and streetscape value of the locality.
Storage of any kind is not permitted within the building setback area.	Compliant.
Zero side and rear setbacks are permitted between allotments subject to meeting fire rating requirements.	N/A
Pedestrian access should be provided to all landscaped setback areas for maintenance and security purposes.	Compliant.

Control	Compliance
5. A setback of 15m from the northern boundary (where it adjoins the riparian corridor associated with Bedwell Park wetland area), and 10m from the eastern boundary.	Compliant.
2.2 Site Coverage	
Objectives: - To ensure that adequate area is available to accommodate landscaping, open space for employees and screening of loading and storage areas. - To ensure that adequate area is available for driveways and access, onsite parking and manoeuvring of vehicles. To achieve appropriate building setbacks that are landscaped to ensure integration with streetscape and street tree planting.	
Controls:	
1. Site coverage is not to exceed 50% for Large Format Retail development. Site coverage includes the footprint of all buildings and canopy areas (excluding hard stand areas).	N/A The proposed development does not comprise Large Format Retail.
2.3 Built form and Design	
Objectives: To encourage buildings that are of architectural merit, diversity, scale and high quality built form. To encourage a built form that contributes to the visual amenity of the site.	
Controls:	
1. Applicants are to give consideration to optimising building orientation and siting to natural elements such as topography, wind and sunlight, energy efficiency and to maximise weather conditions for loading and unloading.	Compliant.
2. Applicants are to consider a range of fascia treatments, facade treatments, rooflines and building materials to reduce the impact of walls facing the street.	Compliant. The proposal varies materiality throughout all elevations of the proposed development. The proposal avoids blank walls on the southern elevation facing Skyline Crescent, and includes a combination of colours and materials on the façade of the blank wall facing east.
3. The maximum building height is 14m. Taller buildings will be permitted where it can be demonstrated that: - the proposed height is in keeping with the character of the locality; - the building, or any part thereof, is not visually obtrusive; and - the overall design of the development, including landscaping and building materials, reduces the impact of height and bulk of the building.	Compliant. The proposed building height is 13.7m.
4. Goods, plant, equipment and other material resulting from the development are to be stored within a building or will be suitably screened from view from residential areas.	Compliant.
5. Development which can be viewed from residential properties will require special attention regarding the scale, form and external finishes of buildings, to reduce their visual impact.	Compliant. The proposal includes a 5m landscaped buffer zone along the eastern boundary, to screen and improve the outlook from residential properties located to the east.
6. Development should incorporate the Crime Prevention Through Environmental Design (CPTED) principles where appropriate.	Compliant.
7. Prominent elevations, such as those with a frontage to the street or public reserves, must present a building form of significant architectural and design merit.	Compliant.

Control	Compliance
8. Large elevations should be articulated by structural variations and/or a blend of external finishes. Additionally, the landscape design should consider the scale of the building and where appropriate, the location of and careful selection of plants may aid in reducing the bulk and scale of the building form.	Compliant.
9. Particular care should also be taken in: - designing roof elements; and - locating plant and mechanical equipment including exhausts, so as to screen them from a public place.	Compliant.

2.4 External Materials and Colours

Objectives:

- To encourage a high standard of contemporary architectural design, utilising quality materials and finishes appropriate to the locality.
 - To ensure that new development contributes to the creation of a visually cohesive urban environment.
- To encourage the innovative use of materials.

Controls:

1. Highly reflective materials, including white or off-white metal colours should be minimised. In this regard, the roof material(s) to be used shall not be reflective.	Compliant.
2. Courtyard and screen walls should generally be in the same material as the building facades.	Compliant.
3. The development is to incorporate a variety of external finishes in terms of both colour and type of material used. The external finishes of the development are to be: - made from durable high quality, low maintenance materials; - compatible with the overall design and form of the development; - selected for all built forms to ensure the entire development presents a homogeneous form; - considered for their ability to provide visual relief in large wall surfaces and elevations; and - selected to ensure the development complements the surrounding environment while reducing the temptation to vandalism and graffiti.	Compliant. Refer to external finishes included within Architectural Plans included within the EIS.

2.5 Entrance Treatment

Objectives:

- To provide an active frontage and level of surveillance to the street.
- To ensure an identifiable entrance point to the property and building.

Controls:

1. Entries to buildings should be clearly visible to pedestrians and motorists and be integrated into the form of the building.	Compliant.
2. Architectural features are to be provided at ground level and are to address the primary street frontage.	Compliant.
3. All entrance treatments, such as directory boards, must be located on private property, with appropriate management arrangements to ensure that the ongoing maintenance of such treatments.	Compliant.
4. Entries should be articulated through the use of colour, signage, lighting, material change and texture, and strengthened through landscape design.	Compliant.

2.6 Staff Amenities

Objectives:

To provide facilities for workers.

Control	Compliance
Controls:	
1. Outdoor spaces should be provided for staff. The spaces should be easily accessible from the buildings and should maximise site opportunities such as views and solar access.	Compliant.
2. Opportunities for shade should be provided in outdoor staff amenity areas.	Compliant.
3. Within each development shower and change facilities shall be provided for staff. This is designed especially to encourage employees to access the site by bicycle or on foot.	Compliant.
2.7 Fencing and Walls	
Objectives:	
1. To provide an appropriate level of security for property owners and contribute to the amenity of the Precinct. 2. To encourage pedestrian access to businesses from the street. 3. To ensure that fences and walls respond to the topography, streetscape and landscape. To enhance the visual outlook of adjoining rural residential properties.	
Controls:	
1. Fencing may be positioned along the front property boundary only if: • it is decorative fencing that has an open style appearance (metal, pool type fencing); and • the fencing is complementary to the landscaping.	Compliant. The proposed property fencing has an open style appearance.
2. Solid front fences must have a maximum height of 1.2m.	N/A fence is open style.
3. Front fences higher than 1.2m shall be consistent with the following: • maximum height of 2m; • transparent; and • dark colour.	Compliant.
4. Fences should not prevent surveillance by the building's occupants of the main open or communal areas within the property or street frontage.	Compliant.
5. Chain wire, metal sheeting, brushwood or electric fences are not permitted.	Non-Compliant. The proposal includes chain wire fencing along the side and rear boundaries, however will be screened by landscaping.
6. Cyclone fencing may be used on side and rear boundaries which do not front roads.	Compliant
7. Fencing required for acoustic mitigation purposes shall be suitably screened with landscaping or the like.	N/A
2.8 Signage and Lighting	
Objectives:	
1. To promote an integrated design approach to all signage in character with the locality, and its architectural and landscape features. 2. To prevent the proliferation of advertising signs. To prevent distraction to motorists and minimise the potential for traffic conflicts.	
Controls:	
1. All advertising is to be: • constructed of high quality, durable materials; • considered in conjunction with the design and construction of buildings; and • contained wholly within the site.	Compliant.

Control	Compliance
2. In the case of strata titled factory units: - each factory unit development should have a directory board within or near the landscape area listing each firm and their unit number within the complex; - subject to compliance with the exempt development requirements; and - each firm is entitled to have: - a sign located on or over the door of the unit so occupied; and - another sign placed on the face of the building(s).	N/A
3. lighting must be provided to external entry path, common lobby, driveway and car park to a building using vandal resistant, high mounted light fixtures.	Compliant.
4. The lighting in car park areas must conform to AS 1158.1, 1680 and 2890.1.	Compliant.
5. External lighting must give consideration to the impact of glare on adjoining residents.	Compliant.

2.9 Landscaping

Objectives:

- To encourage a well-designed, legible and cohesive landscape framework for development/project application.
 - To ensure landscape plans submitted to Council are of a high standard, and that all landscaping is carried out and maintained to an appropriate level on completion of the development.
 - To screen undesirable views and minimise the visual impact of hard surface areas.
 - To encourage and build upon the landscape of the adjoining Bedwell Park Westland area and existing vegetation.
- To encourage the use of both hard and soft landscape to assist in creating comfortable micro climate conditions, and enhancing the environmental amenity of the development and the Precinct.

Controls:

1. A detailed Landscape Plan shall accompany a development application for future development for buildings on the site. The Landscape Plan shall be prepared by a suitably qualified Landscape architect.	Compliant. A Landscape Plan has been provided within the DA and supporting EIS Report prepared by Ethos Urban. This proposed detailed landscape plan, is consistent with the Landscape Plan of the Concept Approval (SSD 6324).
2. The Landscape Plan shall be consistent with the site landscape plans prepared for the site by Arcadia Landscape Architecture dated December 2014.	Compliant.
3. Native species should be used due to their low maintenance, relative fast growth, aesthetic appeal and suitability to the natural habitat.	Compliant.
4. The landscape must conform to the bushfire requirements, specifically when planting within Defendable Spaces.	Compliant.
5. Presentation of a building facade to the street should be complemented with appropriate vegetation. The visual impact of large expanses of wall should be reduced in scale by architectural treatment as well as by dense grove planting or other landscape design solutions.	Compliant. A Visual Impact Analysis has been prepared for the proposed development, and is included within the EIS.
6. Landscape materials should cause minimal detrimental visual impact, and the use of subtle coloured materials and block or brick paving is encouraged. Paving and structures shall complement the architectural style of existing buildings.	Compliant
7. Consideration should be given to solar access and energy conservation, with the appropriate use of deciduous trees.	Compliant
8. Plant material in car parks should be used ameliorate views of large expanses of paved areas and parked cars, and to identify entrances to car parks.	Compliant.
9. Island planting beds should be interspersed throughout large parking areas.	Compliant.

Control	Compliance
3.1 Local Road Network	
Objectives: - To provide adequate vehicular entrance to and exit from the development in a manner that is safe for pedestrians and vehicles using the site and adjacent roadways. - To incorporate a road layout that is well connected, displays a legible street hierarchy that will accommodate anticipated traffic volumes and vehicle types, and permits access to allotments via roads. To incorporate a road layout that provides safe access for the needs of all users including large trucks, pedestrians and cyclists.	
Controls:	
1. Development should comply with the road design principles identified in Roads and Traffic Authority, Road Design Guidelines; and Roads and Traffic Authority, Guide to Traffic Generating Development (1993) in relation to the number, locations and design of any vehicular entry and exit points and/or certain road construction works.	N/A. Internal roads will be completed as part of existing Concept Approval.
2. All roads and intersections within any internal road network shall incorporate traffic facilities that promote safe and efficient traffic movement, speed control and maximise landscape opportunities.	N/A. Internal roads will be completed as part of existing Concept Approval.
3. The Internal road design shall be consistent with Figure 2 .  Figure 2 – Typical Local Road Section Source: Arcadia Landscape Architects	N/A. Internal roads will be completed as part of existing Concept Approval.
3.2 Site Access and Movement	
Objectives: To ensure the safe and efficient movement of vehicles and pedestrians within a development site.	
Controls:	
1. Truck access, manoeuvring and loading areas are to be separated from car parking areas.	Compliant.
2. Development shall, where appropriate, be designed to: - allow all vehicles to either leave or enter the site in a forward direction; - accommodate heavy vehicle parking and manoeuvring areas; - avoid conflict with staff, customer and visitor vehicular movements; and - ensure satisfactory and safe operation with the adjacent road system.	Compliant.
3. In determining access, servicing and car parking requirements, Council will take the following into consideration: - the location, type and scale of the proposed development; - the compatibility of the location and design of the car park with adjoining properties; - the Traffic Authority Guidelines and comments of the Local or Regional Traffic Committee(s); and - the potential for the land use to generate heavy vehicle movements.	Compliant. A traffic and parking assessment has been prepared for the proposed development, and is included with the EIS.

Control	Compliance
Full details of the volume, frequency and type of vehicle movements shall be submitted with future applications.	
4. Where the nature of the development will attract clients/visitors to the site, the following elements shall be included in the car park design: - the internal (vehicular) circulation network is to be free of disruption to circulating traffic and ensures pedestrian safety; and - the movement of pedestrians throughout the car park is clearly delineated by all users of the car park and minimises conflict with vehicles.	Compliant.
5. All internal two-way roadways are to have a minimum width of 7m. Lesser widths may be considered for one-way internal access roads. All internal roadways, circulation and parking areas are to be sealed with a hard-standing, all-weather material.	Compliant.
6. Direction arrows are to be shown on all internal roadways in order to satisfactorily facilitate the movement of vehicles.	Compliant.
7. All loading and unloading must take place on-site. Adequate space is to be provided within the site for the loading, unloading and fuelling (if applicable) of vehicles.	Compliant. The proposal includes sufficient space of 1,057 m ² for loading/unloading on-site.

3.3 On-site Parking

Objectives:

To ensure that safe and sufficient car parking shall be provided on each lot to satisfy the likely peak parking demands of the development.

Controls:

1. Parking is to be provided in accordance with the minimum requirements in Table 1 . Table 1 – Car Parking Requirements <table> <tr> <th>Land Use</th><th>Minimum car parking requirements</th></tr> <tr> <td>Large Format Retail</td><td> - Large Format Retail: 1 space per 150m² GFA </td></tr> <tr> <td>Industrial / Warehouse</td><td> - Office: 1 space / 40m² GFA - Factory: 1 space / 100m² GFA for the first 100m², then 1 space / 200m² GFA (includes office component) - Warehouse: 1 space / 300m² GFA + 1 space / 40m² office </td></tr> </table> * GFA (Gross Floor Area) as defined in the Standard LEP template.	Land Use	Minimum car parking requirements	Large Format Retail	Large Format Retail: 1 space per 150m² GFA	Industrial / Warehouse	- Office: 1 space / 40m² GFA - Factory: 1 space / 100m² GFA for the first 100m², then 1 space / 200m² GFA (includes office component) - Warehouse: 1 space / 300m² GFA + 1 space / 40m² office	Compliant. The proposed development provides more than the minimum parking requirements outlined within Table 1 .
Land Use	Minimum car parking requirements						
Large Format Retail	Large Format Retail: 1 space per 150m² GFA						
Industrial / Warehouse	- Office: 1 space / 40m² GFA - Factory: 1 space / 100m² GFA for the first 100m², then 1 space / 200m² GFA (includes office component) - Warehouse: 1 space / 300m² GFA + 1 space / 40m² office						
2. One bicycle parking space shall be provided per 10 car spaces.	Compliant.						
3. Car parks, aisles and manoeuvring areas shall be designed with function and safety in mind, and have minimum dimensions in conformity with the Australian Standards 2890 - Parking Facilities. The relevant parts of this standard are AS2890. Off-street parking, AS2890.2 – Commercial vehicle facilities, and AS2890.3 - Bicycle parking facilities.	Compliant.						
4. Where parking spaces are to be provided for people with disabilities, these spaces are to be: - suitably located near entrances to the building, lifts and access ramps (if required); and - provided in accordance with AS1428.1 – Design for Access and Mobility.	Compliant.						
5. Parking facilities for commercial vehicles should be designed to accommodate the largest type of truck which could be reasonably expected to park on the site.	Compliant.						
6. All parking areas shall be constructed of hard-standing, all-weather material, with parking bays and circulation aisles clearly delineated.	Compliant.						