



Advisian

WorleyParsons Group

Advisian
Level 12, 141 Walker St
North Sydney NSW 2060
Australia

Trading as WorleyParsons
Services Pty Ltd
ABN: 61 001 279 812

P: +61 2 8923 6866

www.advisian.com

17 December 2021

Peter Wark
Associate Director
at&l
Level 7 153 Walker Street
North Sydney NSW 2060

By email: peter.w@atl.net.au

Dear Peter

SYDNEY FISH MARKETS – TIDAL IMACTS OF PROPOSED CONSTRUCTION METHOD

I have reviewed the tidal impacts of the proposed method of construction comprising capping the seabed beneath the structure to allow works to be undertaken in the dry, as depicted in the sketches ATL-CV-SKT-00041, 00042, 00043 and 00044 dated 24-11-21.

The works associated with this method would have no impact on the tidal prism of Sydney Harbour as the works proposed would be undertaken entirely below the lowest tidal level. Further, the works would allow for the incorporation of sediment discharged from the Central Culvert and would allow for the free flow of tidal streams beneath the Sydney Fish Markets once completed.

I trust this is suited to your requirements, but should you have any queries please contact me.

Yours sincerely,

Alexander Nielsen NER RPENSW
Principal Consultant