



NSW RURAL FIRE SERVICE



Department of Planning & Environment
GPO Box 39
SYDNEY NSW 2001

Your Ref: SSD 9237
Our Ref: D18/5137

ATTENTION: Mandana Mazaheri

12 September 2018

Dear Mandana

Yarrabee Solar Exhibition of Environmental Impact Statement

I refer to your email dated 22 August 2018 seeking comment with the exhibition of an Environmental Impact Statement.

1. A Fire Management Plan (FMP) shall be prepared for the proposed facility in consultation with the local NSW RFS District Office. The FMP shall include:
 - 24 hour emergency contact details including alternative telephone contact
 - site infrastructure plan
 - fire fighting water supply plan
 - site access and internal road plan
 - construction of asset protection zones and their continued maintenance
 - location of hazards (physical, chemical and electrical) that will impact on the fire fighting operations and procedures to manage identified hazards during the fire fighting operations
 - such additional matters as required by the NSW RFS District Office.
2. The entire solar array development footprint shall be managed as an asset protection zone as outlined within section 4.1.3 of "Planning for Bush Fire Protection 2006" and the NSW RFS document "Standards for asset protection zones".

Postal address

Records
NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address


NSW Rural Fire Service
Planning and Environment Services (South)
Unit 2, 63 Cranbrook Road
BATEMANS BAY NSW 2536

T (02) 4472 0600
F (02) 4472 0690
www.rfs.nsw.gov.au
Email: pes@rfs.nsw.gov.au

3. A 10 metre defensible space, managed as an asset protection zone, shall be provided around the perimeter of the solar array development site to allow for emergency service personnel to undertake property protection activities.
4. A 20,000 litre water supply (tank) fitted with a 65mm Storz fitting shall be located adjoining the internal property access road within the required asset protection zone.

For any enquiries regarding this correspondence please contact Deborah Dawson on (02) 4474 0600.

Yours faithfully

A handwritten signature in dark ink, appearing to read 'Martha Dotter', with a stylized, cursive script.

Martha Dotter
A/Team Leader Development Assessment & Planning
Planning & Environment Services - South