

Emma Barnet

From: Brendan.M Hurley <Brendan.M.Hurley@fire.nsw.gov.au>
Sent: Monday, 28 September 2020 11:40 AM
To: Emma Barnet
Cc: Fire Safety
Subject: HPE CM: SEARs request for Prestons Waste Treatment Facility SSD 9346594. BFS20/2994

Categories: Objective

SEARs request for Prestons Waste Treatment Facility SSD 9346594

Dear Emma,

Fire & Rescue NSW (FRNSW) acknowledge the receipt of your email on the 17th September 2020, requesting input into Secretary's Environmental Assessment Requirements (SEARs) for the Prestons Waste treatment Facility from Golder on behalf of Hi Quality Treatment Services Pty Ltd (the Applicant).

It has been the experience of FRNSW that waste recycling facilities pose unique challenges to firefighters when responding to and managing an incident. Factors such as high and potentially hazardous fuel loads, facility layout, and design of fire safety systems have a significant impact on the ability to conduct firefighting operations safely and effectively. Consultation with organisations such as FRNSW throughout the development process enables the design and implementation of more effective fire safety solutions that help to mitigate the impact of incidents when they occur.

FRNSW have reviewed the documentation that was provided in support of the development and will not be providing comment at this time as there is currently insufficient information available regarding the fire safety and emergency response management aspects of the project.

We request that we be given the opportunity to review and provide comment once approvals have been granted and the project has progressed such that there is more relevant detailed information available.

FRNSW note that screening will be carried out under SEPP 33 to determine if the site is deemed potentially hazardous or offensive.

As additional details become available Fire & Rescue NSW requests to be consulted with respect to the proposed fire and life safety systems and their configuration at the project's preliminary and final design phases.

While there is currently no requirement for a fire safety study, FRNSW may request one be undertaken at a later stage should information be provided such it is deemed that the development poses unique challenges to the response to and management of an incident.

Please see the FRNSW fire safety guideline for Fire Safety in Waste Facilities that includes legislated requirements and development considerations (planning).

https://www.fire.nsw.gov.au/gallery/files/pdf/guidelines/guidelines_fire_safety_in_waste_facilities.pdf

If you have any queries regarding the above please contact the Fire Safety Infrastructure Liaison Unit, referencing FRNSW file number BFS20/2994. Please ensure that all correspondence in relation to this matter is submitted electronically to firesafety@fire.nsw.gov.au.

Regards
Brendan



INSPECTOR BRENDAN HURLEY

Team Leader Infrastructure Liaison

Fire Safety | Fire and Rescue NSW

E: brendan.m.hurley@fire.nsw.gov.au

M: 0438 601 582

1 Amarina Ave, Greenacre, NSW 2190

PREPARED FOR ANYTHING.

www.fire.nsw.gov.au



FRNSW CONFIDENTIALITY NOTICE AND DISCLAIMER

The information in this transmission may be confidential and/or protected by legal professional privilege, and is intended only for the person or persons to whom it is addressed. If you are not the intended recipient of this message you must not read, forward, print, copy, disclose, use or store in any way the information in this e-mail or any attachment it may contain. Please notify the sender immediately and delete or destroy all copies of this e-mail and any attachment it may contain.

Views expressed in the message are those of the individual sender, and are not necessarily the views of Fire and Rescue NSW (FRNSW). Use of electronic mail is subject to FRNSW policy and guidelines. FRNSW reserves the right to filter, inspect, copy, store and disclose the contents of electronic mail messages, as authorised by law.

This message has been scanned for viruses.
