

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF ASSESSMENT</b>	<b>CERTIFICATE No : SFC 51713600.1</b>	<b>Page 1 of 2</b>
---------------------------------------	--	--------------------



Report Sponsor	Certificate Issue Date	Products Name
AFS Systems Pty Ltd 110 Airds Road Minto NSW 2566	17/04/2018	<b>The fire resistance performance of AFS Rediwall loadbearing wall systems if tested in accordance with AS1530.4-2014</b>

Assessment Report Reference	Referenced Standard	Report Issue Date	Report Validity Date
EWFA 5173600.1	AS1530.4-2014	17/04/2018	30/04/2023

Introduction
The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for a complete description of the assessed construction.

Assessed systems description and performance
<p>Based on the discussion presented in the assessment report, it is the opinion of this testing authority that if the specimen described in section 1 of the report had been modified within the scope of section 3, it will achieve the performance as stated below if tested in accordance with the test method referenced in Section 4 and subject to the requirements of Section 7:</p> <p style="text-align: center;"><b>RW156C Wall System, FRL: 240/240/240, uniformly applied load is 700kN</b></p> <p style="text-align: center;"><b>RW200C Wall System, FRL: 240/240/240, uniformly applied load is 1000kN</b></p> <p style="text-align: center;"><b>RW256S Wall System, FRL: 240/240/240, uniformly applied load is 1000kN</b></p> <p><u>For full and detailed description of the assessed systems please refer to assessment report EWFA 51713600.1</u></p>

Conditions/Validity
<ul style="list-style-type: none"> <li>• THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.</li> <li>• Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.</li> <li>• The assessment report or short form assessment report does not provide an endorsement by Exova Warringtonfire Aus Pty Ltd of the performance of the actual products supplied. It is intended to provide a brief outline of the above referenced assessment reports and not to replace them.</li> <li>• The conclusions in this certificate of assessment relate to the configurations as detailed, and should not be applied to any other configuration. The conclusions expressed in this document assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.</li> <li>• Full copies of the assessment and relevant test reports may be obtained from the sponsor.</li> </ul>

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	Unit 2, 409-411 Hammond Road , Dandenong Victoria 3175	
<b>Phone / Fax</b>	T: +61 (0)3 9767 1000	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:  O. Saad	Reviewed By:  C. McLean