

26 August 2020

Our Ref: 179684

Asini Rajapakse

Student Planner

Industry Assessments

Department of Planning, Industry & Environment

4 Parramatta Square, Parramatta NSW 2150

asini.rajapakse@planning.nsw.gov.au

RE: RtS for SSD-9522 Kemps Creek Warehouse, Logistics and Industrial Facilities Hub

Thank you for notifying Sydney Water of SSD-9522 at 657-769 Mamre Road, Kemps Creek, which proposes development of a warehouse, logistics and industrial facilities hub including construction and operation of eight warehouses, comprising 166,225 m² of floor space, 744 parking spaces, and a 17-lot Torrens Title subdivision. Sydney Water has reviewed the application based on the information supplied and provides the following comments in line with our initial advice sent on the 5th of July 2019, to assist in planning the servicing needs of the proposed development.

Potable Water

- Limited potable water services are available in the area.
- A developer-led potable supply is being investigated to bring water from the north down Mamre Road to the site.
- Furthermore, Sydney Water is investigating a trunk main from the south along Mamre Road, anticipated by 2023-24. We will be working with TfNSW-RMS to deliver trunk mains in Mamre Road during road upgrades, subject to funding approval.
- Developer delivered precinct trunk mains will also be required to service the precinct.

Wastewater

- Long-term wastewater servicing for the proposed development will be provided from Sydney Water's proposed Upper South Creek Advanced Water Recycling Centre planned to be completed by 2025-26.
- Wastewater services to the proposed development may be initially staged to enable wastewater servicing from the St Marys Water Recycling Plant. This servicing should take up to two to three years to plan, design, and install. This timeframe is based on formal notification to Sydney Water of the expected date of connection.
- The developer would be responsible for all costs associated with the temporary servicing.
- While options for providing wastewater servicing to proposed development in isolation are technically viable, there is opportunity to investigate wastewater servicing options that meets the needs of the wider precinct.

Recycled Water

- Recycled water services are being investigated for the whole of the Western Sydney Aerotropolis Growth Area (WSAGA) including within this precinct.
- We are seeking information on potential recycled water demands, types of use and will provide further advice later in the year. Consideration should be given to incorporating third pipe reticulation and recycled water plumbing connections during your planning stages.

Stormwater

- Sydney Water is collaborating with the Western Sydney Planning Partnership Office, member councils, and agencies on typologies, flood, and waterway health models for the whole South Creek catchment. Consideration should be given to managing flooding and stormwater runoff quality.

This advice is not formal approval of our servicing requirements. Detailed requirements, including any potential extensions or amplifications, will be provided once the development is referred to Sydney Water for a Section 73 application. More information about the Section 73 application process is available on our web page in the [Land Development Manual](#).

The developer will need to engage a Water Servicing Coordinator (WSC). The WSC will be the applicant's point of contact with Sydney Water. The WSC can answer most questions the applicant might have on Sydney Water's developer process and charges. For a list of authorised Coordinators, either call 13 20 92 or visit www.sydneywater.com.au › Plumbing, building & developing › Developing › Providers › Lists.

Further advice and requirements for this proposal can be found in Attachments 1 & 2. If you require any further information, please do not hesitate to contact the Growth Planning Team at urbangrowth@sydneywater.com.au.

Yours sincerely,

**Kristine Leitch**

Growth Intelligence Manager
City Growth and Development, Sydney Water
1 Smith Street, Parramatta NSW 2150

Attachment 1

Sydney Water Servicing

A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained from Sydney Water.

The proponent is advised to make an early application for the certificate, as there may be water and wastewater pipes to be built that can take some time. This can also impact on other services and buildings, driveways or landscape designs.

Applications must be made through an authorised Water Servicing Coordinator. For help either visit www.sydneywater.com.au › Plumbing, building and developing › Developing › Land development or telephone 13 20 92.

Building Plan Approval

The approved plans must be submitted to the Sydney Water [Tap in™](#) online service to determine whether the development will affect any Sydney Water sewer or water main, stormwater drains and/or easement, and if further requirements need to be met.

The Sydney Water [Tap in™](#) online self-service replaces our Quick Check Agents as of 30 November 2015.

The [Tap in™](#) service provides 24/7 access to a range of services, including:

- building plan approvals
- connection and disconnection approvals
- diagrams
- trade waste approvals
- pressure information
- water meter installations
- pressure boosting and pump approvals
- changes to an existing service or asset, e.g. relocating or moving an asset.

Sydney Water's [Tap in™](#) online service is available at: <https://www.sydneywater.com.au/SW/plumbing-building-developing/building/sydney-water-tap-in/index.htm>

Attachment 2

Requirements for **Business Customers for Commercial and Industrial Property Developments.**

Trade Wastewater Requirements

If this development is going to generate trade wastewater, the property owner must submit an application requesting permission to discharge trade wastewater to Sydney Water's sewerage system. You must obtain Sydney Water approval for this permit before any business activities can commence. It is illegal to discharge Trade Wastewater into the Sydney Water sewerage system without permission.

The permit application should be emailed to Sydney Water's Business Customer Services at businesscustomers@sydneywater.com.au

A Boundary Trap is required for all developments that discharge trade wastewater where arrestors and special units are installed for trade wastewater pre-treatment.

If the property development is for Industrial operations, the wastewater may discharge into a sewerage area that is subject to wastewater reuse. Find out from Business Customer Services if this is applicable to your development.

Backflow Prevention Requirements

Backflow is when there is unintentional flow of water in the wrong direction from a potentially polluted source into the drinking water supply.

All properties connected to Sydney Water's supply must install a testable Backflow Prevention Containment Device appropriate to the property's hazard rating. Property with a high or medium hazard rating must have the backflow prevention containment device tested annually. Properties identified as having a low hazard rating must install a non-testable device, as a minimum.

Separate hydrant and sprinkler fire services on non-residential properties, require the installation of a testable double check detector assembly. The device is to be located at the boundary of the property.

Before you install a backflow prevention device:

1. Get your hydraulic consultant or plumber to check the available water pressure versus the property's required pressure and flow requirements.
2. Conduct a site assessment to confirm the hazard rating of the property and its services. Contact PIAS at NSW Fair Trading on 1300 889 099.

For installation you will need to engage a licensed plumber with backflow accreditation who can be found on the Sydney Water website:

<http://www.sydneywater.com.au/Plumbing/BackflowPrevention/>

Water Efficiency Recommendations

Water is our most precious resource and every customer can play a role in its conservation. By working together with Sydney Water, business customers are able to reduce their water consumption. This will help your business save money, improve productivity and protect the environment.

Some water efficiency measures that can be easily implemented in your business are:

- Install water efficiency fixtures to help increase your water efficiency, refer to WELS (Water Efficiency Labelling and Standards (WELS) Scheme, <http://www.waterrating.gov.au/>
- Consider installing rainwater tanks to capture rainwater runoff, and reusing it, where cost effective. Refer to <http://www.sydneywater.com.au/Water4Life/InYourBusiness/RWTCalculator.cfm>
- Install water-monitoring devices on your meter to identify water usage patterns and leaks.
- Develop a water efficiency plan for your business.

It is cheaper to install water efficiency appliances while you are developing than retrofitting them later.

Contingency Plan Recommendations

Under Sydney Water's [customer contract](#) Sydney Water aims to provide Business Customers with a continuous supply of clean water at a minimum pressure of 15meters head at the main tap. This is equivalent to 146.8kpa or 21.29psi to meet reasonable business usage needs.

Sometimes Sydney Water may need to interrupt, postpone or limit the supply of water services to your property for maintenance or other reasons. These interruptions can be planned or unplanned.

Water supply is critical to some businesses and Sydney Water will treat vulnerable customers, such as hospitals, as a high priority.

Have you thought about a contingency plan for your business? Your Business Customer Representative will help you to develop a plan that is tailored to your business and minimises productivity losses in the event of a water service disruption.

For further information please visit the Sydney Water website at: <http://www.sydneywater.com.au/OurSystemsandOperations/TradeWaste/> or contact Business Customer Services on 1300 985 227 or businesscustomers@sydneywater.com.au.