From:	Rory Toomey
To:	Alex Hill
Cc:	Emma Kirkman
Subject:	UNSW D14
Date:	Wednesday, 8 May 2019 5:35:43 PM
Attachments:	image003.png

Hi Alex

Thank you for your enquiry about this project.
The project was first reviewed in October by the SDRP.
The 2nd presentation to the SDRP made in November 2018 demonstrated significant improvements and a comprehensive response to advice given at SDRP 01 in October.

The only outstanding area of concern to the panel was the ESD performance of the proposed glazed facades. Inclusion of sunshading in the current scheme is acknowledged but the geometry of the proposed shading is not convincing for addressing solar heat gain in the mid to late afternoon. We encourage the design team to further their efforts on ensuring a high performing, energy efficient façade system.

With regards proximity to the White House heritage item, the panel had no concerns around impacts from the proposed building and supported the cascading terraced steps from the Level 1 terrace down to ground level.

Hope this assists your assessment.

Best

Rory Toomey
Principal Design Excellence
Architect NSW Registration 7743

Government Architect NSW
L3, 320 Pitt Street, Sydney NSW 2000
GPO Box 39, Sydney NSW 2001
T +61 (02) 98601458

Rory.Toomey@planning.nsw.gov.au
governmentarchitect.nsw.gov.au

18th April – 19th May 2019

Australian Heritage Festival

Connecting People, Places and the Past

Have you seen our Design Guide for Heritage and case studies?

Link to Design Guide for Heritage Webinar 14th May