

Reference: Schedule 2 – Part B

Project Approval Condition	Project Approval Description
B6	Before the issue of a Construction Certificate, the Applicant must provide the Certifying Authority with documented evidence that the products and systems proposed for use or used in the construction of external walls including finishes and claddings such as synthetic or aluminium composite panels comply with the requirements of the BCA.
E5	EXTERNAL WALLS AND CLADDING FLAMMABILITY Prior to the issue of any Occupation Certificate, evidence shall be submitted to the PCA demonstrating all external walls of the new building, including cladding, comply with the relevant requirements of the BCA, consistent with the requirements of Condition A6.

In Response to Condition B6 of Schedule 2 – Part B and Condition E5 of Schedule 2 – Part 5. The following certificates are attached to demonstrate compliance with NCC 2019.

Cladding Code	Cladding Type	Notes
EWP-01 & 02	Brick Cladding	Certificate attached
EWP-03 & 04 & 10	Colorbond Standing Seam Cladding	Certificate attached
EWP-05	Rendered Blockwork	Certificate attached (Render)
EWP-06	CFC Cladding	Certificate attached
EWP-08	Powdercoated Steel Screening	Custom Fabricated Steel Item certificate not applicable)
EWP-09	Colorbond Spandek Cladding	Certificate attached
EWG-01	RHI Replacement Glazing	Not applicable *
EWG-02	RHI New Entry Glazing	Not applicable *
EWG-03	Multicell Polycarbonate Cladding	Certificate not provided, cladding forms part of the fire engineering solution undertaken by Arup and submitted to McKenzie Group for assessment as part of other conditions. Refer to ARUP - Sydney Swans Headquarters and Community Centre FER – Job Number 270188 – FER Revision 01 - Dated 19 th of December 2019.

EWG-04	Frameless Glazed Foyer Entry	Not applicable *
EWG-05	Office Glazing	Not applicable *
EWG-06	Shopfront Glazing	Not applicable *
EWG-07	Reflective Glazing	Not applicable *

* Under BCA clause C1.9 (d) glazing is excluded from meeting the non-combustible criteria.



Henry Coates

Architect
BOAQ Reg 5281

18th August, 2021