

Patrick Copas

From: Zhaleh Najari alamouti <Zhaleh.ALAMOUTI@transport.nsw.gov.au>
Sent: Tuesday, 17 March 2020 12:27 PM
To: Patrick Copas
Cc: Olivia Hirst; Pahee Rathan
Subject: RE: Major Projects – New Request for Advice - MOD 1 - Diesel fuel storage and generator arrangements (SSD-9741-Mod-1) (Lane Cove)

Hi Patrick,

TfNSW has reviewed the proposed modifications to approved Data Centre - SSD 9741 and requests the following information for further assessment:

Section 1.1 of the Modification Application Report states that the zone in the eastern end will be utilised for an additional data hall which will require the lowest level to be set at RL8.4 instead of RL9.9:

- Will there be changes to the RL of the piles?
- Will the change impact on the LCT Ventilation Exhaust Tunnel?
- Please provide updated drawings which show the RL of the piles and distance of the piles relative to the Ventilation Exhaust Tunnel.

TfNSW requests the above information for further assessment prior to the determination of the application. Upon receipt of the information, TfNSW will further review and provide response accordingly.

Please contact me or Development Sydney Development.Sydney@rms.nsw.gov.au if you have any question.

Kind regards

Zhaleh Alamouti
A/Senior Land Use Assessment Coordinator
Planning and Programs
Greater Sydney
Transport for NSW
transport.nsw.gov.au

T 02 8849 2331
Level 5, 27 Argyle Street Parramatta NSW 2150