



NSW RURAL FIRE SERVICE

Department of Planning and Environment (Sydney Offices)
GPO Box 39
Sydney NSW 2001

Your reference: SSI-48492458
Our reference: DA20220920010735-SEARS-1

ATTENTION: Javier Canon

Date: Thursday 29 September 2022

Dear Sir/Madam,

Development Application
State Significant – SEARS – Electricity Generating Works
Waratah Super Battery Energy Storage System - Central Coast, (none)

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 16/09/2022.

The NSW Rural Fire Service has reviewed the information provided and advises that future stages of the development and subsequent referrals must be supported by a bush fire report prepared by a suitably qualified bush fire consultant which addresses the relevant sections including but not limited to section 8.3.9 of *Planning for Bush Fire Protection 2019*.

For any queries regarding this correspondence, please contact Surbhi Chhabra on 1300 NSW RFS.

Yours sincerely,

Adam Small
Supervisor Development Assessment & Plan
Built & Natural Environment

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au