



RFS



Department of Planning, Housing & Infrastructure (Sydney
Offices)
GPO Box 39
Sydney NSW 2001

Your reference: SSI-70610456
Our reference: DA20240612002376-SEARS-1

ATTENTION: Lauren Clear

Date: Wednesday 12 June 2024

Dear Sir/Madam,

**State Significant Development – Electricity Generating Works
Request for Secretary's Environmental Assessment Requirements
Rocky Point Road Eraring 2264, (none)**

Reference is made to correspondence dated 16/05/2024 seeking input regarding the preparation of Secretary's Environmental Assessment Requirements for the above State Significant Development in accordance with the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the information provided and advises that a bush fire assessment report shall be prepared which identifies the extent to which the proposed development conforms with or deviates from the relevant provisions of *Planning for Bush Fire Protection 2019*.

The proposal appears to be generally consistent with the aim and objectives of Planning for Bush Fire Protection 2019, however any development (as proposed) must comply with clause 8.3 (Other Non-Residential Development) of Planning for Bush Fire Protection 2019.

For any queries regarding this correspondence, please contact Surbhi Chhabra on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese
**Supervisor Development Assessment & Plan
Built & Natural Environment**

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au