

---

## OFFICIAL

Good afternoon Jess,

The Department of Defence (Defence) has reviewed the above-mentioned proposal and notes that the alignment of the proposed transmission lines and tower structures traverse the Singleton Military Area and Military Restricted Airspace R564A

It is therefore requested the Hunter Transmission Project (HTP) be required to liaise with Defence concerning the detailed design of the proposal, prior to and during construction, as well as the future operation and maintenance of the infrastructure.

This is address Defence requirements in relation to:

- the final coordinates and elevations of transmission lines and tower structures;
- electromagnetic interference on communications;
- obstacle lighting and marking of cables/lines and structures; and
- the use of cranes, drones and helicopters during construction.

Regards  
Anthony

**Anthony Deutschmann** | Assistant Director  
Land Planning and Regulation Directorate - Estate Planning Branch

---

**Department of Defence**  
Infrastructure Division | Security and Estate Group

**IMPORTANT: This email remains the property of the Department of Defence. Unauthorised communication and dealing with the information in the email may be a serious criminal offence. If you have received this email in error, you are requested to contact the sender and delete the email immediately.**

---