



RFS



Department of Planning, Housing and Infrastructure (Major Projects)

Locked Bag 5022
Parramatta NSW 2124

Your reference: SSI-82522960

Our reference: DA20250422001516-SEARS-1

ATTENTION: Vince Di Bono

Date: Monday 12 May 2025

Dear Sir/Madam,

Development Application
State Significant Development - SEARS - Industry
2536 Narriearra Road Tiboburra NSW 2880, 783//DP762129

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 22/04/2025.

- The New South Wales Rural Fire Service advises, that the preparation of an Environment Impact Statement, should incorporate a bush fire assessment report, prepared by a suitably qualified person, that addresses the aim and objectives of *Planning for Bush Fire Protection 2019* and which recommends measures to prevent a fire occurring within the site from developing into a bush/grass fire risk to the surrounding area. As the proposed development is for the construction of an underground high pressure gas pipeline and associated above ground infrastructure, it is considered to be hazardous industry under S8.3.9 of the *Planning for Bushfire Protection (PBP) 2019*;
- The bush fire assessment report, should address the extent and scope of the proposed works and associated issues as outlined in the APA Bulloo Interlink Pipeline, Scoping Report prepared by GHD Pty Ltd, Project Reference: 12658961, APA Group, V.Donat and dated 10 April 2025; and,
- Accordingly under S8.3.9 of *Planning for Bush Fire Protection 2019*, it is suggested a Fire Safety Study under the DPIE Hazardous Industry Planning and Assessment Papers (HIPAPs) should be prepared. This study should provide details of all credible fire hazards and the associated fire prevention and mitigation measures for the development. The Bush Fire Design Brief (BFDB) must address the appropriate protection measures to be provided commensurate with the bush fire hazards and associated risks with specific reference to 8.3.9 Hazardous industry and the preparation of a Fire Safety Study under the DPIE Hazardous Industry Planning and Assessment Papers (HIPAPs) and Section 8.3.10 Commercial and industrial development.

For any queries regarding this correspondence, please contact Craig Casey on 1300 NSW RFS.

Yours sincerely,

Joshua Calandra
Supervisor Development Assessment & Plan
Built & Natural Environment

1

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au