

18 November 2019

181230 FAAA

Group DLA Pty Ltd
Suite 1202, 109 Pitt Street
Sydney NSW 2000

Attention: Shane Berry

New Maitland Hospital

SSI 9775 Condition B4 – External Walls and Cladding

Dear Shane,

We certify that we have prepared the Façade Performance Specification for the New Maitland Hospital project.

The specification stipulates that the materials used by the Contractor on the facades of the building shall be non-combustible in accordance with BCA requirements.

The building materials proposed for the facades of the buildings can comply with this condition.

The proposed benchmark cladding products, Lysaght Enseam and Lysaght Custom Orb Accent 35, shown on the façade intent details TD001, TD002, TD003, TD004, TD017, TD018, TD019 and TD020 contained in the specification are deemed non-combustible as stated on the attached manufacturer's product advisory bulletin.

Should you require anything further please contact the undersigned.

Yours faithfully,

TAYLOR THOMSON WHITTING (NSW) PTY LTD
in its capacity as trustee for the
TAYLOR THOMSON WHITTING NSW TRUST



ROBERT MACKELLAR
Managing Director

Encl.











P:\2018\1812\181230\Letters\Facade\191118 NMH Façade external wall combustibility statement DL.docx

FLAMMABILITY OF LYSAGHT® STEEL PRODUCTS

SCOPE

Flammability of LYSAGHT® steel building products including roofing, walling, structural and rainwater goods manufactured from COLORBOND® steel, ZINCALUME® steel or galvanised steel from BlueScope.

THE LYSAGHT® STANDARD ROOFING RANGE*

				
CUSTOM ORB®	CUSTOM ORB ACCENT 21®	CUSTOM ORB ACCENT 35®	FLATDEK®	FLATDEK® II
				
KLIP-LOK® 406	KLIP-LOK 700 HI-STRENGTH®	KLIP-LOK CLASSIC® 700	SPANDEK®	TRIMDEK®

THE LYSAGHT ZENITH™ ROOFING RANGE*

				
LONGLINE 305® (Not Tapered)	BAROQUE™	DOMINION™	ENSEAM™	IMPERIAL™

*Not all products available in all regions. Please check product availability on www.lysaght.com or with your nearest Lysaght branch.

CONTEXT

Fire performance is a common query about the LYSAGHT® range of steel building products. The data presented in this bulletin has been compiled to provide designer's, builder's, installers, and users basic information on the fire resistance properties of LYSAGHT® steel products.

AUSTRALIAN NATIONAL CONSTRUCTION CODE

The Australian National Construction Code (NCC) sets out criteria for the determination of Non Combustible materials at:

C1.9.(e).(v) NON-COMBUSTIBLE MATERIALS

The following materials, may be used wherever a non-combustible material is required:

- (e) Pre-finished metal sheeting having a combustible surface finish not exceeding 1mm thickness and where the Spread-of-Flame Index of the product is not greater than 0:

And;

C3.7.1.1.(e) GENERAL CONCESSION - NON-COMBUSTIBLE MATERIALS

The following materials, though combustible or containing combustible fibres, may be used wherever a non-combustible material is required in the Housing Provisions:

- (e) Pre-finished metal sheeting having a combustible surface finish not exceeding 1mm thickness and where the Spread-of-Flame Index of the product is not greater than 0:

BLUESCOPE TESTING

BlueScope has commissioned CSIRO to undertake a comprehensive range of testing to determine the Flammability of various permutations of COLORBOND® steel, ZINCALUME® steel and galvanised steel material. These tests have been conducted in accordance with AS1530.3: SIMULTANEOUS DETERMINATION OF IGNITABILITY, FLAME PROPAGATION, HEAT RELEASE AND SMOKE RELEASE.

The results of this testing are summarised at Table 1 (next page).

Table 1:

Product	Test Cert	Ignitability Index ⁽¹⁾ (0-20)	Spread of Flame Index ⁽²⁾ (0-10)	Heat Evolved Index ⁽³⁾ (0-10)	Smoke Developed Index ⁽⁴⁾ (1-10)
0.70 BMT COLORBOND® steel Astro™	FNE11604	0	0	0	2
0.35 BMT COLORBOND® steel Woodland Grey®	FNE11605	0	0	0	2
0.55 BMT COLORBOND® Metallic steel Citi	FNE11606	0	0	0	1
0.42 BMT galvanised steel	FNE11600	0	0	0	2
0.42 BMT TRUECORE® steel	FNE11601	0	0	0	1
0.42 BMT ZINCALUME® steel	FNE11602	0	0	0	2

Explanation of four indices are assigned to materials tested to AS 1530.3

1. Ignitability index – a measure of the tendency for the gaseous pyrolysis products to be ignited during the test. Materials are rated from zero to 20, with materials that do not ignite having an index of zero.
2. Spread of flame index – a measure of the rate of radiant heat release once a material has ignited. Materials are rated on a scale of zero to 10. The maximum spread of flame index is 10, and the minimum zero.
3. Heat evolved index - is a measure of the quantity of radiant heat released by the test material in a specified time interval after ignition. Materials are rated on a scale of zero to 10, with increasing indices indicating increasing quantities of radiant heat evolution.
4. Smoke developed index - relates to the maximum optical density of the smoke produced during the test. The index has a range of zero to 10, with each increase of one index unit indicating a doubling in the optical density of the smoke produced

CONCLUSION

As a result of this testing we are able to determine that LYSAGHT® products manufactured from BlueScope's COLORBOND® steel, ZINCALUME® steel or galvanised steel materials all have a Spread-of-Flame index of 0 (zero) and as such are considered non-combustible materials in accordance with the National Construction Code clauses C1.12 (e) and C7.12 (e).

Additional information in relation to use of COLORBOND® steel products in bush fire prone areas may be sourced from The BlueScope Fact File Steel cladding details for bushfire-prone construction at: www.bluescopesteel.com.au/tools-and-resources/bushfire-design



IMPORTANT NOTE:

When considering the information presented in this bulletin it is important to understand the difference between “flammability” and “fire rating”.

Flammability is a measure of how easily a specific material ignites or sustains a combustion reaction.

Fire ratings are applied to complete systems and not to individual materials or components of the system. Fire ratings, or Fire Resistance Level (FRL) refer to the fully constructed system's ability to withstand structural failure, prevent the spread/penetration of flames and ability to insulate interior elements from maximum specified temperatures. It is often expressed in minutes without failure for each of the three elements i.e. 60/60/60, -/120/120 anywhere from 30 minutes up to 240 minutes.

National Construction Code:

The National Construction Code (NCC) is an initiative of the Council of Australian Governments (COAG) developed to incorporate all on-site construction requirements into a single code. The NCC comprises the Building Code of Australia (BCA), Volumes One and Two; and the Plumbing Code of Australia (PCA), as Volume Three.

PRODUCT DESCRIPTIONS

All descriptions, specifications, illustrations, drawings, data, dimensions and weights contained in this catalogue, all technical literature and websites containing information from Lysaght are approximations only. They are intended by Lysaght to be a general description for information and identification purposes and do not create a sale by description. Lysaght reserves the right at any time to:

- (a) supply Goods with such minor modifications from its drawings and specifications as it sees fit; and
- (b) alter specifications shown in its promotional literature to reflect changes made after the date of such publication.

DISCLAIMER, WARRANTIES AND LIMITATION OF LIABILITY

This publication is intended to be an aid for all trades and professionals involved with specifying and installing Lysaght products and not to be a substitute for professional judgement.

Terms and conditions of sale available at local Lysaght sales offices.

Except to the extent to which liability may not lawfully be excluded or limited, BlueScope Steel Limited will not be under or incur any liability to you for any direct or indirect loss or damage (including, without limitation, consequential loss or damage such as loss of profit or anticipated profit, loss of use, damage to goodwill and loss due to delay) however caused (including, without limitation, breach of contract, negligence and/or breach of statute), which you may suffer or incur in connection with this publication.

FOR YOUR NEAREST SUPPLIER VISIT:

WWW.LYSAGHT.COM

FOR SALES ENQUIRIES CALL 13 30 38

FOR TECHNICAL ENQUIRIES CALL 1800 641 417

© BlueScope Steel Limited 29 March 2019.

® product and colour names are registered trade marks of BlueScope Steel Limited. ™ product and colour names are trade marks of BlueScope Steel Limited ABN 16 000 011 058. The LYSAGHT® range of products is exclusively made by BlueScope Steel Limited trading as Lysaght

