

24 November 2022

The Secretary
NSW Department of Planning and Environment

Attention: Patrick Andrade

MA 347.2/2021 at 10 OLD WALLGROVE ROAD HORSLEY PARK 2175

Dear Sir or Madam

I refer to the Department's email of 17 November 2022 regarding modification application SSD-10391 - Mod 2 for the New Liverpool Primary School Mod 2 Internal Road and Staging for changes to staff parking, waste collection, bike parking and drop-off and pick-up; new internal road and median island to Lachlan Street; and associated changes to landscaping, infrastructure and fencing at 18 Forbes Street, Liverpool (Lot 1 DP 1137425) in the Liverpool City Council Local Government Area (LGA). Submissions need to be made to the Department by 5 December 2022.

Appendix Z - Addendum Infrastructure Management Statement includes the following advice.

2.0 Impact of Modifications to Proposed Services Infrastructure

2.1 Electricity

The changes to the project presented in the modification application do not impact the currently proposed incoming electrical infrastructure. Refer to the appendix of this letter for the previously issued SSDA report outlining the proposed infrastructure.

Notwithstanding, the applicant will need to contact Endeavour Energy's Customer Network Solutions Branch who are responsible for managing the conditions of supply with the proponent and their Accredited Service Provider (ASP), if this Development Application:

- Includes any contestable works projects that are outside of any existing approved / certified works.
- Results in an electricity load that is outside of any existing Supply / Connection Offer requiring the incorporation of the additional load for consideration.

For further advice the applicant can call Endeavour Energy via Head Office enquiries on business days from 9am - 4:30pm on telephone: 133 718 or (02) 9853 6666 and the following contacts:

- Customer Network Solutions Branch for matters related to the electricity supply or asset relocation. Alternatively contact can be made by email cicadmin@endeavourenergy.com.au .
- Easements Officers for matters related to easement management or protected works / assets. Alternatively contact can be made via email Easements@endeavourenergy.com.au .
- Property Branch for matters related to property tenure. Alternatively contact can be made by email network_property@endeavourenergy.com.au (underscore between 'network' and 'property').
- Field Operations Branch for safety advice for building or working near electrical assets in public areas. The site is in the area covered by Hoxton Park Field Service Centre. Alternatively contact can be made by email Construction.Works@endeavourenergy.com.au .

Should you wish to discuss this matter, or have any questions, please do not hesitate to contact me or the contacts identified above or in Endeavour Energy's previous submission in relation to the various matters. Due to the high number of development application / planning proposal notifications submitted to Endeavour Energy, to ensure a response contact by email to property.development@endeavourenergy.com.au is preferred.

Yours faithfully

Cornelis Duba | Development Application Specialist

M 0455250981

E cornelis.duba@endeavourenergy.com.au

51 Huntingwood Drive, Huntingwood NSW 2148. Dharug Country

endeavourenergy.com.au




**Endeavour
Energy**

**POWER
together**



Endeavour Energy respectfully acknowledges the Traditional Custodians on whose lands we live, work, and operate and their Elders past, present and emerging.


Site Plan from Endeavour Energy's G/Net Master Facility Model




























| G3E_FID | Feature Name | Component Name | G3E_CID | G3E_ID | LOT | SECTION | DP |
|----------|--------------|-------------------|---------|---------|-----|---------|---------|
| 66669388 | Crown Parcel | Crown Parcel Find | 1 | 1960364 | 1 | | 1137425 |

Please note the location, extent and type of any electricity infrastructure, boundaries etc. shown on the plan is indicative only. In addition it must be recognised that the electricity network is constantly extended, augmented and modified and there is a delay from the completion and commissioning of these works until their capture in the model. Easements benefitting Endeavour Energy are indicated by red hatching. Generally (depending on the scale and/or features selected), low voltage (normally not exceeding 1,000 volts) is indicated by blue lines and high voltage (normally exceeding 1,000 volts but for Endeavour Energy's network not exceeding 132,000 volts / 132 kV) by red lines (these lines can appear as solid or dashed and where there are multiple lines / cables only the higher voltage may be shown). This plan only shows the Endeavour Energy network and does not show electricity infrastructure belonging to other authorities or customers owned electrical equipment beyond the customer connection point / point of supply to the property. This plan does not constitute the provision of information on underground electricity power lines by network operators under Part 5E 'Protection of underground electricity power lines' of the *Electricity Supply Act 1995* (NSW).

Site Plan from Endeavour Energy's G/Net Master Facility Model



| LEGEND | |
|---|----------------------------------|
|  | Padmount substation |
|  | Indoor substation |
|  | Ground substation |
|  | Kiosk substation |
|  | Cottage substation |
|  | Pole mounted substation |
|  | High voltage customer substation |
|  | Metering unit |
|  | Switch station |
|  | Indoor switch station |
|  | Voltage regulator |
|  | Customer connection point |
|  | Low voltage pillar |
|  | Streetlight column |
|  | Life support customer |
|  | Tower |
|  | Pole |
|  | Pole with streetlight |
|  | Customer owned / private pole |
|  | Cable pit |
|  | Load break switch |
|  | Recloser |
|  | Proposed removed |
|  | Easement |
|  | Subject site |

Google Maps Street View. Padmount substation no. 1366 to the Lachlan Street road frontage.

