



Reg No.: 22/0998  
Your Reference: SSD-46246214  
To: NSW PLANNING & ENVIRONMENT

Wednesday, 14 December 2022

**Feedback on proposed changes to planning controls**

Controlled Activity: OLS ENQUIRY  
Location: HUNTER STREET WEST OVER STATION  
DEVELOPMENT  
Council: NSW PLANNING & ENVIRONMENT

Sydney Airport received the above request for comments from you on 05/12/2022.

The height of the Obstacle Limitation Surface (OLS) for Sydney Airport over the site is 156m AHD.

Any proposed development designed to be taller than 156m AHD, would be considered a controlled activity and be subject to the Federal Airports (Protection of Airspace) Regulations 1996.

Construction cranes may be required to operate at a height significantly higher than that of the proposed development and consequently, may not be approved under the Airports (Protection of Airspace) Regulations 1996.

Sydney Airport advises that approval to operate construction equipment (ie cranes) should be obtained prior to any commitment to construct.

Sincerely,

A handwritten signature in dark ink, appearing to read 'P Bleasdale'.

**Peter Bleasdale**  
Manager, Airfield Infrastructure Technical Planning

**Sydney Airport**

Sydney Airport Corporation Limited ACN 082 578 809 — The Nigel Love Building, 10 Arrivals Court, Locked Bag 5000  
Sydney International Airport NSW 2020 Australia — Telephone +61 2 9667 9111 — [sydneyairport.com.au](http://sydneyairport.com.au)

**SYD Classification: Confidential**