

7 June 2023

Chief Executive Officer  
Shellharbour City Council

Attention: Madeline Cartwright

**DAM0065/2023 at 50 & 86 DUNMORE ROAD DUNMORE 2529**

Dear Sir or Madam

I refer to the referral of 6 June 2023 from NSW Planning & Environment regarding NSW Government concurrence and referral request CNR-56108 for Shellharbour City Council Development Application DAM0065/2023 at 50 & 86 DUNMORE ROAD DUNMORE 2529 (Lot 10 DP 1281639, Lot 1 DP302910) for S4.55(2) modification application to DA0606/2022 for 'Early works/site preparation for the New Shellharbour Hospital, including demolition, earthworks, vegetation removal, construction access road, and associated works'. Submissions need to be made to Council by 27 June 2023.

Please refer to the attached copy of Endeavour Energy's submission made to Council via email on 12 January 2023 regarding Development Application DA0606/2022 at 86 Dunmore Road, Dunmore (Lot 10 DP 1281639) for 'Demolition of existing buildings, removal of fifteen trees, construction of access road, remediation of contaminated land and bulk earthworks' being Early Works for New Shellharbour Hospital.

The Modification Report No.1 DA0606/2022 includes the following advice but does not appear to address in further detail the proposal to 'Relocate existing aerial electricity lines located on Lot 1 DP302910 underground and associated works, including works in the road reserve'.

### **3.2 Need for Modification and Consideration of Alternatives**

The relocation of the stockpiling area arose from design progression and improvements to the works/construction methodology. Relocating the stockpile area from Lot 10 DP1281639 will provide more available space within the lot and improve the area available for vehicle movements throughout the site, and for ongoing works as part of the future/separate hospital construction scope. With the movement of vehicles required between the two lots, the relocation of the existing overhead electricity lines will improve safety onsite by removing a potential obstacle.

The applicant will need to make an application to Endeavour Energy's Customer Network Solutions Branch for the proposed asset removal / relocation. However please note that this does not constitute or imply the granting of approval by Endeavour Energy to any or all of the proposed asset removal / relocation.

Notwithstanding the proposed modifications the conditions and advice provided in Endeavour Energy's submission to DA0606/2022 essentially remain valid. Based on and subject to the foregoing Endeavour Energy has no objection to the Development Application.

Please find attached for the applicant's reference a copy of Endeavour Energy's Standard Conditions for Development Applications and Planning Proposals, Version 8, May 2023. For further advice the applicant can call Endeavour Energy via Head Office enquiries on business days from 9am - 4:30pm on telephone: 133 718 or (02) 9853 6666 and the following contacts:

- Customer Network Solutions Branch for matters related to the electricity supply or asset removal / relocation who are responsible for managing the conditions of supply with the applicant and their Accredited Service Provider (ASP). Alternatively contact can be made by email [cicadmin@endeavourenergy.com.au](mailto:cicadmin@endeavourenergy.com.au) .
- Easements Officers for matters related to easement management, protected works or other forms of property tenure / interests. Alternatively contact can be made by email [Easements@endeavourenergy.com.au](mailto:Easements@endeavourenergy.com.au) .
- Property Branch for matters related to property tenure. Alternatively contact can be made by email [network\\_property@endeavourenergy.com.au](mailto:network_property@endeavourenergy.com.au) (underscore between 'network' and 'property').
- Field Operations Branch for safety advice for building or working near electrical assets in public areas. The site is in the area covered by Shellharbour Field Service Centre. Alternatively contact can be made by email [Construction.Works@endeavourenergy.com.au](mailto:Construction.Works@endeavourenergy.com.au) .

Should you wish to discuss this matter, or have any questions, please do not hesitate to contact me or the contacts identified above or in Endeavour Energy's submission to DA0606/2022 in relation to the various matters. Due to the high number of development application / planning proposal notifications submitted to Endeavour Energy, to ensure a response contact by email to [property.development@endeavourenergy.com.au](mailto:property.development@endeavourenergy.com.au) is preferred.

Yours faithfully

**Cornelis Duba** | Development Application Specialist

M 0455250981

E [cornelis.duba@endeavourenergy.com.au](mailto:cornelis.duba@endeavourenergy.com.au)

51 Huntingwood Drive, Huntingwood NSW 2148. Dharug Country

[endeavourenergy.com.au](http://endeavourenergy.com.au)



**Endeavour  
Energy**

**POWER  
together**

