



AIR NAVIGATION, AIRSPACE AND AERODROMES BRANCH

CASA Ref: F24/25214-94

DPE ref: SSD-57838709 Email Fri 7/03/2025 3:30 PM

Erin White and Patrick Nash  
The Department of Housing and Infrastructure  
NSW

[erin.white@planning.nsw.gov.au](mailto:erin.white@planning.nsw.gov.au) [patrick.nash@planning.nsw.gov.au](mailto:patrick.nash@planning.nsw.gov.au) Submitting through the NSW Planning portal

**TEACHING AND LEARNING HUB (SSD-57838709)**  
**THE UNIVERSITY OF SYDNEY, CAMPERDOWN CAMPUS: CASA COMMENTS**

CASA has reviewed the Aviation Impact Assessment, by AviPro of 20 August 2024, for the proposed Teaching and Learning Hub at the University of Sydney, Camperdown Campus, south-eastern corner of the intersection of Parramatta Road and Western Avenue (also referred to as Ross Street).

CASA has no issues with the Aviation Impact Assessment. Notwithstanding that CASA is not an Approval Authority, CASA does not object to the Proposal. The proposed structure will not be a risk to Aviation Safety.

Note:

The Aviation Impact Assessment advises: “As a construction crane(s) will be close to an HLSs, the Guidelines require such cranes to be lit when “in the vicinity” of a Hospital HLS.”. AviPro is the ‘authority’ on marking and lighting of obstacles near Helicopter Landing Sites in NSW and is therefore best placed to advise on marking and lighting of the crane(s) .... when the height and configuration of the crane(s) is known.

Technical enquiries can be addressed to [David.Alder@casa.gov.au](mailto:David.Alder@casa.gov.au) or 02 62171342.

Yours sincerely

*David Alder*

David Alder  
Aerodrome Engineer  
13 March 2025