



Department of Primary Industries

OUT15/10330

Mr Thomas Piovesan
Industry Assessments
NSW Department of Planning and Environment
GPO Box 39
SYDNEY NSW 2001

Thomas.Piovesan@planning.nsw.gov.au

Dear Mr Piovesan,

Teys Abattoir, Bomen (DA220-7-2002 Mod 6) Proposed Modification

I refer to your email dated 15 April 2015 requesting comment from the Department of Primary Industries (DPI) in respect to the above matter.

Comment by NSW Office of Water

The NSW Office of Water has reviewed the Environmental Assessment (EA) for the proposed modification to the Teys Australia Bomen Processing Facility. The following comments and recommended condition of approval are provided to assist in finalising the assessment of the project.

- It is understood the proposed modification includes additional facilities within the existing hardstand areas and connections of roof and hardstand runoff to the existing drainage network. No increase in stormwater runoff from the site is predicted.
- Erosion and sediment controls are proposed for the construction phase of the project. It is recommended these be in accordance with the guideline, *Managing Urban Stormwater: Soils and Construction* (Landcom 2004).
- Based on the EA indicating no modifications to the runoff leaving the site and no additional disturbance to watercourses or the groundwater system, the Office of Water has no further comments.

Recommended Condition of Approval

Erosion and sediment controls are to be designed and implemented in accordance with the guideline, *Managing Urban Stormwater: Soils and Construction* (Landcom 2004).

For further information please contact Tim Baker, Senior Water Regulation Officer (Dubbo Office) on 6841 7403 or at tim.baker@water.nsw.gov.au.

Fisheries NSW and Agriculture NSW advise no issues.

Yours sincerely



Kristian Holz
Director Policy, Legislation and Innovation